

AIR HANDLER SCHEDULE

SYM.	LOCATION FLOOR BLDG.	MFG. MODEL	AIR FLOW			CHILLED WATER COIL										ELECTRICAL SUPPLY FAN		OPER. WT. (LBS)	FILTERS MERV 7 (30%)	REMARKS	
			SUPPLY FAN		OSA CFM	MBH	ENT AIR		LVG AIR		WATER				ROWS						FPI
			CFM	ESP			DB	WB	DB	WB	FLOW	ΔP	ENT	LVG							
AHU 1	MECH RM. SECOND FLOOR	TRANE M-17	7450	3"	1850	256.1	81.1°F	69.2°F	55.0°F	53.2°F	51.3 GPM	3.13'	45°F	55°F	6	-	208-3	10	1655	YES	PROVIDE WITH UV LIGHT AND VFD
AHU 2	MECH RM. SECOND FLOOR	TRANE M-17	7520	3"	1400	244.6	81.1°F	69.2°F	55.0°F	53.3°F	48.9 GPM	2.92'	45°F	55°F	6	-	208-3	10	1558	YES	PROVIDE WITH UV LIGHT AND VFD
AHU 3	MECH RM. THRD FLOOR	TRANE M-17	8170	3"	1400	287.7	81.1°F	69.2°F	55.0°F	53.1°F	57.6 GPM	3.81'	45°F	55°F	6	-	208-3	10	1558	YES	PROVIDE WITH UV LIGHT AND VFD

* COIL SIZE & GPM BASED ON 100% OSA UPON DRV FAILURE.

ENERGY RECOVERY UNIT-DEDICATED OSA AHU

SYM.	LOCATION FLOOR BLDG.	MFG. MODEL	AIR FLOW				SUMMER						WINTER		PREHEAT COIL										ELECTRICAL				OPER. WT. (LBS)	FILTERS MERV 13	REMARKS
			SUPPLY FAN		EXH FAN		OSA IN		RA		OSA OUT				ENT AIR		LVG AIR		WATER				ROWS	FPI	VOLTAGE	SUP FAN	EXH FAN				
			CFM	ESP	CFM	ESP	DB	WB	DB	WB	DB	WB	DB	WB					DB	WB	FLOW	ΔP				ENT	LVG	HP			
 1	MECH RM. ATTIC	COOK — OR EQUAL	4650	3/4"	4045	2.0"	91.0	81.0	76.0	50%	76.0	69.2	26°F	53.9°F	71.200	53.9"	39.2"	68.0"	40%	7.1 GPM	2.13"	180	160	TBD	—	208—3	3	5	3850	YES	

CHILLER SCHEDULE

SYM.	MFG. & MODEL No.	SERVICE	LOCATION	TYPE	EVAPORATOR					CONDENSER					POWER			EFFICIENCIES		OPER. WT. (LBS)	REMARKS	
					WATER			PD	CAPACITY	WATER			PD (FT)	FOULING FACTOR	AMBIENT DESIGN	V-PH	MCA	MOCP	KW/TON			EER
					FLOW	IN	OUT			GPM	IN	OUT										
CH 1	TRANE CGAM 70	FIRST FLOOR MECH RM	EXTERIOR	AIR COOLED	157 GPM	54 F	44 F	6.3 FT	65.4 TONS	-	-	-	-	-	91F	208-3	343.9	400	0.98	11.9	4000	

PUMPS

SYM.	MANUFACTURER & MODEL NO.	FLOW RATE	WATER Δ P	RPM	ELECTRICAL		OPER. WT. (LBS)	PUMP EFF.	BLDG FLOOR LOCATION	REMARKS
					VOLTAGE	HP				
CHWP 1	BELL & GOSSET 1510 2 1/2BB	157 GPM	80 FT	1750	208-3	10	360	74.88	FIRST FLOOR MECH ROOM	
CHWP 2	BELL & GOSSET 1510 2 1/2BB	157 GPM	80 FT	1750	208-3	10	360	74.88	FIRST FLOOR MECH ROOM	STAND-BY
HWP 1	BELL & GOSSET 1510 1 1/2"BC	65 GPM	80 FT	1750	208-3	5	210	62.27	FIRST FLOOR MECH ROOM	WITH VFD
HWP 2	BELL & GOSSET 1510 1 1/2"BC	65 GPM	80 FT	1750	208-3	5	210	62.27	FIRST FLOOR MECH ROOM	STAND-BY WITH VFD

HEATING HOT WATER HEAT EXCHANGER

SYM.	MANUFACTURER & MODEL NO.	FLOOR BLDG.	LOCATION	SIZE	TUBE (WATER)				STEAM		REMARKS
					EWL	LWT	GPM	PASS	PRES.	#/HR	
HX 1	BELL & GOSSET TYPE SU	FIRST FLOOR MECH RM	STEAM RM.	83-4	160	180	85	-	15	850	-
HX 2	BELL & GOSSET TYPE DIAMONDBACK	FIRST FLOOR MECH RM	STEAM RM.	-	120	140	155	-	15	1550	DOUBLE WALL HEAT EXCHANGER FOR DOMESTIC USE

CONDENSATE RETURN PUMP

SYM.	MANUFACTURER & MODEL NO.	EDR	DISCHARGE PRESSURE	RECEIVER GALLON CAPACITY	BLDG FLOOR LOCATION	REMARKS
CRP 1	SPIRAX / SARCO	10,900	100 PSI	PER MFG. ROUNDS	BEQ STEAM ROOM	PRESSURE POWERED

SUPPLY DIFFUSER SCHEDULE

UNIT NO.	MANUFACTURER	MODEL	NECK SIZE	FRAME TYPE	RANGE C.F.M.	REMARKS
AH	KRIEGER (OR EQUAL)	51240	6x6	23	0-120	PROVIDE AS 4-WAY DISCHARGE PATTERN UNLESS SHOWN OTHERWISE ON PLANS
BH			8x8		121-210	
CH			10x10		211-330	
DH			12x12		331-470	
EH			14x14		471-640	
FH			16x16		641-1000	
GH		5880	30x16	22	600-1300	DOUBLE DETECTION ADJUSTABLE GRILLE w/ ALUMINUM USD

NOTES:

1. USE SURFACE MOUNT IN GYP. BOARD CEILING FRAME TYPE 1 SUBSCRIPT "H" WHEN SHOWN DENOTES GYP. BOARD CEILING.

RETURN/EXHAUST REGISTER SCHEDULE

UNIT NO.	MANUFACTURER	MODEL	NECK SIZE	FRAME TYPE	RANGE C.F.M.	REMARKS
AAH	KRIEGER (OR EQUAL)	SS80H (SQUARE)	6x6	23	0-160	3/4" SPACED FIBER GLASS, 35° DEFLECTION
BBH			8x8		161-280	
BBH			10x10		281-435	
BBH			12x12		436-625	
BBH			14x14		626-855	
BBH			16x16		856-1110	
BBH			18x18		1111-1800	
BBH		SS80H (RECTANGULAR)	36x16	22	750-2000	3/4" SPACED FIBER GLASS, 35° DEFLECTION

NOTES:

1. USE SURFACE MOUNT IN GYP. BOARD CEILING FRAME TYPE 1 SUBSCRIPT "H" WHEN SHOWN DENOTES GYP. BOARD CEILING.
2. ALL RETURN AIR GRILLS FOR FAN POWERED BOXES SHALL BE MINIMUM 18X12 FILTER GRILLE WITH FILTERS.



SHEET NO. 1
 DATE: 09-11-2011
 SCALE: AS INDICATED
 DRAWN BY: [Name]
 CHECKED BY: [Name]
 PROJECT: M-601
 140 WEST 2ND AVENUE, SUITE 1000, DENVER, CO 80202
 (303) 733-1111
 www.sullivan-engineering.com

M-601

07 NOVEMBER 2011 COURT HOUSE, BAY RECORD DRAWINGS