TAG	PUMP TYPE	SERVICE	LOCATION	FLUID TYPE	FLUID TEMP (°F)	GPM	HEAD (FT H2O)	NSPH REQD (FT)	IMPELLER DIAMETER (IN)	MIN EFF. (%)
BP- 1 TO 6	INLINE	PRIMARY HW (BOILER RECIRC)	MECH 1403	WATER	140	SEE BOILER SCHEDULE				
P-1,2	BASE MOUNTED	SECONDARY HOT WATER	MECH 1403	WATER	140	160	90	7.7	9.75	66.4
P-3,4,5	BASE MOUNTED	PRIMARY CHILLED WATER	CHILLER YARD	WATER	42	173.7	30	6.2	6.0	78.4
P-6,7	BASE MOUNTED	SECONDARY CHILLED WATER	MECH 1304	WATER	42	347.4	70	5.2	8.750	77.1
P-8,9	INLINE	CONDENSER HEAT RECOVERY	CHILLER YARD	WATER	150	32	75	9.1	4.875	42.8

NOTES:
1. MOTORS SHALL BE PREMIUM EFFICIENCY TYPE.
2. UNIT SHALL BE SERVED BY VARIABLE SPEED DRIVE.
3. PUMPS SHALL BE CONFIGURED IN PARALLEL CONFIGURATION WITH 2 PUMPS SIZED FOR FULL LOAD CONDITIONS + 1 SHARED REDUNDANT PUMP.
4. PROVIDE PUMP WITH FULL SIZE IMPELLER; BALANCE TO THE DESIGN CONDITIONS USING THE VFD.
5. MOTORS SHALL BE TEFC AND RATED FOR OUTDOOR CONDITIONS.

HOT WATER BOILER SCHEDULE

TAG	TYPE	MAX OUTPUT (MBH)	MAX GAS INPUT (MBH)	MIN GAS INPUT (MBH)	MIN GAS PRESS (IN WG)	WATER DATA			
						EWT (°F)	LWT (°F)	GPM	WPD (FT H2O)
B-1	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11
B-2	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11
B-3	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11
B-4	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11
B-5	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11
B-6	FIRETUBE / CONDENSING	379	399	80	4.0	110	140	26	11

NOTES:
1. PROVIDE WITH MULTIPLE BOILER CONTROLLER AND INTERFACE TO BUILDING DDC SYSTEM (BACNET COMPATIBLE)
2. PROVIDE WITH DIRECT SPARK IGNITION SYSTEM, MODULATING GAS VALVE AND BURNER CAPABLE OF 5:1 TURNDOWN.
3. BOILER SHALL ACHIEVE 95% THERMAL EFFICIENCY & MEET ALL CURRENT LOW NOx REGULATIONS.
4. BOILER TO BE SUPPLIED WITH FORCED COMBUSTION AIR DRAFT SYSTEM.
5. PROVIDE CONCENTRIC STAINLESS STEEL FLUE AND THRU-WALL TERMINATIONS FOR VENTING AND COMBUSTION AIR INLET AS INDICATED ON PLANS.
6. PROVIDE WITH MANUFACTUER'S CONDENSATE TRAP AND NEUTRALIZATION KIT FOR CONDENSATE DISCHARGE.
7. UNIT SHALL COMPLY WITH ASME CSD-1 REQUIREMENTS FOR ELECTRICAL (PART CE) AND WATERSIDE CONTROL (PART CW).

CHILLED WATER BUFFER TANK (CWBT) SCHEDULE

TAG	TYPE	SERVICE	LOCATION	SIZE DIA x HT (IN)	CONN. SIZE (IN)	CAPACITY (GAL)	BASIS OF DESIGN		NOTES
							MANUF	MODEL	
CWBT-1	VERTICAL	CHILLED WATER	CHILLER YARD	48 X 96	6" FLANGE	680	CEMLINE	V680CWB6-F-C-20-O	1 - 2

NOTES:
1. PROVIDE WITH R-20 (2") INSULATION WITH FACTORY PRE-INSTALLED HEAT TAPE AND JACKETING FOR OUTDOOR INSTALLATION; TOTAL INSTALLED HEAT TRACING = 60 FT @ 5 W/FT (300W).
2. UNIT SHALL BE ASME RATED PRESSURE VESSEL - RATED TO 125PSIG @ 400°F; BUILT TO ASME SECTION VIII, DIVISION 1.

2/4/2015 11:22