

YORKTOWN NAVAL WEAPONS STATION REPLACE CHILLER YORK 2075



York 2075

Main Gate #3

YORK 2075 BEQ

100 Ton Trane
Chiller

2075

1807

MCSFR Training
Center (ISMT)





REFRIGERATING MACHINE
UN2857

X390005990100



FOR OUTDOOR USE

SERIAL NUMBER

U13L39763

MODEL NUMBER

CLAH 120A 2X02 AX02 A1A1 A1AX XA1C 1A4X XXXX XA1A 3A1D XXXL XX

RATED
VOLTAGE/HZ/PH

208/60/3

MIN CKT
AMPACITY (A)

444

MAX FUSE/
BREAKER (A)

500

VOLT UTILIZATION
RANGE

187-229

SHORT-CIRCUIT
CURRENT RATING (A)

5000

RATED
VOLTAGE/HZ/PH

115/60/1

VOLT UTILIZATION
RANGE

100-126

WATTS

CKT 3 FREEZE
PROTECTION
HEATERS

630

WATTS

CKT 4 BUFFER
TANK HEATER

RLA LRA

COMPR MTR 1A 91 560

COMPR MTR 1B 91 560

COMPR MTR 1C

RLA LRA

COMPR MTR 2A 91 560

COMPR MTR 2B 91 560

COMPR MTR 2C

FIXED SPEED
FAN MOTORS

6

2 SPEED
FAN MOTORS

VFD
CONTROLLED
FAN MOTORS

2

PUMP
MOTORS

0

QTY HP EA FLA EA

1.27 6.2

QTY HP EA FLA EA

1.27 6.2

QTY HP EA FLA EA

0

VFD INPUT AMPS MTR VOLT

7.3

VFD INPUT AMPS

7.3

VFD INPUT AMPS

7.3

REFRIGERANT

FACTORY

CHARGED

TYPE
NUMBER

410A

CKT 1 (LBS)

90

CKT 2 (LBS)

90

REFGT CHARGE

410A

OIL CHARGE

OIL 00079

CKT 1 (GAL)

3.5

CKT 2 (GAL)

3.5

HIGH
SIDE

650

DESIGN PRESSURES (PSI)

LOW
SIDE

238

WIRING DIAGRAM BOOK

5720 6004 8100

INSTALLATION, OPERATION
& MAINTENANCE MANUAL

CC-SUK17E-EN



LISTED

LIQUID CHILLER
SELF-CONTAINED UNIT
8510

X39002008010C

Unit Model Number Complies
With Efficiency Requirements of
ASHRAE Standard 90.1

X39002008010C

NAVFAC MIDLANT
713354







