



PCA ENGINEERING, INC.

57 CANNONBALL ROAD • P.O. BOX 196 • POMPTON LAKES, NEW JERSEY 07442

Telephone: 973-616-4501 • Toll Free: 1-800-666-PCA 1 • Fax: 973-616-4451

Regional Offices in MA, PA and VA

ENGINEERING • CORROSION CONTROL • TESTING & MATERIALS • ENVIRONMENTAL SERVICES

January 23, 2019

Pumping Services, Inc.
201 Lincoln Boulevard
Middlesex, NJ 08846

Att: Mr. Walter Pytlik

Re: PCA Job No. 36142

Dear Mr. Pytlik:

On January 15, 2019, PCA Engineering, Inc. personnel were on site at the Naval Weapons Station Earle, Building 558, Colts Neck, New Jersey facility to perform start-up potential testing of the fire water storage tank.

The fire water storage tank measures 50 feet in diameter by 21 feet in height. The galvanic cathodic protection system designed to protect the tank consists of 20 high potential magnesium anode rods and two (2) permanent copper/copper sulfate reference cells. It was noted that the center reference cell has been moved to the north side of the tank.

A layout of the cathodic protection system is as shown on PCA Drawing No. CW-36142-01.

To test the effectiveness of the galvanic cathodic protection system, structure-to-soil potential measurements were taken using a Fluke Model 73 High Resistance Voltmeter in conjunction with the permanent copper/copper sulfate reference cells.

PEOPLE • CAPABILITY • ACHIEVEMENT FOR OVER 55 YEARS

Mr. Walter Pytlik
Re: PCA Job No. 36142
January 23, 2019
Page 2

The potential readings obtained (-0.941 for the north side and -1.120 for the south side) indicate the cathodic protection system is operating effectively as outlined in the NACE Publication SP0193-2016, "External Cathodic Protection of On-Ground Metallic Storage Tank Bottoms".

PCA Engineering, Inc. recommends that the cathodic protection system be tested annually by qualified corrosion control personnel.

In addition, records of the operation of the cathodic protection must be maintained to demonstrate compliance with the performance standards.

We trust the enclosed to be complete and satisfactory; however, should there be any questions or if additional information is required, please do not hesitate to contact us.

Sincerely,


PCA ENGINEERING, INC.

Technician:



RANDALL B. SMITH
NACE CORROSION TECHNICIAN
CERTIFICATION NO. 6339
PCA ENGINEERING, INC.

Edited and
Reviewed by:



WILLIAM J. SIMPSON
NACE CP SPECIALIST
CERTIFICATION NO. 3634
PCA ENGINEERING, INC.

RBS:rd

PCA ENGINEERING, INC.

Notwithstanding anything contained in this report, nothing herein shall be construed as a representation, warranty or guarantee, either express or implied, regarding the future structural integrity or future life expectancy of any of the items tested. This report and any analysis provided is in all respects subject to and shall be interpreted within the limitations and parameters of the test procedures performed. In the event testing is performed using a sampling procedure, this report and any analysis shall be limited to those areas actually tested and the type of test conducted, and the customer is cautioned not to extrapolate the results of the test samples.

A copy of this survey shall remain on-site to comply with State regulations.