

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES		
2. AMENDMENT/MODIFICATION NUMBER 040ADV-26-R-0016-C0004		3. EFFECTIVE DATE 05/05/2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
				Same As Issuing Office			
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NUMBER 040ADV-26-R-0016	
				☒		9B. DATED (SEE ITEM 11) 01/30/2026	
				☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

AMENDMENT CONTROL NUMBER: 040ADV-26-R-0016

SUMMARY OF CHANGES: All Prospective contractors, the purpose of this amendment is to:

1. Clarify the previous responses to Q.21 and Q.144.
2. Provide clarification to the hazardous materials scope.
3. All terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER Troy D. White, Supervisory Contracting Officer	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Previous edition unusable

Q & A #21 states that we will need to work after hours (4 pm to midnight to hammer drill) to anchor the shelving to the floor. Yes – this will cause a lot of noise and we will have to figure costs for working off hours. Can we work Saturday's to do the hammer drilling?

A: Work outside normal working hours, including Saturdays, may be permitted subject to approval and coordination with the Government. The Contractor shall include any costs associated with off-hours work in their proposal.

Q & A #144, the spec says 350 lbs per shelf but drawings A303 – Top of page is the Shelving notes and in item #1 says to provide 18 gauge shelves. If it was to be 18 gauge, then capacity (depending on manufacture) would range between 800 and 1000 lbs per shelf. A much more expensive shelf. Please confirm the Government still want us to provide shelves under the guide lines of 350 lbs per shelf and that the gauge of shelf will be as needed to meet that 350 lbs capacity.

A: The shelving shall meet the specified minimum load capacity of 350 lbs per shelf. The gauge of steel shall be as required by the manufacturer to achieve this performance. The note indicating 18-gauge shelves is not intended to increase the required load capacity beyond the specified 350 lbs per shelf. Provide shelving that meets the specified performance requirements.

Hazardous Materials Scope Clarification

1. Hazardous Materials Survey: Any survey provided by the Government shall be reviewed and incorporated into the work. See document, Hazardous Materials Survey Report_GPO Safety.
2. Asbestos (ACM): Abatement will be performed by the Government under a separate contract. Offerors shall not include asbestos abatement in their proposals.
3. Lead-containing materials: Work associated with lead shall be included in the Contractor's scope in accordance with applicable regulations.
4. Unidentified conditions: Offerors shall not assume presence or absence of hazardous materials. If encountered, work shall stop in the affected area and be addressed per contract provisions.
5. Contractor shall coordinate with Government performed abatement activities.