

PPI No.	Date Submitted	Reference			Question	Government Response	Gov't Responder Name, Email
		Page	Section	Para.			
1	23-Apr-26	N/A	N/A	N/A	Would the government consider a one-week extension upon receipt of answers to questions to allow for incorporation into the proposal?	No.	
2	23-Apr-26	10	Item 7.2	1	Item 7.2, Page 10, Paragraph 1 - Extraction Well Redevelopment - Extraction well development is included under work element 07; however, bullet #2 states "the contractor should plan to re-develop three extraction wells on an annual basis under the major service calls". Is the intent that no costs be allocated to extraction well redevelopment under Work Element 07 and redevelopment costs will be funded under the 3 anticipated major service calls under work element 06? Or is extraction well redevelopment costs including oversight and subcontractor incorporated into work element 07?	work element 7 outlines redevelopment of three wells annually and costs should be relective of that. Service calls are variable in nature and may or may not include redevelopment.	
3	23-Apr-26	N/A	N/A	N/A	General: Please confirm that equipment purchase costs including pumps are not included under any of the work elements.	Replacing pumps or other equipment has been covered under the Service Call tasks. We just recently replaced a well pump and the VFD for another well under the Service Call task.	
4	23-Apr-26	11	Item 7.5	N/A	Item 7.5, Page 11 - When do the various (NPDES, MCES, and DNR Water appropriations) permits expire? Can the most recent permits be provided? The NPDES permit in the available OM&M Manual expired in December 2021.	We are currently operating under an expired NPDES permit. KGS submitted the NPDES renewal application to MPCA on 13 December 2024. MPCA is working on the permit. The MCES permit was recently renewed.Yes, the most recent permits can be provided.	
5	23-Apr-26	19	Item 7.3	N/A	Item 7.3, Page 19 - Can information be provided regarding the quantity and characterization of waste generated including hazardous waste in previous years?	Waste generated in the past has been non-hazardous. Waste volumes vary from year to year. In 2025, approximately 42,000 gallons of waste water was discharged to the sanitary sewer under the MCES permit for a fee of \$53.00.	
6	23-Apr-26	4	Item 2.1	N/A	Item 2.1, Page 4 - Can the most recent most recent Annual Monitoring Report Naval Industrial Reserve Ordnance Plant Fridley, Minnesota February 2026 be provided? It is not publicly available on the administrative record.	Reference the most recent one is. The current report is in review with regulatory agencies. Please reference most recent publicly avavailable document.	
7	23-Apr-26	6	Item 3.1	N/A	Item 3.1, Page 6 - Can you confirm approximate historical polymer dosing rates? The 2025 OM&M Manual indicates estimates of 44 lbs of per day of ChemTreat CL4635. Is that in line with historical values?	The chemical tank is replenished with approximately 350 gallons of chemical once per quarter.	
8	23-Apr-26	7	Item 3.1	N/A	Item 3.1, Page 7 - Historically, what acids have been used to clean the air stripper? Is pressure washing and citric acid generally sufficient?	Pressure washing is typically sufficient.	
9	23-Apr-26	11	Item 8	N/A	Item 8, Page 11 - Are there annual fees associated with the internet system, SCADA system and/or alarm system? Can historical receipts be provided?	We do not have receipts for these items, but we do pay internet which is cellular AT&T which is around \$150 per month based on usage, and we renew the Win911 alarm software license annually. The most recent renewal was approximately \$1,500.00	