

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION
NASA SHARED SERVICES CENTER

RECOMMENDATION AND DETERMINATION TO SOLICIT FROM ONE SOURCE
OR BRAND NAME

PICK ONE

Sole Source:

☐ I recommend that NASA, NASA Shared Services Center negotiate with Vendor Name only for Enter Supply or Service to be procured. The total estimated cost of this effort is Enter Dollar Amount and the estimated period of performance or lead-time for delivery is Date.

OR

Brand Name Justification:

☒ I recommend that NASA, NASA Shared Services Center negotiate only with vendors who can provide the subject band name from Schneider Electric for Modicon M580 PLC Equipment. The total estimated cost of this effort is [REDACTED] and the estimated period of performance or lead-time for delivery is two to three weeks after procurement..

This recommendation is for the acquisition of supplies or services determined to be reasonably available from only one source/only one manufacture. Competition is impractical for the following reasons (please answer the questions below):

1. **What are the reasons for soliciting only the suggested source/suggested brand name?** Please provide the unique characteristics of the items or services along with the supporting rationale and the market research performed to substantiate your reason for the suggested source/brand name.

GRC uses Modicon Schneider Electric PLC equipment for many of their controls and instrumentation readings in the facilities. IRT at GRC has begun upgrading its aging Quantum PLC to M580. This procurement from a brand name is to ensure compatibility and uniformity among GRC facilities and the current PLC system, minimizing the number of spares that need to be purchased and allowing for cross-training center-wide.

2. **What is the impact to the government if another vendor/brand is used?** Include any dollar, schedule, or compatibility impacts if possible.

Using any other PLC equipment would require a complete rewiring of the current system, an entirely new program to be created, and would not be financially feasible, especially since IRT has already started its M580 upgrade.

ADDITIONAL COMMENTS:

The distributor shall be Authorized/Certified through the Schneider Electric Alliance Industrial Automation Distributor (IAD) program. Verification in SE's IAD and verification as an authorized distributor can be confirmed at <https://www.se.com/us/en/partners/distributors/industrial-automation/>.

[REDACTED]

[REDACTED]

[REDACTED]