

KEYNOTES

PANEL TPP1 SCHEDULE											LOCATION: NETWORK 113				
MLO RATING		125 A		208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.		10KAIC SURFACE			
CKT NO.	LOAD DESCRIPTION			BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION		CKT NO.	
1	REC - COMM 1			20	5.0 A			7.2 A			15	EB-1		2	
3	REC - COMM 2			20		5.0 A			7.2 A					4	
5	REC - COMM 3			20			5.0 A			0.0 A				6	
7	REC - COMM 4			20	5.0 A			0.0 A			30	SPARE		8	
9	REC - COMM 5			20		5.0 A			0.0 A					10	
11	REC - AT PANEL			20			1.5 A			0.0 A	30	SPARE		12	
13	OU-2 & IU-2			25	12.0 A			0.0 A				20	SPARE		14
15						12.0 A			0.0 A		20	SPARE		16	
17					NETWORK N CABINET - 1			20			10.0 A		0.0 A	20	SPARE
19	NETWORK P CABINET - 1			20	10.0 A			0.0 A			20	SPARE		20	
21	NETWORK N CABINET - 2			20		10.0 A			0.0 A		20	SPARE		22	
23	NETWORK P CABINET - 2			20			10.0 A			0.0 A	20	SPARE		24	
25	SPD			30	0.0 A			0.0 A			20	SPARE		26	
27					1		0.0 A			0.0 A		20	SPARE		28
29							0.0 A				0.0 A		20	SPARE	
TOTAL CONNECTED AMPS:					A: 38.2		B: 38.2		C: 26.5						

PANEL TPP2 SCHEDULE											LOCATION: NETWORK 214		
MLO RATING		125 A		208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.		10KAIC SURFACE	
CKT NO.	LOAD DESCRIPTION		BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION		CKT NO.
1	REC - COMM - 1		20	5.0 A			9.6 A			20	EB-2		2
3	REC - COMM - 2		20		5.0 A			9.6 A					4
5	REC - COMM - 3		20			5.0 A			0.0 A	30	SPARE		6
7	REC - COMM - 4		20	5.0 A			0.0 A						8
9	REC - COMM - 5		20		5.0 A			0.0 A		30	SPARE		10
11	OU-3 & IU-3		25			12.0 A			0.0 A				12
13				12.0 A			0.0 A			20	SPARE	14	
15	NETWORK P CABINET - 1		20		10.0 A			0.0 A		20	SPARE		16
17	NETWORK N CABINET - 1		20			10.0 A			0.0 A	20	SPARE		18
19	NETWORK P CABINET - 2		20	10.0 A			0.0 A			20	SPARE		20
21	NETWORK N CABINET - 2		20		10.0 A			0.0 A		20	SPARE		22
23	SPARE		20			0.0 A			0.0 A	20	SPARE		24
25	SPD		30	0.0 A			0.0 A			20	SPARE		26
27					0.0 A			0.0 A		20	SPARE		28
29					0.0 A			0.0 A		20	SPARE		30
TOTAL CONNECTED AMPS:				A: 40.7		B: 40.3		C: 25.4					

- | | |
|---|--|
| 1 | COORDINATE EXACT CIRCUIT BREAKER SIZE WITH THE MANUFACTURERS REQUIREMENTS. |
| 2 | REFER TO SHEET EP501 FOR ADDITIONAL INFORMATION. |
| 3 | PROVIDE SEPARATE SWITCHBOARD VERTICAL SECTION FOR THE FIRE PUMP FEEDER. |



FOR COMMANDER NAVFAC

ACTIVITY

DESIGNER	HRM
DRAWN BY	BPD
CHECKED BY	DCL
DESIGN MANAGER	T. CARLETON
PROJECT MANAGER	L. LYONS
FEAD/PM&E	
FIRE PROTECTION	S. RUCINSKI

ND	ME	ME	
----	----	----	--

ITEMS COMMAND
ATLANTIC
RD - KITTERY, M
KITTERY, M

NAVAL FACILITIES ENGINEERING SYSTEMS
 COMMAND - MIDDLE
 PORTSMOUTH NAVAL SHIPYARD

ENGINEERING
SHIPYARD
B60
PANELBOARD

THE NAVY
ILITIES E
NAVAL S

DEPARTMENT OF THE ARMY FACILITIES BUDGET

DEPARTMENT OF AVALANCHE MECHANISMS TSMC

DEPARTAMENTO	DEPARTAMENTO
Nº	Nº
ROCCO	ROCCO
POR	POR

EPROJECT NO.:	1740579
NAVFAC DRAWING NO.	

SHEET 260 OF 282

EP601	
-------	--

DRAWFORM REVISION: 14 SEP 2023