

PANEL PL7 SCHEDULE

LOCATION: ELECTRICAL 213

MCB RATING		250 A	208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.	22KAIC		SURFACE	
CKT NO.	LOAD DESCRIPTION	BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION	CKT NO.		
1	PANELBOARD PL8	150	40.2 A			9.0 A			20	SYSTEMS FURNITURE OFFICE 208 NORTH - 1	2		
3				45.4 A			9.0 A				4		
5					42.9 A			9.0 A				6	
7	PANELBOARD TPP2	70	40.7 A			9.0 A			20	SYSTEMS FURNITURE OFFICE 208 NORTH - 2	8		
9				40.3 A			14.6 A				10		
11					25.4 A		1.5 A				20	12	
13	REC - OFFICE 210	20	7.5 A			2.2 A			15	UH 3-4 (1/20 HP)	14		
15	REC - TRAINING AREA - 1	20		4.5 A			5.0 A		20	NAC, SECOND FLOOR	16		
17	REC - ELEC & CORRIDOR	20			6.0 A			5.0 A	20	REC - OFFICE 210	18		
19			3.0 A			5.0 A			20	REC - MULTI PURPOSE 211	20		
21	SYSTEMS FURNITURE OFFICE 210-1	20		3.0 A			0.4 A		15	UH-2-10 (25W) UH-2-11 (25W)	22		
23					3.0 A			9.8 A	20	REC - RADON FAN ATTIC SOUTH	24		
25	SYSTEMS FURNITURE OFFICE 210-2	20	3.0 A			5.0 A			20	REC - COUNTER RIGHT	26		
27	REC - REFRIGERATOR	20		5.0 A			3.0 A		15	CUH-4	28		
29	REC - MULTI PURPOSE	20			9.0 A			6.0 A	20	REC - OPEN OFFICE 208	30		
31			9.0 A			5.0 A			20	REC - COUNTER LEFT	32		
33	SYSTEMS FURNITURE OFFICE 208 SOUTH - 1	20		9.0 A			5.0 A		20	REC - OPEN OFFICE PRINTER	34		
35					9.0 A			5.0 A	20	REC - TRAINING AREA 202 TV	36		
37	SYSTEMS FURNITURE OFFICE 208 SOUTH - 2	20	6.0 A			6.0 A			20	REC - TRAINING AREA - 2	38		
39	LTG - SECOND FL SOUTH, CORR, ELEC, NETWORK	20		1.2 A			3.0 A		20	REC - TRAINING FLOOR BOX - 1	40		
41	REC - MEZZANINE M201	20			3.0 A			3.0 A	20	REC - TRAINING FLOOR BOX - 2	42		
43	REC - TRAINING QUAD	20	3.0 A			3.0 A			20	REC - TRAINING FLOOR BOX - 3	44		
45	LTG - ATTIC	20		1.3 A			3.0 A		20	REC - TRAINING FLOOR BOX - 4	46		
47	LTG - EXTERIOR EAST END	20			0.6 A			1.0 A	20	TPA-8	48		
49	LTG - OPEN OFFICE 208	20	4.2 A			0.0 A			20	SPARE	50		
51	SPARE	20		0.0 A			0.0 A		20	SPARE	52		
53	SPARE	20			0.0 A			0.0 A	20	SPARE	54		
55	SPARE	20	0.0 A			0.0 A			30	SPD	56		
57	SPARE	20		0.0 A			0.0 A				58		
59	SPARE	20			0.0 A			0.0 A			60		
TOTAL CONNECTED AMPS:			A: 158.6		B: 146.9		C: 126.7						

PANEL PL9 SCHEDULE

LOCATION: SHOP 207

MCB RATING		150 A		208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.	10KAIC		SURFACE	
CKT NO.	LOAD DESCRIPTION	BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION	CKT NO.			
1	REC - WOMAN, MEN, CUST, CORR	20	7.5 A			9.2 A			20	LTG - SHOP 207 - 1	2			
3	REC - EXPRESSING	20		4.5 A			9.2 A		20	LTG - SHOP 207 - 2	4			
5	REC - EXPRESSING REFRIGERATOR	20			3.0 A			9.2 A	20	LTG - SHOP 207 - 3	6			
7			47.5 A			9.2 A			20	LTG - SHOP 207 - 4	8			
9	PANELBOARD PL10	125		44.5 A			10.2 A		20	LTG - SHOP 207 - 5	10			
11					42.5 A			1.0 A	20	LTG - ELEV LIGHT 2ND FL	12			
13			0.0 A			0.0 A			20	SPARE	14			
15	SPARE	20		0.0 A			3.1 A		20	LTG - SHOP 207 VIA EMERGENCY INVERTER	16			
17					0.0 A			8.1 A	20	LTG - SHOP 207 EAST	18			
19	SPARE	20	0.0 A			5.0 A			20	LIGHTING CONTROL PANEL	20			
21				0.0 A			0.1 A		20	LTG - RSTRMS, EXPRESSING, UPHOLSTERY	22			
23	TPA-7 AND EMERGENCY EYEWASH ALARM	20			1.1 A			0.0 A	30	SPARE	24			
25	REC - WATER COOLER	20	5.0 A			0.0 A					26			
27	REC - SHOP 107 NORTH	20		4.5 A			2.5 A		20	LTG - ATTIC	28			
29	REC - SHOP 207 EAST & ROOF	20			7.5 A			0.7 A	20	LTG - CORRIDOR 201	30			
31	REC - GROMMET MACH. - LEFT	20	9.8 A			10.2 A			20	LTG - UPHOLSTERY 206-1	32			
33	REC - GROMMET MACH. - RIGHT	20		9.8 A			5.1 A		20	LTG - UPHOLSTERY 206-2	34			
35	UH-2-4 (1/20HP) UH-2-5 (1/20HP)	15			4.4 A			0.5 A	20	LTG - EXTERIOR NORTH END	36			
37	CUH-3	15	3.0 A			0.0 A					38			
39	REC - ATTIC NORTH	20		1.5 A			0.0 A		30	SPD	40			
41	SPARE	20			0.0 A			0.0 A			42			
TOTAL CONNECTED AMPS:			A: 97.9		B: 87.2		C: 78.0							

PANEL PH1 SCHEDULE

LOCATION: ELECTRICAL 213

MLO RATING		225 A		480V VOLTS			3PH, 3W, SN, 60HZ			MIN.	35KAIC		SURFACE	
CKT NO.	LOAD DESCRIPTION	BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION	CKT NO.			
1	BCU-2	15	2.5 A			68.7 A			200	PANELBOARD PL7 VIA T4	2			
3				2.5 A			63.7 A				4			
5					2.5 A			54.9 A			6			
7	BCU-3	15	2.5 A			0.0 A			20	SPARE	8			
9				2.5 A			0.0 A				10			
11					2.5 A			0.0 A			12			
13	OU-3	15	6.7 A			0.0 A			20	SPARE	14			
15				6.7 A			0.0 A				16			
17					6.7 A			0.0 A			18			
19	CU-2	15	7.5 A			0.0 A			15	SPARE	20			
21				7.5 A			0.0 A				22			
23					7.5 A			0.0 A			24			
25	SPACE	--	--			--			--	SPACE	26			
27				--			--				28			
29					--			--			30			
31	SPACE	--	--			--			--	SPACE	32			
33				--			--				34			
35					--			--			36			
37	SPACE	--	--			--			--	SPACE	38			
39				--			--				40			
41				--			--				42			
TOTAL CONNECTED AMPS:			A: 87.9		B: 82.8		C: 74.0							

PANEL PL8 SCHEDULE

LOCATION: SHOP 207

MLO RATING		150 A		208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.	10KAIC		SURFACE	
CKT NO.	LOAD DESCRIPTION		BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION		CKT NO.	
1	UH 3-2 (1/20HP) & UH 3-3 (1/20HP)		15	4.4 A			6.0 A			20	REC - CEILING - 5		2	
3	REC - RADON FAN ATTIC CENTER		20		9.8 A			6.0 A		20	REC - CEILING - 2		4	
5	REC - LONG ARM SEWING 2		20			6.0 A			6.0 A	20	REC - CEILING - 6		6	
7	REC - SHOP WEST		20	3.0 A			6.0 A			20	REC - CEILING - 3		8	
9	REC - LONG ARM SEWING 3		20		10.0 A			0.0 A		20	SPARE		10	
11	REC - LONG ARM SEWING 4		20			10.0 A			0.0 A	20	SPARE		12	
13	UH-2-7 (1/20HP) UH-2-9 (1/20HP)		15	4.4 A			0.0 A			20	SPARE		14	
15	REC - SEWING MACH. SOUTH 1		20		10.0 A			0.0 A		20	SPARE		16	
17	REC - SEWING MACH. SOUTH 2		20			10.0 A			0.0 A	20	SPARE		18	
19	SPARE		30	0.0 A			0.0 A			20	SPARE		20	
				0.0 A			0.0 A		20	SPARE		22		
					0.0 A		0.0 A		20	SPARE		24		
25	SPARE		30	0.0 A			0.0 A			20	SPARE		26	
				0.0 A			0.0 A		20	SPARE		28		
					0.0 A		0.0 A		20	SPARE		30		
31	REC - BOX STITCHER 120V - 2		20	12.0 A			0.0 A			20	SPARE		32	
33	REC - BOX STITCHER 120V - 1		20		12.0 A			0.0 A		20	SPARE		34	
35	REC - SHOP EAST		20			4.5 A			0.0 A	20	SPARE		36	
37	UH-2-6 (1/20HP) UH-2-8 (1/20HP)		15	4.4 A			--			--	SPACE		38	
39	REC - CEILING - 4		20		6.0 A			--		--	SPACE		40	
41	REC - CEILING - 1		20			6.0 A			--	--	SPACE		42	
TOTAL CONNECTED AMPS:				A: 40.2		B: 45.4		C: 42.9						

PANEL PL10 SCHEDULE

LOCATION: SHOP 207

MLO RATING		125 A		208/120 Wye VOLTS			3PH, 4W, SN, 60HZ			MIN.	10KAIC		SURFACE	
CKT NO.	LOAD DESCRIPTION	BKR TRIP	A	B	C	A	B	C	BKR TRIP	LOAD DESCRIPTION	CKT NO.			
1	UH 3-1 ATTIC (1/20 HP)	15	2.2 A			0.0 A			20	SPARE	2			
3	REC - RADON FAN, ATTIC NORTH	20		9.8 A			12.0 A		20	REC - POLYBAG SEALER	4			
5	REC - UPHOLSTERY 1	20			3.0 A			0.0 A	30	SPARE	6			
7	REC - SEWING MACH. CENTER 1	20	10.0 A			0.0 A				8				
9	UH-2-1(25W) UH-2-2(25W) UH-2-3(25W)	15		0.6 A			0.0 A		20	SPARE	10			
11	REC - UPHOLSTERY 2	20			4.5 A			0.0 A	20	SPARE	12			
13	REC - SEWING MACH. CENTER 2	20	10.0 A			0.0 A			20	SPARE	14			
15	REC - UPHOLSTERY 3	20		4.5 A			0.0 A		20	SPARE	16			
17	REC - SEWING MACH WEST	20			10.0 A			0.0 A	20	SPARE	18			
19	REC - STAND ALONE COMPUTER	20	3.0 A			0.0 A			20	SPARE	20			
21	REC - EMBROIDERY MACH.	20		4.0 A			0.0 A		20	SPARE	22			
23	REC - UPHOLSTERY CEILING 1	20			6.0 A			0.0 A	20	SPARE	24			
25	REC - UPHOLSTERY CEILING 2	20	6.0 A			0.0 A			20	SPARE	26			
27	REC - SEWING #	20		10.0 A			0.0 A		20	SPARE	28			
29	REC - LONG ARM SEWING #	20			10.0 A			0.0 A	20	SPARE	30			
31	REC - LONG ARM SEWING 1	20	10.0 A			0.0 A			20	SPARE	32			
33	REC - CEILING - 3	20		6.0 A			0.0 A		20	SPARE	34			
35	REC - CEILING - 1	20			6.0 A			0.0 A	20	SPARE	36			
37	REC - CEILING - 4	20	6.0 A			--			--	SPACE	38			
39	REC - CEILING - 2	20		6.0 A			--		--	SPACE	40			
41	REC - SHOP 207 NORTHWEST	20			3.0 A			--	--	SPACE	42			
TOTAL CONNECTED AMPS:			A: 47.5		B: 44.5		C: 42.5							