

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE	OF	PAGES
2. AMENDMENT/MODIFICATION NUMBER		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NUMBER	
				☐		9B. DATED (SEE ITEM 11)	
				☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
				☐		10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)



13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
 (Signature of person authorized to sign)		 (Signature of Contracting Officer)	

Previous edition unusable

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section J - List of Attachments

Miscellaneous text in this section has been modified to:

The following documents, exhibits, and other attachments that form part of this solicitation are as follows.

ATTACHMENT NUMBER	TITLE / DESCRIPTION
J-1	Work Specification MSCOK 26-008
J-2	Contractor Price Breakdown
J-3	Contractor Performance Data Sheet
J-4	FAR 52.229-11 Tax on Certain Foreign Procurements - Notice and Representation: IRS Form W-14

Q&A

**** Work Item 0117 Sounding Tube Cap Repair, Para. 4.2 and 7.7**

- Question: There appears to be a conflict between Para. 4.2 (GFM: Inserts and Caps available onboard) and Para. 7.7 (Contractor to fabricate new inserts). Please clarify whether the inserts and caps will be provided as GFM or if the contractor is required to fabricate them.

- Gov't Answer: 4 sounding caps will be provided as GFM. Inserts fabricated (CFM).

**** Work Item 0501 AC No.3 Troubleshoot and Repair**

- Question1: There is a discrepancy between the quantity listed in Para. 3.1.2 (Four (4) AC Plants) and the Instruction in Para. 7.1 (No. 3 AC Plant). Please confirm the exact number of units and the specific designations of the AC plants requiring work.

- Question2: The current RFQ is too broad and does not specify the actual deficiencies or the required spare parts. Since the current status of the equipment is unidentified, we propose to conduct an initial inspection first and report the findings via a Condition found Report (CFR) to determine the necessary repair scope. Please confirm if a comprehensive inspection is the intended starting point for this item.

- Question3: If the specific areas requiring repair have already been identified by the vessel, please provide the detailed scope of work and information on the required spare parts. This will allow for a more accurate technical evaluation and material procurement plan.

- Gov't Answer: It is only one AC Unit, and this is the AC No.3 that needs to be repaired. The issues with No.3 AC relate to the slide valve. It doesn't seem like the control cabinet is sending or receiving signals from the slide valve to properly operate. The unit will start but the slide valve does not move. We've swapped control cabinet components from a working AC but had the same results. We've tried injecting a signal but that hasn't gotten us anywhere either.

