

STATEMENT OF WORK

Miniature Uninterruptible Power Supply (mUPS) Procurement

PURPOSE:

In the National Airspace System (NAS), Miniature Uninterruptible Power Supplies (mUPS) play a crucial role in delivering emergency power to electronics and equipment during power outages or other electrical disturbances. These Mini-UPS units are specifically designed to provide short-term backup for sensitive loads, whether to ride through voltage sags and brief power interruptions or to seamlessly bridge the startup of a generator. To ensure safe and reliable operations within the Federal Aviation Administration (FAA), AJM-5 Telecommunications Integrated Services (TIS) along with Federal Aviation Administration Logistics Center (FAALC) has initiated a comprehensive optimization project to deploy Mini-UPS systems at critical National Airspace System (NAS) facilities, ensuring uninterrupted power to vital equipment.

SCOPE OF WORK:

- Provide UPS's that meet the following requirements:
 - Single-Phase, Capacitor-based, ~800VA, Offline, must include NEMA 5-15 plug (input) and external power strip on output with at least 4x5-15 and no switch plus mounting hardware.
 - Must have the ability to withstand dusty conditions and temperatures over 110 degrees.
 - Single-Phase, Capacitor-based, 1kVA, Online, Dual conversion, must include mounting hardware.
 - Single-Phase, Capacitor-based, 3kVA, Online, must include mounting hardware.
 - 3-Phase 208V, Capacitor-based, 3kVA, Online, must include mounting hardware.
 - Single-phase, 1kVA, Online, capable of providing power for greater than 4 hours. May achieve this by installing additional battery modules
 - Units must have a minimum runtime of fifteen (15) seconds at 192 Watts.

- FAA approved equipment or equivalent:

Table 1 below lists a sample of mUPS designated by FAA as already approved. Any equivalent submittal items must fit the salient features and characteristics of the approved items below, as well as meet the UPS requirements listed above. To see full list of approved product part numbers see attached mUPS bid sheet.

1. Any substitution must be approved by the FAA Program Office.

Approved Equipment type or equivalent (Vendor)	Vendors Equivalent Part Number	Vendor Part Number Description	Quantity
Marathon Power	UP-SDRU-0500-H1	DIN-Rail Mount UPS, 850VA/500W, 120V, Super Cap	600

Table 1

STATEMENT OF WORK

Miniature Uninterruptible Power Supply (mUPS) Procurement

LOCATION:

- Delivery address: Operating Stock, 6500 S MacArthur Blvd, Oklahoma City, OK 73169 or specified address on Delivery Order.
- Packaging and marking: The contractor must follow shipping and packaging guidelines explained in AJW-LWI-CF0077 (Provision 61).

SUBMITTALS:

- Equipment specification sheet
- Delivery lead time for complete order
- Standard Manufacturer Warranty