

Propane Delivery Requirement RFIs Responses

1. For Government-Owned tanks identified in the PWS, please clarify whether the contractor is responsible for maintenance, repair, and replacement of "T Government Owned" tanks, or if these responsibilities remain with the Government. **The contractor is not responsible for any of the below government-owned tanks. We have never had to replace a government owned tank, but if that issue does arise we would discuss with the contractor and see the best way forward.**
2. Can the government provide us with a history of usage? **Sep 2024- August 2025 we used 81,000 gallons. Sept 2025- Mar 2026 we have used 78,254 gallons. A safe estimate would be 75,000- 90,000 gallons yearly per contract dates.**
3. Can the Government provide an estimated monthly and seasonal usage breakdown? **An estimated cold season usage (Dec- Feb) has been roughly 60,000 gallons total.**
4. Given the current volatility in the propane market, please confirm whether any provisions for price adjustment will be included or if offerors are expected to account for all market fluctuations within their proposed firm-fixed price. **No price adjustments; offerors propose a firm fixed price**
5. Can a map of tank locations be provided? **No map is available.**
6. Are we able to install any monitors on tanks? **Yes you can install monitors on all tanks.**
7. Does the current contractor own all the tanks on site? **No**
8. Can you please provide the historical usage for each tank for the current contract? **No**
9. Which tank areas are currently receiving automatic deliveries? **All**
10. Are the tanks at the Temp Building at Camp Buckner cylinders? **Yes**
11. Please provide propane usage history for the past two years. **See question number 2.**
12. For your propane requirements, are you looking for trailer sized loads of propane or bobtail sized loads or both? **Question unclear. If inquiring what truck currently makes delivery, it is the same used for residential delivery.**

13. What is the name of the tank owner? Not the contractor, but whose tanks are onsite? **Superior Propane**

Building		Name	Location	GOCO	Tank Size
648		Auto Craft	USMA	F	500
604		Power Plant		T	1000
702		Medical Warehouse		F	1,000
907		Warehouse		T	1,000
716		Ski Slope Comp Pad		F	500
721		Fire Dept		F	50
2023		Morgan Farms Riding Facility	Morgan Farms	T	2-1,000
854		Rugby Center	Target Hill (4 tanks @ 1000 ea.)	F	4-1,000
1225		Golf Training Center		F	1000
1230		NEW Golf Clubhouse		F	4-1000
1330		ITAMS	Round Pond	F	100
1348		DCFA		F	100
1352		Club House	Round Pond	F	100
1354		Bonneville Cabin	Round Pond	F	500
1351		Round Pond Rental	Round Pond	F	1,000
1364		Round Pond Bath House	Round Pond	F	250
1389		Skeet Lodge	Range 10	T	100
1400		Fire House	RT 293 Next Range CTRL	F	100
1550		Bath House	Camp natural Bridge	T	Varies
1580		CMNDRS Cottage	Camp Buckner	F	100
1585		Mess hall	Camp Buckner	F	2,000
1666		DMI	RT 293/Mine Road	F	100
1670		DMI	RT 293/Mine Road	F	500
1701		Mess hall	Camp natural Bridge	F	1,000

1800		Sup's Cottage	Bull Pond	F	100
1806		Sup's Cottage	Bull Pond	F	100
1864		Youth Camp Mess hall	USMA/Lake Fredericks	F	100
1940		Motor Pool Maint	RT 293	F	5-2,000
1942		Motor Pool-Veh Wash	RT 293	T	2-2,000
1946		Motor Pool-Admin	RT 293	T	3-3,000
2024		Dog/Cat Boarding	Morgan Farms	F	300
2027		Managers Office	Morgan Farms	F	200
83502		Temp Building	Camp Buckner (4-100 lb. gal)	F	4-420 lbs.
83504		Temp Building	Camp Buckner (4-100 lb. gal)	F	4-420 LBS

GOCO Definitions: T=Government owned, F=Contractor owned

Building 1940 tank is contractor owned (previously posted PWS stated this was a government owned tank)