



**DEPARTMENT OF THE NAVY**  
NAVAL FACILITIES ENGINEERING SYSTEMS COMMAND, MID-ATLANTIC  
9324 VIRGINIA AVENUE  
NORFOLK, VIRGINIA 23511-3095

Class J&A No. ML-25-30

**FACILITIES RELATED CONTROLS SYSTEMS  
CLASS JUSTIFICATION AND APPROVAL  
FOR USE OF OTHER THAN FULL AND OPEN COMPETITION**

1. Contracting Activity.

Naval Facilities Engineering Systems Command, Mid-Atlantic (NAVFAC MIDLANT)

2. Description of the Action Being Approved.

This Class Justification and Approval (CJ&A) authorizes and approves the use of brand name commercial equipment from Automated Logic Corporation (ALC) WebCTRL product line and Johnson Controls International (JCI) Metasys system family products for Facility Related Control Systems (FRCS) programmable building controllers to in contract actions requiring interface with the identified Installation networked facilities control and monitoring system at Naval Station Norfolk (referred to in this document as "the Installation"). Authority to act under this class justification is authorized from 16 May 2025 – 15 May 2030.

3. Description of Supplies/Services.

The use ALC WebCTRL product line and JCI Metasys system family products brand name programmable building controllers will be required for all projects that require a connection to the identified (existing or currently under development) installation networked facilities control and monitoring system commonly referred to as the ALC WebCTRL Building Automation System (BAS) Network (ALC BAN) and the JCI Metasys BAS Network (JCI BAN). The ALC controllers and system equipment (hardware) will be configured and programmed using government-licensed ALC WebCTRL software. Programmable building controllers are categorized as FRCS and the ALC hardware includes, but is not limited to, ALC Optiflex product line, BACnet Routers and Gateways, Multi-Purpose Controllers, Multi-Equipment Controllers and expanders, Single Equipment Controllers, Zone Controllers and Sensors. The JCI controllers and equipment (hardware) will be configured and programmed using government-licensed JCI Metasys software. Programmable building controllers are categorized as FRCS and the JCI hardware includes, but is not limited to, Advanced Field Equipment Controllers (FACs), Input/Output Modules (IOMs), Field Equipment Controllers (FEC), Network Automation Engines (NAE), Network Control Engines (NCE), Metasys M4 product line, TEC Thermostat Controllers, Variable Air Volume Modular Assemblies (VMAs), sensors and controlled devices. The requirement to use ALC Automated Logic WebCTRL or JCI Metasys system family software to program ALC Automated Logic WebCTRL product line or JCI Metasys system family brand name commercial equipment does not restrict who can install, commission, test, maintain, or operate the controllers and there are several known sources who can provide such services.

The total estimated value for the use of ALC Automated Logic WebCTRL product line or JCI Metasys family brand name equipment through 15 May 2030 is [REDACTED]. The cost of programmable building controllers typically represents approximately [REDACTED] percent of the cost of the total controls installation effort, and is a miniscule percentage of the total cost of any building construction effort. A non-exhaustive listing of the projected projects that will utilize this equipment is provided in Appendix A. All required programmable building controllers are authorized under this CJ&A regardless of method of execution or procurement strategy (i.e., contracted, in-house shop forces, base operating support contracts, or materials supply chain contractor).

Estimated Dollar Value of Brand Name Equipment (\$K)

|                  | <b>FY25 – FY30</b>   |
|------------------|----------------------|
| MILCON           | \$ [REDACTED]        |
| Special Projects | \$ [REDACTED]        |
| <b>TOTAL</b>     | <b>\$ [REDACTED]</b> |

4. Statutory Authority Permitting Other Than Full and Open Competition.

The statutory authority permitting other than full and open competition is Title 10, U.S.C. 3204(a)(1), as implemented by the Federal Acquisition Regulation (FAR) 6.302-1, "Only one responsible source and no other supplies or services will satisfy agency requirements."

5. Rationale Justifying Use of Cited Statutory Authority.

The Installation has a reasonable need for standardization and interoperability of its existing building control systems that will require a connection to the identified installation networked facilities control and monitoring systems commonly referred to as the ALC WebCTRL and JCI Metasys BAS Networks. Applicable United States Government Accountability Office (GAO) Comptroller General decisions have acknowledged the authority of a federal agency to use other than competitive procedures when there is a reasonable need for standardization or interoperability with existing agency equipment or software and when it is likely that award to other sources would result in substantial duplication of cost to the government that is not expected to be recovered through competition.

To assess the need for standardization and interoperability, a rigorous business case analysis was performed on the existing inventory of building control systems connected to the ALC WebCTRL and JCI Metasys BAS Networks. This business case analysis evaluated the standardization of building programmable controllers and quantified the annual costs associated with procurement, sustainment of operation and maintenance, and establishment and sustainment of Department of the Navy cybersecurity requirements. The results of this business case analysis demonstrate that in order to minimize costs and potential cyber vulnerabilities, the use of the indicated brand name programmable building controllers will be required for all projects that require a connection to the ALC WebCTRL and JCI Metasys BAS Networks.

The Installation requires that programmable building controllers be ALC Automated Logic WebCTRL or JCI Metasys system family brand name in order to meet its need for, and achieve the benefits of, standardization and interoperability as follows:

a. Establish and maintain a defensible cybersecurity posture. The rapid emergence of cyber incidents on critical Industrial Control Systems (ICS), which include FRCS, with the potential to debilitate our installation mission critical assets has catalyzed the need to establish a defensive cybersecurity posture across the shore enterprise. An RMF ATO is required per DoD Instruction 8510.01. The Installation's ATO status is: The ALC WebCTRL and JCI Metasys BAS Networks ATOs are funded and in progress. ETA mid 2025 for ATO approval of each vendor. The indicated manufacturer's programmable controllers and their associated application software will be authorized per the active ATO and provide for the following:

(1) Cost-effectively reduce government information technology cybersecurity risks. Avoid the significant costs and delays associated with obtaining a new ATO for the ALC WebCTRL and JCI Metasys BAS Networks which, due to government information technology cybersecurity risks, is required when additional nonconforming hardware or software is added to the system with resultant changes in the security posture of the system. The process of obtaining a new ATO would unacceptably delay the operational use of programmable controllers for the affected facility and connection of the facility to the ALC WebCTRL and JCI Metasys BAS Networks, resulting in a significant degradation in accomplishment of mission. Similarly, if additional non-conforming equipment and software were added to the ALC WebCTRL and JCI Metasys BAS Networks, the associated cybersecurity costs to sustain the inventory of equipment and software and to maintain the ATO would significantly increase. Additionally, minimizing the different types of equipment and software permitted on the ALC WebCTRL and JCI Metasys BAS Networks avoids incurring additional risks to system operational availability should the NAVFACSYSCOM Functional Authorizing Official (FAO) determine that the additional equipment or software has security vulnerabilities precluding obtaining or maintaining an ATO.

(2) Control Systems (such as networked FRCSs) are classified as Platform Information Technology (PIT) systems. DoD Instruction 8500.01 requires that all PIT systems have their cybersecurity controls documented and validated prior to operation and/or deployment. All PIT systems on Navy networks must obtain an ATO from the FAO. Additionally, connection or integration into the CSPE and subsequently Smart Grid requires that the FRCS obtain an ATO from the NAVFACSYSCOM FAO.

ATOs remain valid for three years as long as the cybersecurity posture of the system does not change. A cybersecurity posture change includes, but is not limited to, system architecture changes or any other changes that increase risk or degrade the security posture. Any cybersecurity posture change must be provided to the FAO that approved/authorized the ATO for impact review on that risk approval. When a cybersecurity posture changes, the PIT system normally will be required to complete the authorization process again to obtain a new ATO for the new configuration. The use of different brand programmable controllers or associated

configuration or programming software on the ALC WebCTRL and JCI Metasys BAS Networks results in an undesirable, higher number of changes to the cybersecurity posture of the system. Obtaining an ATO is not the end of the process; maintaining an ATO is also very resource intensive and the effort increases exponentially when additional hardware or software is added to the system (that is, requires maintaining cybersecurity controls, vulnerability management, system scans/tests, and similar).

b. Maximize utilization of existing government-licensed ALC WebCTRL and JCI Metasys software to configure and program the controllers. Other contractors do not offer programmable controllers that can be configured/programmed with the ALC WebCTRL and JCI Metasys software. Although the BACnet open protocol is the required communications protocol for all manufacturers' controllers, it only allows for different manufacturers' equipment to share basic point data. It does not allow for configuration and programming functions to take place between different manufacturers' controllers. For example, manufacturer A's software cannot be used to program manufacturer B's controller. Each manufacturer's proprietary software tools must be used to configure or change the program within a controller.

c. Maintain installation networked facilities control and monitoring system so that all controllers can be programmed from a single central station versus a hybrid system composed of many different controllers and associated configuration/programming software, this will further improve operational efficiency and decrease installation, maintenance, repair, and energy costs. Utilizing hardware products from the same vendor that produced the configuration/programming software eliminates multi-vendor disputes regarding conflicts, standards, protocols, or performance characteristics should the controller not function as required.

d. Avoid the significant operational burden and cost of having maintenance and engineering staff become proficient with the configuration, programming, commissioning, operation, and maintenance of controllers from different manufacturers. Standardization reduces personnel training costs and decreases procurement costs related to additional equipment, maintenance, and support contracts for another manufacturer's hardware and software, as well as the maintenance of an additional parts inventory. Maintaining multiple solutions is inefficient and creates unnecessary work and overhead that increases the total costs of ownership and manpower costs.

NAVFAC MIDLANT and NAVSTA Norfolk technical personnel who performed this business case analysis have determined that for the Installation, the contract actions authorized by this CJ&A will avoid substantial duplication of cost that is not expected to be recovered through competition. Specifically, the business case analysis performed by NAVFAC MIDLANT and NAVSTA Norfolk concluded that the Navy would realize annual savings of approximately \$[REDACTED] by limiting FRSC controllers to the referenced products. Assuming other brand name controllers could be integrated into the ALC WebCTRL and JCI Metasys BAS Networks so as to be fully functional, the significant cyber security risks, operational challenges, added costs (including the costs to re-procure the Installation's existing inventory), and other disadvantages arising from the use of different brands of controllers outlined above are not expected to be recovered through competition.

6. Description of Efforts Made to Solicit Offers from as Many Offerors as Practicable.

Per FAR 5.201, a Sources Sought announcement was synopsized on the sam.gov website to determine if there are other controllers capable of fully functional interface with the existing ALC WebCTRL and JCI Metasys Government licensed software. The Government received two responses. [REDACTED] proposed an alternative system; however, based on the findings of the Business Case Analysis, NAVFAC MIDLANT determined that procuring a single controller that fully integrates with the existing ATO is in the best interest of the government. The proposed alternative does not meet essential functional requirements, and integrating it into the current infrastructure would not provide the anticipated benefits in terms of cost, efficiency, or risk mitigation as discussed in Paragraph 5 above. Specifically, the proposed alternative cannot provide connectivity to existing installed systems. [REDACTED] also responded but they are a general contractor for installation, not a manufacturer and they did not propose an alternate system. The responses received indicates that there may not be any substitute or equivalent products that would fulfill this requirement.

7. Determination of Fair and Reasonable Cost.

The Contracting Officer has determined the anticipated cost to the Government of the supplies/services covered by this CJ&A will be fair and reasonable. The cost associated with a complete replacement is not practicable or cost effective.

8. Actions to Remove Barriers to Future Competition.

For the reasons set forth in Paragraph 5, NAVFAC MIDLANT does not intend to compete future contracts for the types of supplies/services covered by this document. NAVFAC MIDLANT will continue to monitor the controls industry to determine if a universal controller configuration becomes available and if another potential source emerges, NAVFAC MIDLANT will continually assess whether competition for future requirements is feasible.

**CERTIFICATIONS AND APPROVAL**

**TECHNICAL/REQUIREMENTS CERTIFICATION**

I certify that the facts and representations under my cognizance which are included in this Justification and its supporting acquisition planning documents, except as noted herein are complete and accurate to the best of my knowledge and belief.

[Redacted Signature]

[Redacted Signature]

\_\_\_\_\_  
Date

[Redacted Signature]

**LEGAL SUFFICIENCY REVIEW**

I have determined this Justification is legally sufficient.

[Redacted Signature]


**CONTRACTING OFFICER CERTIFICATION**

I certify that this Justification is accurate and complete to the best of my knowledge and belief.

[Redacted Signature]

**APPROVING OFFICIAL (NPGI 6.304)**

Upon the basis of the above justification, I hereby approve the Class Justification for proposed procurement(s) described herein using other than full and open competition, pursuant to the authority of 10 U.S.C. 3204(a)(1)





### Appendix A

List of projects using Automated Logic WebCTRL or Johnson Controls Metasys family controls.

| PROJECT NO. | DESCRIPTION                                                  | PROGR<br>AM<br>YEAR | FUNDI<br>NG<br>TYPE | CWE<br>COST<br>(000) | MILC<br>ON<br>(Y/N) | Cost of<br>Controller<br>s |
|-------------|--------------------------------------------------------------|---------------------|---------------------|----------------------|---------------------|----------------------------|
| P-1027      | CMV-22 Hangar & Airfield Pavements                           | 2026                | MILCO<br>N          |                      | Y                   |                            |
| P-1127U     | CMV-22 Composite Shop                                        | 2025                | MILCO<br>N          |                      | Y                   |                            |
| P-1137U     | CMV-22 O2/N2 Shop                                            | 2025                | MILCO<br>N          |                      | Y                   |                            |
| P-702       | Submarine Logistics Facility                                 | 2026                | MILCO<br>N          |                      | Y                   |                            |
| P-222       | MQ25 Aircraft Laydown Facilities                             | 2028                | O&M,<br>N           |                      | Y                   |                            |
| P-1041      | Replace Backup Power Generation                              | 2027                | O&M,<br>N           |                      | Y                   |                            |
|             | CEP-201 Building Renovation for DLA                          | 2026                | O&M,<br>N           |                      | N                   |                            |
| 1829271     | NSN CEP 160 RENOVATE BUILDING                                | 2025                | O&M,<br>N           |                      | N                   |                            |
| P-1039      | Combined Rescue Swimmer & Aircrew Training Facility          | 2025                | MILCO<br>N          |                      | Y                   |                            |
| RM21-1939   | LP-21/33/34 ANNEX 705 COMPLIANCE                             | 2025                | O&M,<br>N           |                      | N                   |                            |
| RM24-3467   | ESTABLISH FLEET LEGAL SERVICES COMPLEX - RENOVATE SP64/48/47 | 2025                | O&M,<br>N           |                      | N                   |                            |
| 1814337     | NSN CEP 172 REPLACE VARIOUS A/C AND HEATERS                  | 2025                | O&M,<br>N           |                      | N                   |                            |
| 1813028     | NSN W-143 ROOM 627 RENOVATION FOR BLUE TEAM - SOW            | 2025                | O&M,<br>N           |                      | N                   |                            |
| 1752797     | NSN CEP-198 REPLACE HVAC & ADD AHU                           | 2025                | O&M,<br>N           |                      | N                   |                            |
| 1758693     | NSN V-147 CHILLER REPLACEMENT                                | 2025                | O&M,<br>N           |                      | N                   |                            |
| 1777253     | NSN LF-18 OFFICE SPACE RENOVATIONS                           | 2025                | O&M,<br>N           |                      | N                   |                            |
| TBD         | Norfolk P-222 2T BC Hazardous                                | 2025                | O&M,<br>N           |                      | Y                   |                            |



|           |                                                            |      |           |  |   |  |
|-----------|------------------------------------------------------------|------|-----------|--|---|--|
| TBD       | NSN CEP209<br>RECOMPRESSION CHAMBER<br>HVAC                | 2026 | O&M,<br>N |  | N |  |
| TBD       | NSN X-380 Renovation & Repairs                             | 2026 | O&M,<br>N |  | N |  |
| 21786934  | NSN / W143 / RENOVATE<br>OFFICE                            | 2026 | O&M,<br>N |  | N |  |
| 1808091   | NSN W-143 NAVY BLUE<br>TEAM RENOVATION                     | 2026 | O&M,<br>N |  | N |  |
| 1806357   | NSN SP-312 INSTALL<br>EXHAUST FANS IN 5<br>BATHROOMS       | 2026 | O&M,<br>N |  | N |  |
| TBD       | NSN DS-31 REPLACE<br>RECTIFIER ROOM HVAC                   | 2026 | O&M,<br>N |  | N |  |
| 1814320   | NSN LP34 REPAIR HVAC                                       | 2026 | O&M,<br>N |  | N |  |
| 1812753   | NSN LF-18 REPLACE<br>ROOFTOP UNIT                          | 2026 | O&M,<br>N |  | N |  |
| 1814347   | NSN U-132 RENOVATE<br>RESTROOMS 118, 119, 209 &<br>210     | 2026 | O&M,<br>N |  | N |  |
| 1832364   | NSN N-24 HVAC<br>INSTALLATION & MISC.<br>BUILDING REPAIRS  | 2026 | O&M,<br>N |  | N |  |
| 1834937   | NSN W-143 COLE'S BISTRO                                    | 2026 | O&M,<br>N |  | N |  |
| 1762348   | NSN W-143 FLC REPLACE<br>HVAC UNITS (1ST & 6TH<br>FLOORS)  | 2026 | O&M,<br>N |  | N |  |
| 1782194   | NSN SP-91 SECURE ROOM<br>(119B/119C)                       | 2026 | O&M,<br>N |  | N |  |
| 1794549   | NSN CEP-200 REPLACE AHU-<br>2, AHU-5 & DDC<br>INSTALLATION | 2026 | O&M,<br>N |  | N |  |
| 1794060   | NSN CEP-183 HVAC CONTROL<br>CONVERSION                     | 2026 | O&M,<br>N |  | N |  |
| RM20-0765 | NSN CRAISL CI-294 OWWO<br>TREATMENT PLANT<br>UPGRADES      | 2027 | O&M,<br>N |  | N |  |
| TBD       | Construct New Training Facility                            | 2028 | MCON      |  | Y |  |