

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1		OF PAGES 3	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 03/18/2026		4. REQUISITION/PURCHASE REQ. NO. 7495214		5. PROJECT NO. (If applicable)			
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 CHERRY POINT, NC 28533		Code N40085		7. ADMINISTERED BY (If other than item 6.)			Code		
AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL				☒		9A. AMENDMENT OF SOLICITATION N400857495214			
						9B. DATED (SEE ITEM 11)			
				☐		10A. MODIFICATION OF CONTRACT/ORDER NO.			
						10B. DATED (SEE ITEM 13)			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS									
☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☒ is extended ☐ is not extended . Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.									
12. ACCOUNTING AND APPROPRIATION DATA (if required)									
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.									
☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.									
☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).									
☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:									
☐ D. OTHER: (specify type of modification and authority)									
E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return original to the issuing office.									
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)									
7495214 Repair Leaking Domestic Hot-Water and Cold-Water Lines Bldg 4389, Marine Corps Air Station Cherry Point, NC The purpose of this amendment is to answer pre-award PPIs and postpone PPI due dates and proposals in leu of a site visit. The cut off for pre-award PPIs will now be 27 March 2026. The proposal due date will now be moved to 03 April 2026 at 12:00 PM local time. See Attached.									
15A. NAME AND TITLE OF SIGNER (Type or print)					16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)				
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY			16C. DATE SIGNED		
(Signature of person authorized to sign)				(Signature of Contracting Officer)					
NSN 7540-01-152-8070 PREVIOUS EDITION UNUSABLE		30-105		STANDARD FORM 30 (REV.1-83) Prescribed by GSA			0224-3(10-90)		

RFI Responses:

Will this work need to be performed after normal working hours or during a scheduled shutdown period? Please advise if the work must be treated as an after-hours shutdown repair or replacement.

Response:

The work must be performed during a scheduled, after hours shutdown period.

Are there existing shutoff valves in proximity to the work areas that can be utilized to isolate the water supply to allow removal and replacement of the piping?

Response:

The NHCCP Facilities Department will assist the contractor in securing the water so that the work can be accomplished.

Are any existing valves within the affected areas identified for replacement as part of this repair?

Response:

No valves require replacement

Please confirm the pipe size and approximate length of piping required to repair the Domestic Hot Water line serving Room 1122 and Corridor 2080.

Response:

The pipe in 1122 is a 4" line and is leaking at the solder joint. Requires a 4" 90, 2080 is a 2.5", requires a coupling.

Please confirm the pipe size and approximate length of piping required to repair the Domestic Cold Water line serving Building 4389, Room 2205.

Response:

The pipe is a 4" line and is leaking at the solder joint. Requires a 4" 90.

Please provide clarification regarding the identified cause of the piping leaks referenced in the SOW.

Response:

Unknown. Leaking at the solder joint. Possibly failed due to old age.

The SOW states the contractor must inspect and install proper cathodic protection as necessary. Please clarify (a) the existing cathodic protection conditions.

Response:

Unknown.

Can a site visit be scheduled so the contractor may review the existing conditions and verify the scope of work required for these repairs?

Response:

Yes

We looked at the site today and the leak in Rm 2166 appears to be in Rm 2205. Please verify.

Response:

Verified. We have leaks to be repaired in rooms 1122, 2205, and 2080. There is no leak in room 2166 at this time.

Can a site visit be conducted? There is not enough information to bid.

Response:

Yes, asked and answered.