

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J		PAGE 1 OF 2 PAGES		
2. AMENDMENT/MODIFICATION NUMBER 0002		3. EFFECTIVE DATE 12 Feb 2026		4. REQUISITION/PURCHASE REQUISITION NUMBER See Continuation Sheet		5. PROJECT NUMBER (If applicable) 1737012	
6. ISSUED BY NAVFACSYS COM MID-ATLANTIC 9324 VIRGINIA AVENUE, NORFOLK NORFOLK, VA 23511-0395 UNITED STATES CATHARINE Keeling, Email: catharine.a.keeling.civ@us.navy.mil Telephone: 757-341-0150		CODE N40085		7. ADMINISTERED BY (If other than Item 6) SCD: PAS:		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				☒		9A. AMENDMENT OF SOLICITATION NUMBER N4008525R2639	
				☒		9B. DATED (SEE ITEM 11) 26 Jan 2026	
				☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
				☐		10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

See Section 00 70 00 - Conditions of the Contract

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**


CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

See Schedule

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) CATHARINE A. KEELING	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)	16C. DATE SIGNED 12 Feb 2026
(Signature of person authorized to sign)			

Previous edition unusable

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section 00 72 00 - General Conditions

Miscellaneous text in this section has been added to:

Amendment 0002

This amendment is issued to incorporate the following:

1. Update Site Visit Instructions
2. Provide responses to Pre-Proposal Inquiries (PPIs) (attached separately)

-
1. Updated Site Visit Instructions (update notated in red)

4.1 SITE VISIT

Site Visit:

Date: Wednesday, 18 February 2025

Time: 10:00 AM ET

Meeting Location: 1059 Bellinger Blvd. Norfolk, VA 23511 Parking Lot. Site Visit Map is attached. (Attachment M).

THE FOLLOWING NEEDS TO BE COMPLETED FOR ALL ATTENDEES THAT NEED BASE ACCESS:

Personnel wishing to attend the site visit and who need assistance with obtaining a one-day pass for base access must email necessary forms (see below) to Mellisa Licata at mellisa.d.licata.ctr@us.navy.mil and CC catharine.a.keeling.civ@us.navy.mil. Attachment I -SECNAV FORM 5512 and Attachment J -ODP Badge Access Request Form must be fully completed for each individual attendee who needs base access. Complete all the information to ensure your forms are processed. Both forms must be included with your email.

On the morning of the site visit, please meet Mellisa Licata at the Naval Station Pass Office - 9040 Hampton Blvd, Norfolk VA 23505 at 8am in order to complete the processing of your one-day pass. **PLEASE BRING A REAL ID.**

Please ensure you submit your request no later than Tuesday, 3 February 2026 by 12pm ET, or it will not be guaranteed that your request will be approved in time for the site visit.

All personnel wishing to attend the site visit MUST email Catharine Keeling at catharine.a.keeling.civ@us.navy.mil a list of names with their associated companies that will attend the site visit no later than Tuesday, 3 February 2026. Please state in your email if those names have Base Access or not.

2. Pre- proposal Inquiry Responses

PPI #	Page	Section	Paragraph	Question	Response
1	S-001, SF521, UFGS 08 34 16.20	S-001: Section 2 Design Load Criteria SF521: VLF Door Repairs Section UFGS 08 34 16.20 Specification Requirements		Per S-001, Section 2 (Design Criteria), the Wind Load Design Criteria and associated Design Wind Pressures for wall components are defined as follows (101+ SF): Zone 4: +31 / -76 psf Zone 5: +53 / -96 psf These pressures are based on ASCE 7-16, 128 mph Vult, Risk Category III, Exposure D, and, per UFGS 08 34 16.20, the Vertical Lift Fabric Doors are required to be designed as "Partially Enclosed." Sheet SF521 identifies the scope of work as Vertical Lift Fabric Door Repairs. However, the existing Vertical Lift Fabric Doors were originally designed in 2008 in accordance with ASCE 7-05 and for a wind load design pressure of 43 psf. The current UFGS 08 34 16.20 RFP Specifications (Rev. 8/21 with Change 2 dated 8/24) include requirements that the existing Vertical Lift Fabric Doors, as designed, do not comply with. Please confirm whether: The existing Vertical Lift Fabric Doors may be repaired as currently designed, with the applicable RFP compliance requirements waived, or The existing Vertical Lift Fabric Doors must be fully replaced to meet the current RFP Design Criteria and specification requirements.	Repair as indicated. All new components provided must comply with contract documents. Any existing components that are otherwise functional and will remain in service do not need to be "upgraded" to comply with specifications.