

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 9	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 10-Apr-2025		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY CODE COMNAVFACSYSCOM WASHINGTON 1314 HARWOOD ST WASHINGTON DC 20374		7. ADMINISTERED BY (If other than item 6) CODE See Item 6					
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X 9A. AMENDMENT OF SOLICITATION NO. N4008025R9500			
				X 9B. DATED (SEE ITEM 11) 13-Mar-2025			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer ☐ is extended, ☐ is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) N40080-25-R-9500- Design-Build (DB)/Design-Bid-Build (DBB) Indefinite-Delivery/Indefinite-Quantity (IDIQ) Multiple Award Construction Contract (MACC) for Large Scale U.S. Military Projects, Locations in Washington D.C., Maryland, and Virginia PLEASE SEE SF30 BLOCK 14 CONTINUATION PAGE							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 10-Apr-2025	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE (SF 30)

The following have been added by full text:

0006

The purpose of this amendment is to:

1. Provide Preproposal Conference and Site Visit Detail (Separate Attachments):
 - Attachment M Pre-Proposal Conference Presentation
 - Attachment N Pre-Proposal Conference and Site visit Attendee Log
2. Provide revised ATT H - Price Proposal Form
3. Provide PPI Responses

- 1-2. Revised Solicitation:
Section 00 21 00 – INSTRUCTIONS TO PROPOSERS

TO: Revise Section 6: ATTACHMENTS:

Attachment A PIEE Vendor Registration Instructions
 Attachment B PPI Log
 Attachment C Construction and Design Experience Project Data Sheet
 Attachment D Past Performance Questionnaire (REVISED 04022025)
 Attachment E Small Business Subcontracting Plan
 Attachment F Historical SB Utilization
 Attachment G Small Business Participation Commitment Document
 Attachment H P-691 Price Proposal Form (REV04102025)
 Attachment I P-691 Specifications
 Attachment J P-691 Drawings
 Attachment K SECNAV5512 Access Form
 Attachment L N4008025JA009 (Redacted)
 Attachment M Preproposal Conference and Site Visit Presentation
 Attachment N Preproposal Conference and P691 Site Visit Attendee Log

2. PPI responses:

	Reference			Inquiry	Government Response
#	Page	Section	Para		
50	GC104			General Note 7 on Sheet GC104 states	Confirmed.

				that "Estimated 3 Month waiting period after full height surcharge placement" Please confirm that the 801 day construction duration is based on this 3 month waiting period and that in the event the waiting period exceeds three months, the construction duration will be increased accordingly.	
60	AE414	B1, B3		The door schedule on AE601 states there is on access panel located in A23F. Detail B3/AE414 shows that a 2'x2' access door at the top of the stairs, noted by item H. The top of the stairs on detail B1 show this as door F16A. Detail A3/AE415 shows another access door underneath of the stairs. Please confirm the access door is beneath the stairs and the door at the top of the stairs is to be F16A. If so, please add this additional access panel to the door schedule on AE601.	Bid per RFP. Elevation A3/AE414 shows door F16A at top of stairs. Section A3/AE415 shows access door beneath stairs.
61	E-111C			Confirm furniture whips and final connection to furniture by Owner's Furniture Vendor.	Bid per RFP; Furniture systems final connections are to be made by contractor.
62	14	09 97 13.27	3.2	Section 09 97 13.27-3.2 and AE615 indicate that the exposed steel in the hangar bays is to be coated with the 3 coat shop applied high performance paint system. It also says to coat all other exposed ferrous metal per	Bid per RFP. The hangar bay steel roof joists are considered "secondary members per AE614 note "c". The steel deck in the hangar bay is allowed to be coated with the

				099000. We believe that is interpreted to mean that the joists and deck at the main hangar roof are to follow 099000-3.13.2.3 and receive an Alkyd Primer per MPI 76, and may be field painted ILO shop coated for the intermediate and finish coats of paint. Please confirm.	field applied primer / paint as specified per 09 90 00 - PAINTS AND COATINGS.
64	P-101A typ; P-502			The emergency eyewash station (see P-101A; P-502) do not appear to have any floor drainage in the event of use. Is the intent that they drain into the ILDFA area, or is there floor drains that are not shown and will be required? Please clarify.	Bid per RFP. No additional floor drains are required. ESEW is to spill on the floor and said spill to be collected/squeegeed into adjacent drain in ILDFA system.
67	AE121A - AE121F			Architectural roof plans (e.g. AE121A) note 5 call for Fall Protection system to continue to structure. Please provide details for structural attachments at relevant conditions (at beams, at joints, in between beams or joists).	Bid per RFP; see detail C1/AE124.
71	GC104			Per drawing GC104 wick drains and surcharge must be placed in the designated areas and monitored for 3 months. The detail on this sheet shows wick drains, a 12" drainage layer and 5' of surcharge material. This detail shows the top of the drainage layer to be finished elevation. Is finished elevation, as shown on this drawing, intended to be proposed grade	Confirmed; Finished elevation in this detail is top of proposed grade.

				or subgrade? For example, within the hangar FFE is 47.00', is the finished floor referenced on GC104 at elevation 47' or would it be slab subgrade (bottom of slab aggregate base)?	
72	AE101F			CORR F17 on AE101F has a ramp in it. There are no wall railings at the ramp. Please confirm that none are required.	Confirmed, no handrails are required.
76		02 82 00 02 83 00 02 84 33 02 85 00		The project manual includes specifications for the removal/remediation of asbestos, lead, PCBs, and Mold, presumably present in the buildings to be demolished. There are no Hazmat Surveys, or other documents included that indicate the locations and bid quantities of each to be removed. Please provide the hazmat surveys and/ or reports with this information.	Refer to Appendices A-D in the provided Specifications for hazmat surveys.
77	GC104			The General Notes and Surcharge Detail on drawing GC104 require a 5ft earth surcharge over a 12" drainage layer for an estimated 3 month waiting period over the entire building footprint and a majority of the airfield pavement area. Per Note 1 under the Surcharge Detail, "Contractor's Geotechnical Engineer to confirm design and extent of surcharging to mitigate underlying compressible soil layers". Please confirm that bids are to be	Confirmed. Bid per RFP.

				based on the General Notes and Detail per GC104 and that after award, the Contractor is to retain the services of a Geotechnical Engineer to confirm the design and extent of surcharging.	
78	CD101			For the fire suppression line that crosses Millstone Road and continues north to its tie in point please confirm all tree removal, asphalt sawcutting and patching on CD101 will be performed under ASUS's contract with the government.	Confirmed. Bid per RFP.
81	CU104, CU105			Please confirm the 2" sanitary sewer force main w/ 8" casing under the concrete apron is to be by the contractor and not by ASUS.	Confirmed, work referenced is to be completed by contractor as per RFP.
126				The RFP states " <i>Offeror shall submit a narrative detailing the first task order seed project requirements solution. The narrative should describe how the Offeror intends to successfully complete the seed project. The narrative plan shall not exceed three pages. Information beyond the four-page limit will not be considered.</i> " Please confirm a 4-page narrative is allowed for the schedule narrative.	Bid per Amendment 0005, "Four pages"
145	17	Factor 3: Past Performance: (i) Solicitation Submittal Requirements		In reference to PPI 95 response included in Amendment 0005, please confirm whether the completed CPAR can be a completed interim (i.e.	Bid per RFP, "If there is not a completed CPARS evaluation then submit Past Performance

				not in draft form from the client) CPAR, or if completed is referring to a final CPAR for a project.	Questionnaires (Attachment B) for each project included in Factor 2 for both Construction Experience and Design Experience."
146	17	Factor 3: Past Performance: (i) Solicitation Submittal Requirements		In reference to PPI 98 response included in Amendment 0005, please clarify the response. "Confirmed" makes it appear as though past PPQ can be provided, but the "shall not incorporate by reference" makes it appear as though submissions should not include PPQs from other submissions. Please clarify.	Bid per RFP, Offerors shall not incorporate by reference , but are not prohibited from including the entirety of the previously completed PPQ
147	General			How can an Offeror identify themselves as a Small Business to ensure all reviewing parties acknowledge business status, and understand some requirements (Attachment F submission) do not apply to Small Businesses?	Bid per RFP, "SAM Registration Offeror shall ensure current registration on the SAM Website, www.sam.gov , including Annual Representations and Certifications are complete and updated for this procurement."
148	10 of 96 - Solicitation			Page 10 of 96 of the Solicitation states that based on FAR 19.7, all other than Small Businesses shall submit a Small Business Subcontracting Plan (SBSP, Attachment E). For Small Businesses that are not required to submit an SBSP, should offeror submit a blank Attachment E	Bid per RFP.

				or submit no Attachement E.	
149	Solicitation			Are we able to use reduced font in graphics so long as it is legible?	Bid per Amendment 0004, "10-point Times New Roman"
150	Amendment 1 and 3			Confirm the period of performance - Amendment 1 (page 30 of 32) 52.211-10 calls for 802 CD - Amendment 3 (page 2 and 3 of 9) states 801 CD - please clarify period of performance.	Bid per Amendment 0003.
151	RFP 15/96	(2) Design Experience		This section requires that the offeror provide applicable documentation on projects that were validated and/or certified through a Sustainable Third Party Certification program. Please confirm that this documentation is excluded from maximum page counts.	Confirmed.
152	RFP 22/96	Factor 6 Technical Solution	(i) 2. Critical Path Method Schedule	Please confirm that the CPM Schedule is excluded from the maximum page count for the Factor 6 Technical Solution.	Confirmed.
153	RFP 11/96	Non-Price Proposal Factors	(i) Solicitation Submittal Requirements	This section indicates that text pages are limited to 8 1/2 x 11 format. Please confirm that 11 x 17 pages may be used for the CPM Schedule.	Confirmed.
154	RFP 11/96	Non-Price Proposal Factors	(i) Solicitation Submittal Requirements	Please confirm that 11 x 17 pages used for the MACC Program Organizational Chart only counts as a single page toward the maximum page counts for their relevant sections, if it is not excluded.	Bid per RFP, "Information beyond the five- page limit will not be considered, with the exception of an organizational chart which is not

					included in the page limitation."
168			PPI 9	PPI 9 - Please confirm the PLA is deleted from the Contract Requirements per PPI 10	Confirmed.

(End of Summary of Changes)