

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 12	
2. AMENDMENT/MODIFICATION NO. 0013		3. EFFECTIVE DATE 09-May-2025		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY COMNAVFACSYSCOM WASHINGTON 1314 HARWOOD ST WASHINGTON DC 20374		CODE N40080		7. ADMINISTERED BY (If other than item 6) See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. N4008025R9500	
				X		9B. DATED (SEE ITEM 11) 13-Mar-2025	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer ☐ is extended, ☒ is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) N40080-25-R-9500- Design-Build (DB)/Design-Bid-Build (DBB) Indefinite-Delivery/Indefinite-Quantity (IDIQ) Multiple Award Construction Contract (MACC) for Large Scale U.S. Military Projects, Locations in Washington D.C., Maryland, and Virginia PLEASE SEE SF30 BLOCK 14 CONTINUATION PAGE							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 09-May-2025	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE (SF 30)

The following have been added by full text:

0013

The purpose of this amendment is to:

1. Provide revised ATT H - Price Proposal Form and new ATT O - Signage Guideline from Installation Appearance Plan
2. Provide revisions to design documents in accordance with noted PPIs
3. Provide PPI responses

Proposal due date remains unchanged at 22 May 2025 1400 local time

1. Revised Solicitation:

Section 00 21 00 – INSTRUCTIONS TO PROPOSERS

TO: Revise Section 6: ATTACHMENTS:

Attachment A PIEE Vendor Registration Instructions

Attachment B PPI Log

Attachment C Construction and Design Experience Project Data Sheet

Attachment D Past Performance Questionnaire (REVISED 04022025)

Attachment E Small Business Subcontracting Plan

Attachment F Historical SB Utilization

Attachment G Small Business Participation Commitment Document

Attachment H P-691 Price Proposal Form (REV05092025)

Attachment I P-691 Specifications

Attachment J P-691 Drawings

Attachment K SECNAV5512 Access Form

Attachment L N4008025JA009 (Redacted)

Attachment M Preproposal Conference and Site Visit Presentation

Attachment N Preproposal Conference and P691 Site Visit Attendee Log

Attachment O Signage Guideline from IAP

2. Revisions to Specification Sections and Drawings:

Note: Revised Specification and Drawing Sheets issued by way of amendment 0013 are available via restricted access through PIEE. If an offeror has an issue retrieving the revised documents, they are instructed to contact the Contract Specialist, Molly Lawson at molly.e.lawson.civ@us.navy.mil in order to receive the documents via DoD Safe.

PPI #139, 194, 248, 347, 437 - See Attachment O and revision to specification section 01 30 02.00 22

PPI #384 – See revised Attachment H

PPI #471 – See revision to specification section 34 73 13

PPI #584 – See Attachment O

PPI #521 – Delete specification section 09 67 23.13

PPI #692 – See revision to specification section 03 30 00

Per Amendment 0010 (PPI#565, 616) – See revision to specification 27 41 00

3. PPI Responses:

	Reference			Inquiry	Government Response
#	Page	Section	Para		
139	01 30 02.00 22	1.3	3	Specification section 01 30 02.00 22 states that "The Government AV budget on the Bid Schedule/Price Proposal Form for the AV Planned Modification is \$43,800.00 and does NOT include the Contractor's Handling and Administration Rate (HAR)." Please confirm Option 7 (CLIN 0008) shall be \$43,800.00 + HAR.	Bid per bid sheet. Refer to Government Response to PPI #347.
141	31 00 00	1.6.1		Specification section 31 00 00 states that all excavation will be designated as unclassified. Please confirm this is Unclassified to Subgrade.	Confirmed.
194	Specifications	01 30 02.00 22	1.3	Specification section 01 30 02.00 22 1.3 states that the Government AV budget on the Bid Schedule/Price Proposal Form for the AV Planned Modification is \$43,800 and does not include the Contractor's HAR. However, the Price Proposal Form provided in Amendment 0002 does not show the AV Option as a Planned Modification with the Government Budget. Please confirm that the AV Option on the Price Proposal should be revised to include the Government AV Budget and Contractor's HAR.	Bid per bid sheet. Refer to Government Response to PPI #347.

197		Price Proposal Form	General Bid Note 1.2c	On the Price Proposal Form, General Bid Note 1.2c states that CLINs 0002-0007 may be awarded within 365 days after contract award. However, CLINs 0002-0004 would need to be determined sooner due to the timing of shop drawing submittals and procurement of materials in order to complete this project within the 801 day duration. Please consider reducing the award of CLINs 0002-0004 to 60 days after contract award.	Refer to New Price Proposal Form. See revised attachment H
248		01 03 02.00		Spec reads that AV install is to be \$43,800 and not modified by contractor. Please confirm that this price should be carried for CLIN 0008 Opt 7.	Bid per bid sheet. Refer to Government Response to PPI #347.
273	CU105			Tellecommunications ductbank (labeld CU) on CU105 notes to reference telecommunications plans for details. Telecom site utility plant TS101 does not shown this ductbank. Provide details of ductbank or confirm this is not in scope.	Yes, reference re-issued drawing TS101 in amendment 011
275				Are new site conduit telecom concrete encased or direct burried, please provide detail for new work	Details provided on CU501, detail 2
293	Price Proposal Form	1.2 General Bid Notes		Price Proposal Form, General Bid Note F indicates that the contract completion date (CCD) does not change if any or all of the bid options award but only specifically addresses CLINS 0001 - 0008. Please clarify if the CCD changes should CLIN 0009 be exercised, or if it remains the same.	CCD will not be extended with options. Refer to New Price Proposal Form. See revised attachment H
347	Spec 01 30 02.00 22 Page 2	1.3		AV specifications state "The Government AV budget on the Bid Schedule/Price Proposal Form for the AV Planned Modification is \$43,800. Please update the bid pricing sheet to reflect this.	Bid sheet to remain as is. Refer to revision to specification section 01 30 02.00 22
384	Attachment H	1.2 General Bid Notes	c & f	Per part "c" CLIN 008 is not required to be executed within 365 days of award, however part "f" notes that CLIN 008 must be complete within the CCD (801 days) timeline. Please confirm that CLIN 008 is not fixed to the RFP Contract Completion Date.	AV does need to be completed by the CCD. See Revised Attachment H - Price Proposal Form

437		01 30 02.00 & Bid Form	(1.3) (2.1.1)	Section 01 30 02.00 22 (1.3) calls for the purchase and installation of the AV Package to be funded separately. Section (2.1.1) calls for the AV Estimate to be indicated on Price Proposal Form (Bid Schedule). Will the government be providing a new Bid Schedule with the AV estimate or are contractors to include the Government's AV budget of \$43,800.00 and /or Contractor's Handling and Administration Rate (HAR) for Option No.7: CLIN 0008 on Bid Form?	Refer to Government Response to PPI #347.
471	39	32 13 14.13	2.12.1	This paragraph calls for 650 flexural concrete for the apron. On page 2 of Spec Section 34 75 13, Paragraph 2.3, the concrete around the mooring eyes is to be 6,000 psi. Are these blocks to be 6,000 psi or is the whole apron to be 650 flexural concrete?	See specification 32 13 14.13 in RFP and revised specification 34 73 13
521	N/A	09 67 23.13	N/A	There are 3 resinous flooring specs (Standard, 3 - Coat, and 5 - Coat). However, within the finish schedule there are only 3 - Coat and 5 - Coat identified. Is there additional resinous flooring areas receiving Standard Resinous?	There is no standard resinous flooring in the project. Delete specification section 09 67 23.13
548	CD105 & TS101			The civil and comm drawings show comm duct bank demolition but no relocations. Confirm if this contract is to include reroutes for comm cables being demolished and if so, identify quantity and routing.	Lines denoted in drawing are not on record at PWD as live and needing re-location. KTR to provide for demolition only and notify COR if/when lines are encountered.
584	CS512			Page CS512 indicates a building sign that requires matching existing installation. Please provide appropriate information for subcontractors to price the sign including finish, support, foundation, applicable utilities, and sign content.	Refer to signage guidelines from Installation Appearance Plan to be provided as Attachment O.
660	CU104 & CU105			Utility Plans CU104 and CU105 indicate to install steel casing around the existing 8" fuel line which is located under the new concrete airfield apron. In addition there are also fuel line casing vents to be constructed at each end of the fuel line casing. There is no profile provided for this existing fuel line. Please provide a profile for the existing fuel line so that the depth below existing grade can be determined.	KTR to field verify through soft dig, to verify depth of fuel line

661		12 24 13	2.1	Indicates a recycled fiber requirement that no shade manufacturer meets. There is no manufacturer that offers a product with 60% of recycled material included in its components. Confirm we can exclude this requirement.	Requirement may be waived
662		12 24 13	1.1.2.3.a	This section mentions a shade in Lobby B21, however the RCP only indicates shades (Keynote"4") in the Conference Room. Please advise.	Shade in lobby as well. IN101B
663		12 24 13	2.1.2.3.c	This section indicates fabric attachment to be manufacturer's standard method. The BOD Manufacturer – Lutron – uses LSE (Low Surface Energy) adhesive as its standard method of fabric attachment. Confirm we can quote shades that use adhesives for shadeband/fabric attachment.	Confirmed.
664		12 24 13	2.1.2.5.a	This section indicates 3% fabric with no other provisions. Confirm if we can quote any 3% solar fabric offered by Draper for manual light filtering shades.	Bid per RFP. See AE616
665		12 24 13	2.1.2.6	This section indicates Front Fascia or Exposed Headbox for the shades's top treatment. Which is preferred?	Front Fascia

666	AE112B, Keynote 4			This note indicates roller shade location. This keynote only shows up in Conference Room B22. Specification mentions shades at Lobby B231. Please advise.	Refer to Government Response to PPI #662.
667	AE504/Detail C2			This is not clear as to whether these shades are to have fascia or headbox. Please advise.	Refer to Government Response to PPI #665.
668		DIVISION 28		Section 08 71 00-2.3 states that there is a DIV 28 Electronic Security Systems ESS specification section, however, this specification section is not in the project specification manual. Please provide to price 'CLIN 7 Option 8 Electronic Security System ESS'	ESS is pathways only. No DIV28. Refer to section 26 20 00. Design and install of ESS devices by others. KTR to provide for coordination.
669				Can a specific division be bid alone, ie; Division 27 as Prime for that single division.	No
671				Are there specific manufactures, brands, that are required for Low Voltage Data Cabling (Cat6, Cat6A, Single or Multi Mode Fiber)	No

672				There are some Cable Location that don't have a (U) or a(S) so what do these require as far as cabling? Did these just get missed and need a cable designation? Example – 3rd drawing section – 1st floor area B, several desks not identified.	See updated drawings re-issued as a part of Amendment #0011. Non-labeled devices default to a “U”
673				What are the clarifications for pre-approval of subcontractors that may be utilized? Is Pre-Approval needed prior to bid, or a post award.	Bid per RFP
674				Is this a Prevailing Wage for Division 27	Bid per RFP
675	4	11 01 50	2.1	The interior fall protection specification states that the system will be designed for three users per line, on line each over fuselage and wings as illustrated on the structural drawings. These areas are not noted on the structural drawings, S152 C3 notes a D-ring attachment point at the antenna platform but does not note any other fall protection locations. Please clarify.	See Government response to PPI#57, 314 and 432, amendment 0008, 0009
678	AE205	Material Keynotes List	Item #24	The hangar doors are noted to be clad with FWP3 panels. Exterior materials legend on AE617 only notes FWP1 and FWP2 fabricated wall panels. Please confirm the hangar door panels should be FWP1 to match the adjacent wall panels.	Refer to Government Response to PPI #295, amendment 0011

679	S-301,S-302			Details on drawings S-301 and S-302 indicate details, locations and quantities of tension rods that are to be installed. Please provide diameter and length of tension rod, or provide uplift loads at these locations so that the diameter and length can be determined by the ground improvement engineer as diameter and length are currently not shown on the Contract Documents.	See Government response to PPI#387, amendment 0008. Sheet S-302 was re-issued as a part of this amendment
680	CU504			Drawing CU504 requires a minimum 1" (Schedule 100) thickness for the 16" diameter fuel line casing, which split case piping manufacturers are having trouble sourcing. Please confirm if Schedule 40 split case piping would be acceptable for the fuel line casing similar to casing wall thickness required for the sanitary force main that also goes under the concrete apron.	No, bid per RFP.
681		09 97 13.27	1.4.6.8	The qualifications for the coating contractor is indicates as SSPC QP1. This certification is for field applications (which we assume would be relegated to touchup of the steel). Due to the fact that the intent to shop coat the paint, shouldn't they also be QP3 for the shop coatings? Please confirm.	Bid per RFP. See AE616
682		05 12 00	2.6.2	Section 05 12 00 - 2.6.2 requires the use a AISC certified contractors carrying the SPE1 certification for Sophisticated Paint. Is the intent that the we will need both the AISC SPE1 certification and the SSPC QP1/QP3 certifications (per 09 97 13.27) to apply the shop applied coatings, or if the steel contractor is SPE1 we do not need the SSPC QP1 and QP3 certifications, meaning we just need one set of certifications or the other? Please clarify.	Bid per RFP.
683	PPI Response 186, Amendment 0008, Page 9			PPI Response 186, issued in Amendment 0008, indicates that there is no security scope for devices, wiring, or equipment as part of the CM contract for the project. The pathway infrastructure is indicated in CLIN 0007 to be base bid and not included in CLIN 0007. Bid form note 1.2 b states that Failure to enter a price for any CLIN will be result in a proposal being rejected as unacceptable.	Refer to New Price Proposal Form. See revised attachment H

				Please clarify if CLIN 0007 / Option 6 for security shall be left blank on the bid form submission and that note 1.2 b would not apply to this situation. Or please provide a new bid form bidders clarifying/removing CLIN 0007.	
684	PPI Response 132, Amendment 0008, Page 6			PPI Response 132 response states that design for the FF&E needs to be under the base contract. Please clarify if the construction manager needs to hire an architect/designer to design the FF&E for this scope as a design build component of this project or if this scope will be designed by the Owner's designer.	PPI Response 132, Amendment 0008, Page 6. KTR to hire their own Interior Designer as a part of services described in RFP.
685	PPI Response 132, Amendment 0008, Page 6			Similarly to PPI Response 132, please clarify if the design of the security (outside of CM contract) and the AV (outside of CM contract) need to be design build costs by the CM or if this scope will be designed by the Owner's designer.	Design for the support /infrastructure of the ESS is complete and a part of the base bid. Design and installation of the ESS if GFGL.
686	PPI Response 308, PPI Response 426			PPI 308 and 426 requested more information, a specification, and details on the fire draft curtains that are identified on the structural drawings. Without a specification here subcontractors will not be able to accurately bid the intent of the scope. Please provide a specification, details, and time to allow for the subcontractors to accurately propose on the scope. If specification, details, and time are not available to price the scope please provide an allowance to carry for this scope.	The information on the draft curtains is shown in details C1/S-337 and C2/S-337. The cold-formed metal framing is a delegated design in accordance with specification 05 40 00. Refer to PPI Response 308, PPI Response 426

688	34 73 13 Section 3.1			Specification 34 73 13, subsection 3.1 calls for installing mooring devices within +/- 2" of the location shown in the contract drawings. Where in the contract drawings are these mooring devices located?	Labeled as tie downs, not moorings. CS 121, keynote 6
689	PPI #443			PPI #443 issued with Amendment 0010 notes revisions to CS508. Revised CS508 was not issued with Amendment 0010, please issue the updated drawing.	Refer to CS508 issued with amendment #0011
690	PPI #247, 436			PPI #247 issued with Amendment 0010 states that the AV design is already complete and included with the construction documents, where as PPI #436 states that AV design services are to be included in the base bid. Please confirm, per PPI #247, no additional AV design services are needed.	Refer to Government Responses to PPI #436, 571, amendment 0010 & amendment 0011
691	PPI #186, 266, 556-564, 659			Per the referenced PPI's the Electronic Security System is GFGL. As referenced in Attachment H, the supporting infrastructure (pathways etc) are to be included in CLIN 0001. Please confirm that CLIN 0007 can be removed from the Price Proposal Form.	Confirmed. See revised attachment H
692	PPI #421			Amendment 0008 responded to PPI #421 regarding pour size limit of 1,200 sf as noted in 03 30 00 3.11.1.1. The PPI response states to review the updated 03 30 00 specification provided with Amedment 0008, however this section of the specification was not updated. Please confirm that contractors are not required to provide a maximum pour size of 1,200 sf.	Limit removed. See Amendment 0013 for revised specification section 03 30 00.

(End of Summary of Changes)