

Repair AFLD Lighting SYS MAFB

Question #	Answer	Date
01) Does the Prime contractor have to be within 100 miles?	1A) Yes, the contractor is required to be a Small Business located within a 100 mile radius of Maxwell AFB.	7-Apr-26
02) The Statement of Work does not clearly define whether the existing light fixtures, regulators, transformers, or other devices on circuits A-1, A-2, A-3, S-1, and PP-2 must be completely replaced or if only targeted repairs are required. While the scope explicitly calls for replacing the current-carrying conductors (FAA-L 824 #8 cable) and associated raceways, it is silent on full component replacement if legacy equipment is found to be obsolete or non-functional during execution. Bringing the systems fully up to current FAA standards could therefore necessitate a total replacement of certain components, as many older parts are no longer manufactured or supported by the original equipment manufacturers.	2A) The intention was to replace the conductors and to make targeted repairs for devices; restoring functionality to the circuits and airfield. Total replacement is a project currently in design so this project will avoid total replacement. Any devices/circuits found to be obsolete and/or un-serviceable shall be addressed on an individual basis and by modification or new contract work.	8-Apr-26
03) Is Standard Form 1442 the only form required to submit a bid?	3A) The SF1442 with proposed pricing and the AF3052 Construction Cost Breakdown are requirements of the proposal.	7-Apr-26
04) Are there any amendments at this point?	4A) Yes, Amendment FA330026R00160001 was published on sam.gov on 3Apr26. Please, review sam.gov for the most current information.	7-Apr-26
05) Section L-3(b) mentions unit price, Is that the total price?	5A) The unit of issue is EA (per the Solicitation) the unit price shall be the total price.	7-Apr-26
06) Section L-3(d) References attachment 03 Air Force Form (AF3052). I do not see it.	6A) The Contract Specialist shall upload another AF3052 to sam.gov. If you are unable to access the published AF3052, please email the Contract Specialist or alternate for an emailed digital copy. (See ATTCH 03)	7-Apr-26

Repair AFLD Lighting SYS MAFB

07) Please, verify that Material Onsite payments and work progress payments exist.	7A) Progress payments are authorized.	7-Apr-26
08) Is there a grounding report or system audit?	8A) There is not. (checked with airfield team and electricians)	8-Apr-26
09) Can the contractor request a reduction of \$2,834.00 in liquidated damages FAR 52.211-12?	9A) There will be no reduction of the current liquidated damages assessment.	7-Apr-26
10) May we assume the contract could be extended 6 months, due to unforeseen circumstances?	10A) The contract has an anticipated period of performance of 195 calendar days after receipt of Notice To Proceed. The contract awardee may request/negotiate an alternate PoP schedule during the Pre-Construction Conference, if necessary.	7-Apr-26
11) May the contractor work weekends?	11A) Weekend work request are determined by the CO on a case by case basis. The contract awardee may request/negotiate an alternate PoP schedule during the Pre-Constuction Conference, if necessary.	7-Apr-26
12) Does the Government provide soil condition and possible underground cluster information for trench lines?	12A)The soils that will be encountered will consist of layers of saturated sand and clay. Expect the soils to be in a near saturated condition. No rock will be encountered. Please find supplemental paving samples acquired near the control tower that may be found as useful.	8-Apr-26
13) Can the Question due date/time be extended?	13A) No, there shall be no extension to the due date/time of questions.	7-Apr-26
14) Can the Proposal due date/time be extended for 14 days to further evaluate the solicitation and satisfy this requirement?	14A) No, the proposal due date/time of Monday, 13Apr 2026 at 1200 (CDT) shall remain the same.	8-Apr-26

Repair AFLD Lighting SYS MAFB

[illegible]