

ASBESTOS INSPECTION REPORT of:

Building # HP265

MCB CAMP LEJEUNE



Print Date

Thursday, March 12, 2026

INSPECTION SUMMARY

BLDG #: HP265

YEAR BUILT: 1983

OCCUPANT: BEQ

ASBESTOS MANAGER: 910-451-5837

BUILDING COMMENTS:

HAZ RANK 3/GREEN [JUN2023]
LTD. ACM SEALANTS ON ROOF/ ATTIC

JUN2023
ACM REMAINS

DEC2019
NO CHANGES

AUG2016
ACM REMAINS

APR2014
MAJOR RENOVATIONS/ GUTTED. LIMITED ACM ROOFING SEALANTS REMAIN, OTHER ACM HAS BEEN ABATED TO BARE CONCRETE.

AUG2011
PVS. ACM TRANSITE DEBRIS REMOVED BY INSPECTOR, ADDL SAMPLING, NO ADDL ACM ID'D

JUL/DEC09
TEM/ PLM CONFIRMATION SAMPLING, PVS. ACM CONFIRMED AND REMAINING, ADDL ACM INCLUDES:
TRANSITE PANEL MATERIAL, GRAY

NOV06
ACM IDENTIFIED INCLUDES:
12" TAN w/BROWN FLOOR TILE AND MASTIC
ROOF TAR, FLASHING MATERIALS, BLACK/ GRAY

NOTIFICATION OF ACM IN BUILDING

NOTICE: The following asbestos-containing materials have been identified in this structure. Refer to survey findings for additional information or contact the Asbestos Program Manager. Please note ACM that is intact and undisturbed is not considered a significant health hazard to building occupants.

Friable ACM(s) identified

<i>DESCRIPTION</i>	<i>LOCATION</i>	<i>Date</i>	<i>Quantity</i>
No friable ACM records found in database			

Non-friable ACM(s) identified

<i>DESCRIPTION</i>	<i>LOCATION</i>	<i>Date</i>	<i>Quantity</i>
ROOF FLASHING/SEALER MATERIAL	ROOFING SYSTEM PARAPET WALL COVERINGS	11/8/2006	1,500 SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	11/8/2006	124 SF
ROOF FLASHING/SEALER MATERIAL	ROOFING SYSTEM PARAPET WALL COVERINGS	7/9/2009	1,500 SF

ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	7/9/2009	124	SF
ROOF FLASHING/SEALER MATERIAL	ROOFING SYSTEM PARAPET WALL COVERINGS	8/26/2011	1,500	SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	8/26/2011	124	SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	8/17/2016	12	SF
ROOF FLASHING/SEALER MATERIAL	ROOF/ ATTIC, CENTER LINE OLD VENT PIPES AND DRAINS	12/10/2019	10	SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	12/10/2019	12	SF
ROOF FLASHING/SEALER MATERIAL	ROOF/ ATTIC, CENTER LINE OLD VENT PIPES AND DRAINS	8/17/2016	10	SF
ROOF FLASHING/SEALER MATERIAL	ROOF/ ATTIC, CENTER LINE OLD VENT PIPES AND DRAINS	4/15/2014	10	SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	4/15/2014	12	SF
ROOF FLASHING/SEALER MATERIAL	ROOFING SYSTEM PARAPET WALL COVERINGS	6/8/2023	10	SF
ROOFING SEALANT, GRAY	ROOFING SYSTEM CENTER VENT FAN BASE FLASHINGS	6/8/2023	12	SF

Tested Non ACM or REMOVED Materials

<i>DESCRIPTION</i>	<i>LOCATION</i>	<i>Date</i>
JOINT MATERIAL	DORM ROOMS WALL AND CEILING AT RESTROOM AREAS	11/8/2006
12" TAN w/BROWN FLOOR TILE AND ADHESIVE	DORM ROOMS AND CENTRAL LOUNGES THROUGHOUT	11/8/2006
FIBERGLASS INSULATION SEALANT	CENTRAL PIPE CHASES, EAST AND WEST MECHANICAL ROOM PIPING	11/8/2006
EXTERIOR CAULKING,	CONCRETE FOUNDATION/ WALKWAYS TO BRICK, AND BRICK WALL JOINTS	11/8/2006
DUCT SEALANT, RED	CENTRAL PIPE CHASES AND EAST/ WEST MECHANICAL ROOMS	11/8/2006
ROOFING MATERIAL,	ROOFING SYSTEM CENTER VENT FAN BASE FLASHING FELTS	11/8/2006
DUCT SEALANT, TAN	CENTRAL PIPE CHASES AND EAST/ WEST MECHANICAL ROOMS	11/8/2006
RESIDUAL MASTIC	SECOND FLOOR CENTER AREA LOUNGE	11/8/2006
EXTERIOR CAULKING,	CENTRAL LAUNDRY, EXTERIOR VENTS	11/8/2006
ADHESIVE	DORM ROOMS THROUGHOUT	11/8/2006

ROOFING MATERIAL,	ROOFING SYSTEM MEMBRANE TOP COAT AND PATCHING (SEE ALSO HM51)	11/8/2006
EXTERIOR CAULKING,	EXTERIOR WINDOWS AND DOORS	11/8/2006
12" BEIGE w/BROWN FLOOR TILE AND ADHESIVE	CENTRAL AREA LOUNGES	11/8/2006
12" OLIVE FLOOR TILE AND ADHESIVE	CENTRAL HALLWAY PATCHING	11/8/2006
12" BLACK w/ WHITE FLOOR TILE AND ADHESIVE	FIRST FLOOR CENTER LOUNGE (w/HM11) OVER HM08	11/8/2006
12" WHITE FLOOR TILE AND ADHESIVE	FIRST FLOOR CENTER LOUNGE (w/HM10) OVER HM08	11/8/2006
PITCH POCKET TAR	ROOFING SYSTEM AT EQUIPMENT/ HVAC MOUNTS, CABLE/ CONDUIT PENETRATIONS THROUGH ROOF	8/26/2011
BUILT-UP ROOFING	ROOFING SYSTEM TOP LAYER (SEE ALSO HM21)	8/26/2011
INTERIOR CAULKING,	METAL DORM ROOM DOORS AND VANITY SINKS	7/9/2009
WINDOW GLAZING MATERIAL	CENTER HALL LOUNGES AND LAUNDRY DOORS (w/WINDOWS)	7/9/2009
TEXTURED CEILING MATERIAL	DORM ROOMS	11/8/2006
INTERIOR CAULKING,	CENTRAL HALLWAY DOORS	11/8/2006
EXTERIOR CAULKING,	BRICK EXPANSION JOINTS IN STAIRWELLS AND NORTH/ SOUTH JOINTS	11/8/2006
VINYL THRESHOLD MATERIAL	CENTRAL HALLWAYS AT LAUNDRY AND EQUIPMENT ROOMS	7/9/2009
MEMBRANE-TYPE ROOFING	ROOFING DEBRIS	7/9/2009
2'x2' CEILING TILE,	CENTRAL AREA LOUNGES	11/8/2006
PIPE INSULATION SEALANT	PIPE CHASES AND LAUNDRY ROOM HEATER PIPE (CAPPING)	11/8/2006
ROOFING SEALANT, BLACK	BUCKET LID, ROOF SOUTHWEST (PATCHING MATERIAL UTILIZED)	7/9/2009
TRANSITE PANEL MATERIAL	EASTSIDE CENTER EXTERIOR GROUND	7/9/2009
CLOTH LAGGING MATERIAL	PIPE CHASES AND MECHANICAL ROOM FIBERGLASS INSULATION PATCHING	7/9/2009
ROOFING MATERIAL,	ROOFING SYSTEM MEMBRANE (UNDER RUBBER)	12/10/2019
ROOFING MATERIAL,	ROOFING SYSTEM CENTER VENT FAN BASE FLASHING FELTS	7/9/2009
ROOFING MATERIAL,	ROOFING SYSTEM MEMBRANE TOP COAT AND PATCHING (SEE ALSO HM51)	7/9/2009
ADHESIVE	DORM ROOMS THROUGHOUT	7/9/2009
EXTERIOR CAULKING,	CONCRETE FOUNDATION/ WALKWAYS TO BRICK, AND BRICK WALL JOINTS	7/9/2009
FIBERGLASS INSULATION SEALANT	CENTRAL PIPE CHASES, EAST AND WEST MECHANICAL ROOM PIPING	7/9/2009
DRYWALL AND JOINT MATERIAL	DORM ROOMS WALL AND CEILING AT RESTROOM AREAS	7/9/2009

TEXTURED CEILING MATERIAL	DORM ROOMS	7/9/2009
12" TAN w/BROWN FLOOR TILE AND ADHESIVE	DORM ROOMS AND CENTRAL LOUNGES THROUGHOUT	7/9/2009
12" WHITE FLOOR TILE AND ADHESIVE	FIRST FLOOR CENTER LOUNGE (w/HM10) OVER HM08	7/9/2009
EXTERIOR CAULKING,	EXTERIOR WINDOWS AND DOORS	7/9/2009
12" TAN w/BROWN FLOOR TILE AND ADHESIVE	DORM ROOMS AND CENTRAL LOUNGES THROUGHOUT	12/15/2009
12" BLACK w/ WHITE FLOOR TILE AND ADHESIVE	FIRST FLOOR CENTER LOUNGE (w/HM11) OVER HM08	7/9/2009
PIPE INSULATION SEALANT	PIPE CHASES AND LAUNDRY ROOM HEATER PIPE (CAPPING)	7/9/2009
12" TAN w/BROWN FLOOR TILE AND ADHESIVE	DORM ROOMS AND CENTRAL LOUNGES THROUGHOUT (MULTIPLE MIXED VARIETIES)	8/26/2011
ROOFING MATERIAL,	ROOFING SYSTEM MEMBRANE TOP COAT AND PATCHING (SEE ALSO HM51)	8/26/2011
INTERIOR CAULKING,	METAL DORM ROOM DOORS AND VANITY SINKS	8/26/2011
ROOFING MATERIAL,	ROOFING SYSTEM MEMBRANE (UNDER RUBBER)	6/8/2023

HEALTH ASPECTS:	ACM only presents a health hazard when asbestos fibers are airborne and inhaled. Avoid disturbance which will release fibers. The presence of asbestos does not constitute a health hazard.
CONDITIONS TO AVOID:	Do not disturb or cause damage to ACM. Do not sand, grind or abrade materials or cause damage with any type of equipment.
REPORTS OF DAMAGE:	Report any damage, dust or debris that may come from ACM or suspect ACM, or any change in the condition of materials, or accidental disturbance to the Asbestos Program Manager.
RESPONSE ACTION:	Corrective action initiated to minimize fiber release and protect personnel.
INSPECTION:	ACM will be inspected periodically to evaluate any changes in condition.
RECORDKEEPING:	The Camp Lejeune Asbestos Program Manager maintains a copy of the survey for the building.

CAMP LEJEUNE Asbestos Program Manager:

Phone: (910) 451-5837

SAMPLES COLLECTED

Sample	HA	Description	Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-01-01	01	JOINT MATERIAL	11/8/2006	1ST FL WEST, NORTH RM 122	0	0	0
HP265-01-02	01	JOINT MATERIAL	11/8/2006	2ND FL WEST, NORTH RM 218	0	0	0
HP265-01-03	01	JOINT MATERIAL	11/8/2006	3RD FL WEST, NORTH RM 328	0	0	0
HP265-01-04	01	JOINT MATERIAL	11/8/2006	3RD FL EAST, SOUTH RM 303	0	0	0
HP265-01-05	01	JOINT MATERIAL	11/8/2006	2ND FL WEST, SOUTH RM 221	0	0	0
HP265-01-06	01	JOINT MATERIAL	11/8/2006	1ST FL WEST, SOUTH 119	0	0	0
HP265-01-10	01	JOINT MATERIAL	7/9/2009	1ST FL WEST, NW RM	0	0	0
HP265-01-11	01	JOINT MATERIAL	7/9/2009	2ND FL EAST, NW RM	0	0	0
HP265-01-12	01	JOINT MATERIAL	7/9/2009	3RD FL WEST, NE RM	0	0	0
HP265-02-01	02	TEXTURED CEILING MATERIAL	11/8/2006	1ST FL WEST, NORTH RM 122	0	0	0
HP265-02-02	02	TEXTURED CEILING MATERIAL	11/8/2006	2ND FL WEST, NORTH RM 218	0	0	0
HP265-02-03	02	TEXTURED CEILING MATERIAL	11/8/2006	3RD FL WEST, NORTH RM 328	0	0	0
HP265-02-04	02	TEXTURED CEILING MATERIAL	11/8/2006	3RD FL EAST, SOUTH RM 303	0	0	0
HP265-02-05	02	TEXTURED CEILING MATERIAL	11/8/2006	2ND FL WEST, SOUTH RM 221	0	0	0
HP265-02-06	02	TEXTURED CEILING MATERIAL	11/8/2006	1ST FL WEST, SOUTH RM 119	0	0	0
HP265-02-10	02	TEXTURED CEILING MATERIAL	7/9/2009	1ST FL WEST, NW RM	0	0	0
HP265-02-11	02	TEXTURED CEILING MATERIAL	7/9/2009	2ND FL EAST, NW RM	0	0	0
HP265-02-12	02	TEXTURED CEILING MATERIAL	7/9/2009	3RD FL WEST, NE RM	0	0	0
HP265-03-01	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	1ST FL WEST, NORTH RM 122	2	0	0
HP265-03-01tem	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	1ST FL WEST, NORTH RM 122	1.21	0	0

Sample	HA	Description	Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-03-02	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	2ND FL WEST, NORTH RM 218	2	0	0
HP265-03-03	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	3RD FL WEST, NORTH RM 328	0	0	0
HP265-03-04	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	3RD FL EAST, SOUTH RM 303	5	0	0
HP265-03-05	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	2ND FL WEST, SOUTH RM 221	0	0	0
HP265-03-06	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	11/8/2006	1ST FL CNTR LOUNGE	3	0	0
HP265-03-10	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	1ST FL CNTR LOUNGE	2	0	0
HP265-03-11	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	1ST FL WEST, NW RM	.1	.1	.1
HP265-03-12	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	1ST FL EAST, SE RM	0	0	0
HP265-03-13	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	2ND FL EAST, NW RM	2	0	0
HP265-03-14	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	2ND FL WEST, SE RM	2	0	0
HP265-03-15	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	3RD FL WEST, NE RM	0	0	0
HP265-03-16	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	7/9/2009	3RD FL EAST, SE RM	2	0	0
HP265-03-17tem	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	12/15/2009	1ST FL WEST, NE RM	0	0	0
HP265-03-18tem	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	12/15/2009	2ND FL EAST, NW RM 216	2.58	0	0
HP265-03-19tem	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE	12/15/2009	3RD FL WEST, SW RM 331	4.6	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-03-20	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE		8/26/2011	1ST FL EAST, NW RM110	5	0	0
HP265-03-20tem	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE		8/26/2011	1ST FL EAST, NW RM110	0	0	0
HP265-03-21	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE		8/26/2011	2ND FL WEST, SW RM227	5	0	0
HP265-03-22	03	12" TAN w/BROWN FLOOR TILE AND ADHESIVE		8/26/2011	3RD FL EAST, NW RM316	5	0	0
HP265-04-01	04	ADHESIVE	4" VINYL BASE	11/8/2006	3RD FL WEST, NORTH RM 328	0	0	0
HP265-04-02	04	ADHESIVE	4" VINYL BASE	11/8/2006	3RD FL EAST, SOUTH RM 303	0	0	0
HP265-04-3810	04	ADHESIVE	4" VINYL BASE	7/9/2009	2ND FL WEST, SOUTH CNTR RM	0	0	0
HP265-05-01	05	EXTERIOR CAULKING,	GRAY	11/8/2006	1ST FL SOUTH CNTR LAUNDRY	0	0	0
HP265-06-01	06	EXTERIOR CAULKING,	GRAY/ WHITE	11/8/2006	1ST FL SOUTH CNTR	0	0	0
HP265-06-3410	06	EXTERIOR CAULKING,	GRAY/ WHITE	7/9/2009	1ST FL SOUTH CNTR, BOTTOM	0	0	0
HP265-06-3411	06	EXTERIOR CAULKING,	GRAY/ WHITE	7/9/2009	3RD FL NORTH CNTR	0	0	0
HP265-06-3510	06	EXTERIOR CAULKING,	GRAY/ WHITE	7/9/2009	1ST FL SOUTH CNTR, TOP	0	0	0
HP265-06-3511	06	EXTERIOR CAULKING,	GRAY/ WHITE	7/9/2009	3RD FL NORTH CNTR	0	0	0
HP265-07-01	07	EXTERIOR CAULKING,	WHITE	11/8/2006	1ST FL WEST, SOUTH RM WINDOW	0	0	0
HP265-07-02	07	EXTERIOR CAULKING,	WHITE	11/8/2006	2ND FL EAST, NORTH RM DOOR	0	0	0
HP265-07-10	07	EXTERIOR CAULKING,	WHITE	7/9/2009	1ST FL WEST, NW RM DOOR	0	0	0
HP265-07-11	07	EXTERIOR CAULKING,	WHITE	7/9/2009	2ND FL EAST, NW RM DOOR	0	0	0
HP265-07-3512	07	EXTERIOR CAULKING,	WHITE	7/9/2009	3RD FL WEST, NE RM DOOR	0	0	0
HP265-08-01	08	12" BEIGE w/BROWN FLOOR TILE AND ADHESIVE		11/8/2006	1ST FL CNTR LOUNGE	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-08-01tem	08	12" BEIGE w/BROWN FLOOR TILE AND ADHESIVE		11/8/2006	1ST FL CNTR LOUNGE	0	0	0
HP265-09-01	09	12" OLIVE FLOOR TILE AND ADHESIVE		11/8/2006	1ST FL CNTR HALL	4	0	0
HP265-09-01tem	09	12" OLIVE FLOOR TILE AND ADHESIVE		11/8/2006	1ST FL CNTR HALL	0	0	0
HP265-10-01	10	12" BLACK w/ WHITE FLOOR TILE AND ADHESIVE		11/8/2006	1ST FL CNTR LOUNGE CLOSET	0	0	0
HP265-10-10	10	12" BLACK w/ WHITE FLOOR TILE AND ADHESIVE		7/9/2009	1ST FL CNTR LOUNGE	0	0	0
HP265-11-01	11	12" WHITE FLOOR TILE AND ADHESIVE	W/BBLUE	11/8/2006	1ST FL CNTR LOUNGE CLOSET	0	0	0
HP265-11-10	11	12" WHITE FLOOR TILE AND ADHESIVE	W/BBLUE	7/9/2009	1ST FL CNTR LOUNGE	0	0	0
HP265-11-11	11	12" WHITE FLOOR TILE AND ADHESIVE	W/BBLUE	12/15/2009	EXTERIOR NORTH CNTR DEBRIS	3	0	0
HP265-11-11tem	11	12" WHITE FLOOR TILE AND ADHESIVE	W/BBLUE	12/15/2009	EXTERIOR NORTH CNTR DEBRIS	0	0	0
HP265-12-01	12	2'x2' CEILING TILE,	PINHOLES	11/8/2006	1ST FL CNTR LOUNGE	0	0	0
HP265-12-02	12	2'x2' CEILING TILE,	PINHOLES	11/8/2006	1ST FL CNTR LOUNGE	0	0	0
HP265-13-01	13	PIPE INSULATION SEALANT	TAN	11/8/2006	1ST FL SOUTH CNTR LAUNDRY	0	0	0
HP265-13-3010	13	PIPE INSULATION SEALANT	TAN	7/7/2009	1ST FL WEST CHASE, EAST END	0	0	0
HP265-14-01	14	FIBERGLASS INSULATION SEALANT	WHITE	11/8/2006	1ST FL WEST CHASE, EAST	0	0	0
HP265-14-02	14	FIBERGLASS INSULATION SEALANT	WHITE	11/8/2006	1ST FL EAST CHASE, EAST	0	0	0
HP265-14-3210	14	FIBERGLASS INSULATION SEALANT	WHITE	7/9/2009	1ST FL EAST CHASE, WEST END	0	0	0
HP265-15-01	15	RESIDUAL MASTIC	BLACK	11/8/2006	2ND FL CNTR LOUNGE	8	0	0
HP265-15-02	15	RESIDUAL MASTIC	BLACK	11/8/2006	2ND FL CNTR LOUNGE	6	0	0
HP265-16-01	16	INTERIOR CAULKING,	GRAY	11/8/2006	2ND FL HALL, SOUTH DOOR	0	0	0
HP265-17-01	17	EXTERIOR CAULKING,	GRAY	11/8/2006	2ND FL SOUTH STAIRS	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-18-01	18	DUCT SEALANT, RED		11/8/2006	3RD FL EAST CHASE, EAST	0	0	0
HP265-19-00ri08	19	ROOF FLASHING/SEALER MATERIAL	BLACK	7/9/2009	(UNDER LAYERS) N/A	9	9	9
HP265-19-00ri11	19	ROOF FLASHING/SEALER MATERIAL	BLACK	8/26/2011	N/A	9	9	9
HP265-19-00ri13	19	ROOF FLASHING/SEALER MATERIAL	BLACK	4/15/2014	N/A	9	9	9
HP265-19-00ri16	19	ROOF FLASHING/SEALER MATERIAL	BLACK	8/17/2016	N/A	9	9	9
HP265-19-00ri19	19	ROOF FLASHING/SEALER MATERIAL	BLACK	12/10/2019	N/A	9	9	9
HP265-19-00ri23	19	ROOF FLASHING/SEALER MATERIAL	BLACK	6/8/2023	N/A	9	9	9
HP265-19-01	19	ROOF FLASHING/SEALER MATERIAL	BLACK	11/8/2006	ROOF, EAST CNTR	15	0	0
HP265-19-02	19	ROOF FLASHING/SEALER MATERIAL	BLACK	11/8/2006	ROOF, WEST CNTR	10	0	0
HP265-19-4110	19	ROOF FLASHING/SEALER MATERIAL	BLACK	7/9/2009	ROOF, WEST CNTR TOP LAYER	0	0	0
HP265-19-4111	19	ROOF FLASHING/SEALER MATERIAL	BLACK	7/9/2009	ROOF, EAST CNTR TOP LAYER	0	0	0
HP265-20-00ri08	20	ROOFING SEALANT, GRAY	GRAY	7/9/2009	N/A	9	9	9
HP265-20-00ri11	20	ROOFING SEALANT, GRAY	GRAY	8/26/2011	N/A	9	9	9
HP265-20-00ri13	20	ROOFING SEALANT, GRAY	GRAY	4/15/2014	N/A	9	9	9
HP265-20-00ri16	20	ROOFING SEALANT, GRAY	GRAY	8/17/2016	N/A	9	9	9
HP265-20-00ri19	20	ROOFING SEALANT, GRAY	GRAY	12/10/2019	N/A	9	9	9
HP265-20-00ri23	20	ROOFING SEALANT, GRAY	GRAY	6/8/2023	N/A	9	9	9

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-20-01	20	ROOFING SEALANT, GRAY	GRAY	11/8/2006	FLAT ROOF, WEST	18	0	0
HP265-20-02	20	ROOFING SEALANT, GRAY	GRAY	11/8/2006	FLAT ROOF, NORTH	18	0	0
HP265-21-00ri08	21	ROOFING MATERIAL, TAR	TAR	7/9/2009	PATCH, N/A	9	9	9
HP265-21-00ri11	21	ROOFING MATERIAL, TAR	TAR	8/26/2011	N/A	9	9	9
HP265-21-01	21	ROOFING MATERIAL, TAR	TAR	11/8/2006	ROOF, SE CORNER PATCH	4	0	0
HP265-21-02	21	ROOFING MATERIAL, TAR	TAR	11/8/2006	ROOF, SOUTH CNTR TOP	0	0	0
HP265-21-03	21	ROOFING MATERIAL, TAR	TAR	11/8/2006	ROOF, NW CORNER TOP	0	0	0
HP265-21-4010	21	ROOFING MATERIAL, TAR	TAR	7/9/2009	ROOF, EAST CNTR TOP TAR	0	0	0
HP265-21-4011	21	ROOFING MATERIAL, TAR	TAR	7/9/2009	ROOF, SW CORNER TOP TAR	0	0	0
HP265-22-01	22	ROOFING MATERIAL, FELTS	FELTS	11/8/2006	ROOF, CNTR VENT	0	0	0
HP265-22-3910	22	ROOFING MATERIAL, FELTS	FELTS	7/9/2009	ROOF, NE CORNER	0	0	0
HP265-22-3911	22	ROOFING MATERIAL, FELTS	FELTS	7/9/2009	ROOF, NW SIDE	0	0	0
HP265-23-01	23	DUCT SEALANT, TAN		11/8/2006	2ND FL EAST MECH RM	0	0	0
HP265-31-10	31	CLOTH LAGGING MATERIAL	w/SEALANT	7/9/2009	1ST FL WEST CHASE, EAST END	0	0	0
HP265-33-10	33	INTERIOR CAULKING, WHITE	WHITE	7/9/2009	1ST FL WEST, NW RM SINK	0	0	0
HP265-33-11	33	INTERIOR CAULKING, WHITE	WHITE	7/9/2009	1ST FL WEST, NW RM DOOR	0	0	0
HP265-33-12	33	INTERIOR CAULKING, WHITE	WHITE	7/9/2009	2ND FL EAST, NW RM DOOR	0	0	0
HP265-33-13	33	INTERIOR CAULKING, WHITE	WHITE	7/9/2009	3RD FL WEST, NE RM DOOR	0	0	0
HP265-33-14	33	INTERIOR CAULKING, WHITE	WHITE	7/9/2009	3RD FL EAST, SE RM SINK	0	0	0
HP265-33-20	33	INTERIOR CAULKING, WHITE	WHITE	8/26/2011	1ST FL EAST, NW RM110 SHOWER	0	0	0
HP265-33-21	33	INTERIOR CAULKING, WHITE	WHITE	8/26/2011	2ND FL WEST, SW RM227 HEAD	0	0	0
HP265-33-22	33	INTERIOR CAULKING, WHITE	WHITE	8/26/2011	3RD FL EAST, NW RM316 SHOWER	0	0	0
HP265-33-23	33	INTERIOR CAULKING, WHITE	WHITE	8/26/2011	3RD FL CNTR LOUNGE WALL/ DOOR	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
HP265-36-10	36	WINDOW GLAZING MATERIAL	BLACK	7/9/2009	2ND FL CNTR LOUNGE DOOR	0	0	0
HP265-36-11	36	WINDOW GLAZING MATERIAL	BLACK	7/9/2009	3RD FL CNTR LAUNDRY DOOR	0	0	0
HP265-37-10	37	VINYL THRESHOLD MATERIAL	1" BROWN	7/9/2009	2ND FL CNTR LAUNDRY	0	0	0
HP265-42-10	42	MEMBRANE-TYPE ROOFING	DEBRIS	7/9/2009	ROOF, SOUTH CNTR	0	0	0
HP265-43-10	43	ROOFING SEALANT, BLACK		7/9/2009	ROOF, SW BUCKET LID	0	0	0
HP265-44-10	44	TRANSITE PANEL MATERIAL	GRAY	7/9/2009	EXT. EAST CNTR GROUND	10	0	0
HP265-45-60	45	ROOFING MATERIAL,	MEMBRANE TAR	12/10/2019	ROOF, CENTER	0	0	0
HP265-45-70	45	ROOFING MATERIAL,	MEMBRANE TAR	6/8/2023	ROOF, CNTR EAST AT VENT	0	0	0
HP265-50-20	50	PITCH POCKET TAR	BLACK	8/26/2011	ROOF, CNTR WEST	0	0	0
HP265-50-21	50	PITCH POCKET TAR	BLACK	8/26/2011	ROOF, WEST CNTR END	0	0	0
HP265-50-22	50	PITCH POCKET TAR	BLACK	8/26/2011	ROOF, WEST CNTR SOUTH	0	0	0
HP265-51-20	51	BUILT-UP ROOFING	BLACK	8/26/2011	ROOF, SW	0	0	0
HP265-51-21	51	BUILT-UP ROOFING	BLACK	8/26/2011	ROOF, CNTR	0	0	0
HP265-51-22	51	BUILT-UP ROOFING	BLACK	8/26/2011	EAST CNTR	0	0	0