

---

## Department of the Air Force: Justification for Other Than Full and Open Competition

---

**Dollar Value of this Acquisition:**    ☒ ≤ \$10M    ☐ > \$10M and ≤ \$100M    ☐ > \$100M and ≤ \$500M    ☐ > \$500M

**CERTIFICATIONS:** CO certification serves as J&A approval ≤ \$10M, *See [J&A Template Guidance](https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory) at <https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory>* J&A Template Guidance tab

|                           |                                                                                                                                                                                                                                                  |                                                                                                  |
|---------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|
| Date<br><br>20 March 2026 | Contracting Officer (RFO 6.104-1(12))<br>KADE N. FORRESTER, 2d Lt, USAF<br><br>I certify that this justification is accurate and complete to the best of my knowledge and belief.                                                                | Signature<br> |
| Date<br><br>20 March 2026 | Technical and Requirements Personnel (RFO 6.104(b))<br><br><br>I certify that the supporting data herein, which is my responsibility, is accurate and complete. | Signature<br>  |

---

### COORDINATION

---

### APPROVALS ( RFO 6.104-2(a) Table 6-1 & R-DFARS 206.104-72 Table 206.1)

See [J&A Template Guidance](https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory) (<https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory>) - Justification Approvals tab

**NOTE 1:** A signature block will appear here (replacing these notes) based on the "Dollar Value of this Acquisition" selected above. Since most digital signatures that include date/time-stamps are redacted before they are made publicly available, always insert the date in the "Date" cell when affixing a digital signature to this document.

---

## Department of the Air Force: Justification for Other Than Full and Open Competition

---

### I. Agency and Contracting Activity (RFO 6.104-1(a)(1)):

Agency: PACAF

Contracting Activity: 35th Contracting Squadron, Misaw AB Japan

### II. Nature and/or description of the action being approved (RFO 6.104-1(a)(2)):

Sole Source Award. This document approves the award of FFP contract on a sole source basis to Vertiv Corporation for provision of Libert Computer Room Air Condition (CRAC) Parts. This justification is made on an Individual basis.

### III. Description of supplies/services required to meet agency needs (RFO 6.104-1(a)(3)):

The requirement is for the procurement of replacement parts for four (4) Liebert CRAC units, model number DS105ASJ1EI0575, currently installed in an undisclosed location. These are CRAC units that monitors and maintains the temperature, air distribution and humidity in the computer rooms. Desired outcome is four fully operational computer room A/C units that procure 60-tons of cooling in total, 15-tons per unit. Existing CRAC units were made by Libert Corporation and were installed over ten (10) years ago, and they are reaching end of life. If not replaced, the secured facility will lose its function as Mission Training Center which would have significant mission impact on its base mission capability.

The USG found that the below parts are needed for organic replacement:

|     |                                             |    |     |
|-----|---------------------------------------------|----|-----|
| 1.  | Refrigeration compressor ZR190              | EA | 2   |
| 2.  | Compressor Contactors 23B0003N001           | EA | 2   |
| 3.  | Filter Dryer 305-ODF                        | EA | 4   |
| 4.  | Liquid Line Solenoid Valve LI2324HGP        | EA | 2   |
| 5.  | Sight Glass INDICATOR LIQ 5/80 X 5/8 ODF    | EA | 2   |
| 6.  | Expansion Valve VLV EXP 5/8X1-1/8X1/40DF    | EA | 2   |
| 7.  | Rotor Lock Valve 998-0510 1-1/4 w/Gasket    | EA | 2   |
| 8.  | Rotor Lock Valve 998-0510 1-3/4 w/Gasket    | EA | 2   |
| 9.  | Compressor Gasket Copeland                  | EA | 2   |
| 10. | Humidifier Unit HU650                       | EA | 4   |
| 11. | Copper Tube 1-1/4                           | LF | 100 |
| 12. | Copper Tube Fitting 90° Elbows 1-1/4        | EA | 50  |
| 13. | Supply Air Fan SAF650                       | EA | 6   |
| 14. | Magnetic Contactor AF09-AF12                | EA | 19  |
| 15. | Crank Case Heater 40W-400W                  | EA | 4   |
| 16. | Control Circuit Board for Heater 40W-400W   | EA | 4   |
| 17. | Condenser Fan Motor 1-Speed, 1-Phase        | EA | 6   |
| 18. | Magnetic Contactor for Above 208V 50/60hz   | EA | 6   |
| 19. | Variable Speed ECM Condenser Fan Motors     | EA | 3   |
| 20. | Motor Speed Controller for Above 1C25447P2  | EA | 3   |
| 21. | Condenser Fan Blades 5 Blade                | EA | 9   |
| 22. | Voltage Transformer - Condenser 208V to 24V | EA | 3   |
| 23. | New Refrigerant Gas R-407c                  | EA | 10  |
| 24. | SUNISO Compressor Oil Refrigeration         | EA | 10  |
| 25. | DS High-Precision Pressure Sensor 1124OP    | EA | 2   |
| 26. | DS Low-Precision Pressure Sensor 2234OI     | EA | 2   |
| 27. | DCDF Ambient Stat 12894                     | EA | 4   |
| 28. | DS Control Board Multi-channel D/A          | EA | 4   |
| 29. | DS Indoor Unit Control Transformer          | EA | 1   |
| 30. | DS Indoor Unit Isolation Transformer        | EA | 1   |

---

## Department of the Air Force: Justification for Other Than Full and Open Competition

---

### IV. Statutory Authority Permitting Other Than Full and Open Competition (RFO 6.104-1(a)(4)):

10 U.S.C. 3204(a)(1), Only one responsible source and no other supplies or services will satisfy agency requirements.

### V. Rationale for Use of Authority (RFO 6.104-1(a)(5)):

This requirement will be executed IAW 41 U.S.C. 1901 for a Sole Source acquisition of commercial supplies using Simplified Acquisition Procedures. The CRAC units are failing to critical measures causing mission degradation. The existing units were made by Liebert Corporation, which was acquired by Emerson electric. Emerson Electric then became Vertiv Corporation as of 2016. Due the age of this system not all parts on the needed parts list are accessible by all vendors. some of the parts such as the needed transformers are only made by and available from Virtiv directly. Market research shows that no other vendor is able to manufacture a suitable substitute for these older CRAC unit models. RFIs posted and communication with known suppliers showed that only Vertiv can supply all parts while maintaining needed security protocol. Responders to the prior project were from non-US vendors who failed to demonstrate ability to meet security requirements and ability to provide the specified Vertiv parts.

Due to the criticality of security requirements, only US-made end products can be installed in the facility. Additionally, all materials shall be in possession of a US citizen at all times during the duration of performance to include shipping. As such, this requirement must be handled by a US company to ensure no facility accreditation issues.

### VI. Integrated Market Analysis and Efforts to Solicit Competition (RFO 6.104-1(a)(6), (8), and (10)):

The USG conducted one-on-one communication with interested vendors, posted RFI, and solicited for a similar requirement in the past. All of these found that Vertiv is the only vendor capable of maintaining security requirements and the needed assets. Below is a synopsis of responses received:

| Company                      | US Company | Demonstrated ability to provide assets |
|------------------------------|------------|----------------------------------------|
| American Engineering Company | No         | No....No quote received                |
| Northern Flowers Company     | No         | No                                     |
| Sky Qatar Company            | No         | No                                     |
| Naqa Al Kawthar Company      | No         | No                                     |
| Sultan Erbil Company 2       | No         | No                                     |
| Sultan Erbil Company 1       | No         | No                                     |
| Al-Masa Al-Hamraa Company    | No         | No                                     |
| Wafaa Al-Alam Company        | No         | No                                     |

As shown above, market research found that Vertiv is the sole manufacturer for all the parts and able to meet security requirements.

### VII. Determination of Fair and Reasonable Cost (RFO 6.104-1(a)(7)):

The Contracting Officer is responsible for evaluating, determining, and documenting the anticipated contract cost/price is fair and reasonable in accordance with RFO Subpart 15.4, Contract Pricing.

### VIII. Any Other Facts Supporting the Justification (RFO 6.104-1(a)(9)):

The USG anticipates a fair and reasonable price based on prior estimates form Vertiv, and other estimates received from



---

## Department of the Air Force: Justification for Other Than Full and Open Competition

---

vendors for similar products that do not meet the needs of this requirement.

### **IX. Actions to Overcome Barriers to Competition (RFO 6.104-1(a)(11):**

*The USG is researching the replacement of the outdated CRAC units in the coming future. The replacement would remove this restriction to only Vertiv and fall in-line with current AFCEC approaches to maintaining CRAC units across the enterprise.*