

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES		
2. AMENDMENT/MODIFICATION NUMBER			3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER <i>(If applicable)</i>	
6. ISSUED BY CODE					7. ADMINISTERED BY <i>(If other than Item 6)</i> CODE			
8. NAME AND ADDRESS OF CONTRACTOR <i>(Number, street, county, State and ZIP Code)</i>					(X)		9A. AMENDMENT OF SOLICITATION NUMBER	
					☐		9B. DATED <i>(SEE ITEM 11)</i>	
					☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
					☐		10B. DATED <i>(SEE ITEM 13)</i>	
CODE			FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation data, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>		16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
<i>(Signature of person authorized to sign)</i>		<i>(Signature of Contracting Officer)</i>	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section 00 00 00 - Procurement and Contracting Requirements

The following changes have been made:

INFORMATION	FROM	TO
Response Due Date	28 Apr 2026	20 May 2026

Section 00 30 00 - Available Information

Miscellaneous text in this section has been added to:

The purpose of this amendment is to incorporate the following:

1. Extend proposal due date to 20 May 2026 NLT 2:00 PM EDT
2. Provide Class Justification & Approval (CJ&A) ML-25-03 FRCS Cherry Point for Johnson Controls
3. Revised Drawings for P995 (attached separately)
4. Revised Specifications for P995 (attached separately)
5. Additional Pre-Proposal Inquiry (PPI) responses (attached separately)

-
1. **Proposal due date has been extended from 28 April 2026 to 20 May 2026 NLT 2:00 P.M. EDT.**

-
2. **Provide Class Justification & Approval (CJ&A) ML-25-03 FRCS Cherry Point for Johnson Controls**
(ATTACHED SEPARATELY)

-
3. **REVISED DRAWINGS FOR P995:**
(ATTACHED SEPARATELY)

(P995) DWG A-104 - FLOOR PLAN - AREA C

Revised opening size for the 'Knockout Panel' for the Large Autoclave

(P995) DWG A-201 - EXTERIOR ELEVATIONS

Revised opening size for the 'Knockout Panel' for the Large Autoclave

(P995) DWG A-401 - ENLARGED RESTROOM PLANS AND DETAILS

Plan A4/A-401 for clarifications on shower and chase wall type

(P995) DWG A-403 - ENLARGED RESTROOM PLANS AND ELEVATIONS

Clarifications on shower and chase wall type

(P995) DWG A-404 - ENLARGED RESTROOM ELEVATIONS AND SHOWER DETAILS

For revised shower wall detailing

(P995) DWG A-501 - WALL TYPE DETAILS

Revised "WALL TYPE B" and "WALL TYPE C" (revised stud size to deck)

(P995) DWG A-502 - WALL TYPE DETAILS

Revised WALL TYPE D", "WALL TYPE F" and "WALL TYPE G" (revised stud overhead bracing)

Revised "WALL TYPE H", "WALL TYPE J" (revised furring wall anchorage).

(P995) DWG A-503 - WALL TYPE DETAILS

Revised "WALL TYPE L" (revised furring wall anchorage).

(P995) DWG I-601 - SCHEDULES & LEGENDS

Revised ROOM FINISH SCHEDULE

(P995) DWG I-602 - SCHEDULES & LEGENDS

Revised FINISH LEGEND

(P995) DWG M-502 - MECHANICAL DETAILS

Omit Detail A1 (sheet not revised)

4. REVISED P995 SPECIFICATIONS:

(ATTACHED SEPARATELY)

(P995) SECTION 07 61 14.00 20 CP STEEL STANDING SEAM ROOFING

Revise the last sentence of paragraph 1.7 Warranty to read "In addition, provide a 5 year general contractor bonded weathertightness warranty covering labor costs for roofing system damages caused by winds having a velocity of 139 mph or less during the applicable warranty period"

(P995) SECTION 12 24 13 ROLLER WINDOW SHADES

Replace entire section.

Change made to paragraph 2.1.2.1 Chain and Clutch Operating Mechanisms. Paragraph 2.1.3.2 Bead Chains has been added.

(P995) SECTION 22 00 00 PLUMBING, GENERAL PURPOSE

In paragraph 2.1 Materials add the following sentence to the end of the paragraph: "High Pressure and Low Pressure Vacuum piping systems must be 304 stainless steel that meets ASTM A269/A269M or ASTM A312/A312M standards."

(P995) SECTION 23 64 26 CHILLED-HOT WATER PIPING SYSTEMS

Add the following to the end of paragraph 2.2.1 Pipe: "Above ground piping 4 inch and smaller must be Type L copper."

(P995) SECTION 25 05 11.01 CYBERSECURITY FOR FA/MNS FACILITY-RELATED CONTROL SYSTEM

This a new section to add to the project. Addition to submittal register for this section is located at the end of the PDF.

(P995) SECTION 41 22 23.19 MONORAIL HOISTS

In Paragraph 1.3.1.1 General, revise Nominal length to be 419 feet

(P995) SECTION 45 52 00 AEROSPACE X-RAY TESTING EQUIPMENT

Replace entire section

Revision and additions made to paragraph 3.4 AEROSPACE X-RAY TESTING EQUIPMENT SCHEDULE, XTE-1 Aerospace X-ray Testing Equipment

5. PRE-PROPOSAL INQUIRY RESPONSES:

(ATTACHED SEPARATELY)

Section 00 73 00 - Supplementary Conditions

The following attachments were added:

Amendment 0004 Pre-Proposal Inquiry Responses