

SECTION 08 71 00

DOOR HARDWARE
02/16, CHG 4: 02/22

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM E283 (2019) Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION (BHMA)

ANSI/BHMA A156.1 (2021) Butts and Hinges
ANSI/BHMA A156.2 (2022) Bored and Preassembled Locks and Latches
ANSI/BHMA A156.3 (2020) Exit Devices
ANSI/BHMA A156.4 (2013) Door Controls - Closers
ANSI/BHMA A156.5 (2020) Cylinder and Input Devices for Locks
ANSI/BHMA A156.6 (2021) Architectural Door Trim
ANSI/BHMA A156.7 (2016) Template Hinge Dimensions
ANSI/BHMA A156.8 (2021) Door Controls - Overhead Stops and Holders
ANSI/BHMA A156.13 (2022) Mortise Locks & Latches Series 1000
ANSI/BHMA A156.16 (2023) Auxiliary Hardware
ANSI/BHMA A156.18 (2020) Materials and Finishes
ANSI/BHMA A156.21 (2019) Thresholds
ANSI/BHMA A156.22 (2021) Gasketing
ANSI/BHMA A156.36 (2010) Auxiliary Locks

STEEL DOOR INSTITUTE (SDI/DOOR)

SDI/DOOR A250.8 (2023) Specifications for Standard Steel Doors and Frames

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

36 CFR 1191

Americans with Disabilities Act (ADA)
Accessibility Guidelines for Buildings and
Facilities; Architectural Barriers Act
(ABA) Accessibility Guidelines

1.2 SUBMITTALS

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Manufacturer's Detail Drawings; G

Verification of Existing Conditions; G

Hardware Schedule; G

Keying System; G

SD-03 Product Data

Hardware Items; G

SD-08 Manufacturer's Instructions

Installation

SD-10 Operation and Maintenance Data

Hardware Schedule Items, Data Package 1; G

SD-11 Closeout Submittals

Key Bitting

1.3 SHOP DRAWINGS

Submit manufacturer's detail drawings indicating all hardware assembly components and interface with adjacent construction. Base shop drawings on verified field measurements and include verification of existing conditions.

1.4 PRODUCT DATA

Provide documentation of ABA/ADA accessibility compliance of applicable components, as required by 36 CFR 1191 Appendix D - Technical.

1.5 HARDWARE SCHEDULE

Provide Hardware Item List and Hardware Schedule containing the following information, and additional information as needed to identify the complete make up of each hardware set and its application to each opening:

1.5.1 Hardware Item List:

- a. Hardware Type
- b. Item Number
- c. Quantity
- d. Size(s)
- e. Reference Publication / Type Number
- f. Manufacturer's Name / Catalog Number
- g. Key Control Symbols
- h. UL Mark (If fire rated and listed)
- i. BHMA Finish(es)
- j. Remarks

1.5.2 Hardware Schedule

- a. Hardware Set Number
- b. Opening Number(s)
- c. Opening Description (single/double leaf, hand, size, door/frame material)
- d. Fire Rating
- e. Sound Rating
- f. Hardware Items
- g. Quantity
- h. Size
- i. BHMA Finish
- j. Remarks

In addition, submit hardware schedule data package 1 in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA.

1.6 KEY BITTING CHART REQUIREMENTS

1.6.1 Requirements

Submit **key bitting** charts to the Contracting Officer prior to completion of the work. Include:

- a. Complete listing of all keys (e.g. AA1 and AA2).
- b. Complete listing of all key cuts (AA1-123456, AA2-123458).

- c. Tabulation showing which key fits which door.
- d. Copy of floor plan showing doors and door numbers.
- e. Listing of 20 percent more key cuts than are presently required in each master system.

1.7 QUALITY ASSURANCE

1.7.1 Hardware Manufacturers and Modifications

Provide, as far as feasible, locks, hinges and closers of one lock, hinge or closer manufacturer's make. Modify hardware as necessary to provide features indicated or specified.

1.7.2 Key Shop Drawings Coordination Meeting

Prior to the submission of the key shop drawing, the Contracting Officer, Contractor, Door Hardware Subcontractor, using Activity and Base Locksmith must meet to discuss and coordinate key requirements for the facility.

Coordinate with the Cherry Point Base Locksmith to resolve keying, procurement, shipping and installation procedures. Confirm keyways utilized and provide compatible cylinders and cores. Confirm hardware set components and functions.

1.8 DELIVERY, STORAGE, AND HANDLING

Deliver hardware in original individual containers, complete with necessary appurtenances including fasteners and instructions. Mark each individual container with item number as shown on hardware schedule. Deliver permanent keys and removable cores to the Contracting Officer, either directly or by certified mail. Deliver construction master keys with the locks.

PART 2 PRODUCTS

2.1 TEMPLATE HARDWARE

Hardware applied to doors must be manufactured using a template. Provide templates to door and frame manufacturers in accordance with ANSI/BHMA A156.7 for template hinges. Coordinate hardware items to prevent interference with other hardware.

2.2 HARDWARE ITEMS

Clearly and permanently mark with the manufacturer's name or trademark, hinges, locks, latches, exit devices, bolts and closers where the identifying mark is visible after the item is installed. For closers with covers, the name or trademark may be beneath the cover.

2.2.1 Hinges

Provide in accordance with ANSI/BHMA A156.1. Provide hinges that are 4-1/2 by 4-1/2 inch unless otherwise indicated. Construct loose pin hinges for interior doors and reverse-bevel exterior doors so that pins are non-removable when door is closed. Other anti-friction bearing hinges may be provided in lieu of ball bearing hinges.

2.2.2 Locks and Latches

- a. At exterior locations provide locksets of full stainless steel type 302 or 304 construction including fronts, strike, escutcheons, knobs, bolts and all interior working parts. Marine Grade I, fully non-ferrous.
- b. In non-air-conditioned interior environments or humid interior environments, provide interior locksets on the same Marine Grade I, fully non-ferrous as exterior locksets.

2.2.2.1 Bored Locks and Latches

Provide in accordance with [ANSI/BHMA A156.2](#), Series 4000, Grade 1.

2.2.2.2 Auxiliary Locks

Provide in accordance with [ANSI/BHMA A156.36](#), Grade 1.

2.2.3 Exit Devices

Provide in accordance with [ANSI/BHMA A156.3](#), Grade 1. Provide adjustable strikes for rim type and vertical rod devices. Provide open back strikes for pairs of doors with mortise and vertical rod devices. Provide touch bars in lieu of conventional crossbars and arms. Provide escutcheons not less than 7 by 2-1/4 inch.

Provide stainless steel exit devices. Also include stainless steel fasteners and screws.

2.2.4 Cylinders and Cores

Provide cylinders and cores for new locks, including locks provided under other sections of this specification. Provide cylinders and cores with seven pin tumblers. Provide cylinders from the products of one manufacturer, and provide cores from the products of one manufacturer. Rim cylinders and levers of bored locksets have interchangeable cores which are removable by special control keys. Stamp each interchangeable core with a key control symbol in a concealed place on the core.

2.2.5 Keying System

Provide an extension of the existing keying system. Provide SFIC Series 7 pin, A Keyway as manufactured by Best, www.bestaccess.com. Provide construction interchangeable cores. Provide key cabinet as specified.

2.2.6 Lock Trim

Provide cast, forged, or heavy wrought construction and commercial plain design for lock trim.

2.2.6.1 Lever Handles

Provide lever handles. Provide in accordance with [ANSI/BHMA A156.3](#) for mortise locks of lever handles for exit devices. Provide lever handle locks with a breakaway feature (such as a weakened spindle or a shear key) to prevent irreparable damage to the lock when force in excess of that specified in [ANSI/BHMA A156.13](#) is applied to the lever handle. Provide lever handles return to within 1/2 inch of the door face.

2.2.7 Keys

Furnish one file key, one duplicate key, and one working key for each key change and for each master keying system. Furnish one additional working key for each lock of each keyed-alike group. Furnish construction master keys, and control keys for removable cores. Furnish a quantity of key blanks equal to 20 percent of the total number of file keys. Stamp each key with appropriate key control symbol and "U.S. property - do not duplicate." Do not place room number on keys.

2.2.8 Door Bolts

Provide in accordance with ANSI/BHMA A156.16. Provide dustproof strikes for bottom bolts, except at doors having metal thresholds.

2.2.9 Closers

Provide in accordance with ANSI/BHMA A156.4, Series C02000, Grade 1, with PT 4C. Provide with brackets, arms, mounting devices, fasteners, full metal covers and other features necessary for the particular application. Size closers in accordance with manufacturer's printed recommendations, or provide multi-size closers, Sizes 1 through 6, and list sizes in the Hardware Schedule. Provide manufacturer's 10 year warranty.

Use stainless steel inside bracketed or door mounted closers on exterior doors. On interior doors use closers of 302 or 304 stainless steel or non-ferrous materials.

2.2.9.1 Identification Marking

Engrave each closer with manufacturer's name or trademark, date of manufacture, and manufacturer's size designation in locations that will be visible after installation.

2.2.10 Overhead Holders

Provide in accordance with ANSI/BHMA A156.8.

2.2.11 Door Protection Plates

Provide in accordance with ANSI/BHMA A156.6.

2.2.11.1 Sizes of Mop and Kick Plates

2 inch less than door width for single doors; 1 inch less than door width for pairs of doors. Provide 8 inch kick plates for flush doors. Provide 4 inch mop plates.

2.2.12 Door Stops and Silencers

Provide in accordance with ANSI/BHMA A156.16. Silencers Type L03011. Provide three silencers for each single door, two for each pair.

2.2.13 Thresholds

Provide in accordance with ANSI/BHMA A156.21. Use J35100, with vinyl or silicone rubber insert in face of stop, for exterior doors opening out, unless specified otherwise.

2.2.14 Weatherstripping Gasketing

Provide in accordance with ANSI/BHMA A156.22. Provide the type and function designation where specified in paragraph HARDWARE SCHEDULE. Provide a set to include head and jamb seals, sweep strips, and, for pairs of doors, astragals. Air leakage of weatherstripped doors not to exceed 1.25 cubic feet per minute of air per square foot of door area when tested in accordance with ASTM E283. Provide weatherstripping with one of the following:

2.2.14.1 Extruded Aluminum Retainers

Extruded aluminum retainers not less than 0.050 inch wall thickness with vinyl, neoprene, silicone rubber, or polyurethane inserts. Provide clear (natural) anodized aluminum.

2.2.14.2 Interlocking Type

Zinc or bronze not less than 0.018 inch thick.

2.2.14.3 Spring Tension Type

Spring bronze or stainless steel not less than 0.008 inch thick.

2.2.15 Rain Drips

Provide in accordance with ANSI/BHMA A156.22. Provide extruded aluminum rain drips, not less than 0.08 inch thick, clear anodized finish. Provide rain drips with a 2 inch overlap on each side of each exterior door that is not protected by an awning, roof, eave or other horizontal projection. Set drips in sealant and fasten with stainless steel screws.

2.2.15.1 Overhead Rain Drips

Approximately 1-1/2 inch high by 2-1/2 inch projection. Align bottom with door frame rabbet.

2.2.16 Auxiliary Hardware (Other than locks)

Provide in accordance with ANSI/BHMA A156.16, Grade 1.

2.2.17 Special Tools

Provide special tools, such as spanner and socket wrenches and dogging keys, as required to service and adjust hardware items.

2.3 FASTENERS

Provide fasteners of type, quality, size, and quantity appropriate to the specific application. Fastener finish to match hardware. Provide stainless steel or nonferrous metal fasteners in locations exposed to weather. Verify metals in contact with one another are compatible and will avoid galvanic corrosion when exposed to weather.

2.4 FINISHES

Provide in accordance with ANSI/BHMA A156.18. Provide hardware in BHMA 630 finish (satin stainless steel), unless specified otherwise. Provide

hinges for exterior doors in stainless steel with BHMA 630 finish. Furnish exit devices in BHMA 630 finish. Match exposed parts of concealed closers to lock and door trim. Match hardware finish for aluminum doors to the doors.

2.5 KEY CABINET AND CONTROL SYSTEM

Provide in accordance with ANSI/BHMA A156.5. Type required to yield a capacity (number of hooks) 50 percent greater than the number of key changes used for door locks.

PART 3 EXECUTION

3.1 INSTALLATION

Provide hardware in accordance with manufacturers' printed installation instructions. Fasten hardware to wood surfaces with full-threaded wood screws or sheet metal screws. Provide machine screws set in expansion shields for fastening hardware to solid concrete and masonry surfaces. Provide toggle bolts where required for fastening to hollow core construction. Provide through bolts where necessary for satisfactory installation.

3.1.1 Weatherstripping Installation

Provide full contact, weathertight seals that allow operation of doors without binding the weatherstripping.

3.1.1.1 Stop Applied Weatherstripping

Fasten in place with color matched sheet metal screws not more than 9 inch on center after doors and frames have been finish painted.

3.1.1.2 Interlocking Type Weatherstripping

Provide interlocking, self adjusting type on heads and jambs and flexible hook type at sills. Nail weatherstripping to door 1 inch on center and to heads and jambs at 4 inch on center.

3.1.1.3 Spring Tension Type Weatherstripping

Provide spring tension type on heads and jambs. Provide bronze nails with bronze. Provide stainless steel nails with stainless steel. Space nails not more than 1-1/2 inch on center.

3.1.2 Threshold Installation

Extend thresholds the full width of the opening and notch end for jamb stops. Set thresholds in a full bed of sealant and anchor to floor with cadmium-plated, countersunk, steel screws in expansion sleeves. For aluminum thresholds placed on top of concrete surfaces, coat the underside surfaces that are in contact with the concrete with fluid applied waterproofing as a separation measure prior to placement.

3.2 HARDWARE LOCATIONS

Provide in accordance with SDI/DOOR A250.8, unless indicated or specified otherwise.

- a. Kick and Armor Plates: Push side of single-acting doors.
- b. Mop Plates: Bottom flush with bottom of door.

3.3 KEY CABINET AND CONTROL SYSTEM

Locate where directed. Tag one set of file keys and one set of duplicate keys. Place other keys in appropriately marked envelopes, or tag each key. Provide complete instructions for setup and use of key control system. On tags and envelopes, indicate door and room numbers or master or grand master key.

3.4 FIELD QUALITY CONTROL

After installation, protect hardware from paint, stains, blemishes, and other damage until acceptance of work. Submit notice of testing 15 days before scheduled, so that testing can be witnessed by the Contracting Officer. Adjust hinges, locks, latches, bolts, holders, closers, and other items to operate properly. Demonstrate that permanent keys operate respective locks, and give keys to the Contracting Officer. Correct, repair, and finish, errors in cutting and fitting and damage to adjoining work.

3.5 HARDWARE SETS

Provide cited hardware items for other doors under this section. Deliver Hardware templates and hardware, except field applied hardware, to the other door and frame manufacturers for their use in fabricating doors and frames.

3.6 HARDWARE SCHEDULE

Location of Hardware Sets	HWS
Section 08 11 16, Aluminum Doors & Frames	1-2
Section 08 33 23, Steel Overhead Coiling Doors	3-4
Section 08 71 00, Door Hardware	5-21
Section 10 22 13, Wire Mesh Partitions	22

BB = Ball Bearing; FMC = Full Metal Cover; LHR = Left Hand Reverse; MIL = Mill Finished Aluminum; NRP = Non Removable Pin; RHR = Right Hand Reverse; SFIC = Small Format Interchangeable Core

HARDWARE SETS

Heavy Duty Exterior Openings

Door No. 129A, 140A, 147A, 148A

HWS-5 Exterior Elec/Mech/Tel Com Pair

	8 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	2 each Overhead Door Holder, C02511	626
	stop mounted slide track arm,	
	push side mount	
Active Leaf RHR		
	1 each Lever Storeroom, F86	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	1 each Brush Astragal	Black
Section 08 11 13	1 each Flat Overlapping Astragal	Galvanealed
Inactive Leaf LHR		
	2 each 12" Lever Ext Flush Bolt, L14251	626

1 each Dust Proof Strike, L04021	626
1 each 100" Drip Ledge	MIL
1 each 8070 Weatherstrip	MIL
2 each 48" Bottom Sweep with Drip	MIL
1 each 96" Threshold, J35100	MIL
2 each Floor Stop, L02131	626

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 141A, 146A

HWS-6 Exterior Elec/Mech/Tel Com

	4 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each Overhead Door Holder, C02511	626
	stop mounted slide track arm,	
	push side mount	
Best	1 each Lever Storeroom, F86	630
	1 each 7 Pin SFIC, F24, E09241	630
	1 each 52" Drip Ledge	MIL
	1 each 4070 Weatherstrip	MIL
	1 each 48" Bottom Sweep with Drip	MIL
	1 each 48" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 144A

HWS-6A Exterior Elec/Mech/Tel Com

	4 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each Overhead Door Holder, C02511	626
	stop mounted slide track arm,	
	push side mount	
Best	1 each Lever Storeroom, F86	630
	1 each 7 Pin SFIC, F24, E09241	630
	1 each 52" Drip Ledge	MIL
	1 each 4070 Weatherstrip	MIL
	1 each 48" Bottom Sweep with Drip	MIL
	1 each 48" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626
GFGI	1 each DPDT Balanced Magnetic Switch	MIL
GFGI	1 each Electric Strike	630
GFGI	2 each Card Reader, Wall Mounted	Black
GFGI	1 each Electric hinge	630

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Note: Furnish electric metallic tubing raceway, cabling, equipment and programming to support connected devices and operate access control components

Note: Furnish electric metallic tubing raceway, pull strings and blank stainless steel coverplates to receive Government furnished and installed devices

Note: Integrate access control equipment with fire alarm equipment. Electric strike fails secure upon fire alarm notification

Note: Access control equipment is located in Comm 117

Door No. 160B

HWS-7 Roof Service Entrance

	3 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each Overhead Door Holder, C02241	626
	track hold and spring stop, stop mounted	
	slide track arm, push side mount	
	1 each Lever Storeroom, F86	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	1 each 40" Drip Ledge	MIL
	1 each 3070 Weatherstrip	MIL
	1 each 36" Bottom Sweep with Drip	MIL
	1 each 36" Threshold, J35100	MIL

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 128A, 152A

HWS-8 Exterior Electrical>800 Amps

	4 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each Overhead Door Holder, C02511	626
	stop mounted slide track arm,	
	push side mount	
	1 each Exit Device w/ Lever, EDF03	630
	Type 4, B x CD, entry by keyed trim,	
	cylinder dogging function	
Best	1 each Rim Cylinder Housing, F26	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	1 each 52" Drip Ledge	MIL
	1 each 4070 Weatherstrip	MIL
	1 each 48" Bottom Sweep with Drip	MIL
	1 each 48" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 125A, 125B, 150A

HWS-9 Exterior Corridor Entrance

	3 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each FMC Closer, C02231 with	630
	spring stop, stop mounted slide track arm	
	push side mount	
	1 each Lever Entry, F109	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	1 each 40" Drip Ledge	MIL
	1 each 3070 Weatherstrip	MIL
	1 each 36" Bottom Sweep with Drip	MIL
	1 each 36" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626
GFGI	1 each DPDT Balanced Magnetic Switch	MIL
GFGI	1 each Electric Strike	630
GFGI	2 each Card Reader, Wall Mounted	Black
GFGI	1 each Electric hinge	630

Note: Furnish electric metallic tubing raceway, cabling, equipment and programming to support connected devices and operate access control components

Note: Furnish electric metallic tubing raceway, pull strings and blank stainless steel coverplates to receive Government furnished and installed devices

*Note: Integrate access control equipment with fire alarm equipment.
Electric strike fails secure upon fire alarm notification*

Note: Access control equipment is located in Comm 117

Door No. 120B, 122A, 127B

HWS-10 Exterior Shop

	3 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each FMC Closer, C02241 with track hold and spring stop, stop mounted slide track arm, push side mount	630
Best	1 each Lever Storeroom, F86	630
	1 each 7 Pin SFIC, F24, E09241	630
	1 each 40" Drip Ledge	MIL
	1 each 3070 Weatherstrip	MIL
	1 each 36" Bottom Sweep with Drip	MIL
	1 each 36" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626
GFGI	1 each DPDT Balanced Magnetic Switch	MIL
GFGI	1 each Electric Strike	630
GFGI	2 each Card Reader, Wall Mounted	Black
GFGI	1 each Electric hinge	630

*Note: Furnish electric metallic tubing raceway, cabling, equipment and
programming to support connected devices and operate access control
components*

*Note: Furnish electric metallic tubing raceway, pull strings and blank
stainless steel coverplates to receive Government furnished and installed
devices*

*Note: Integrate access control equipment with fire alarm equipment.
Electric strike fails secure upon fire alarm notification*

Note: Access control equipment is located in Comm 117

Door No. 131B, 131C, 135B, 136C, 151A, 155B

HWS-10A Exterior Shop

	3 each BB 4.5 x 4.5 Butt Hinge, NRP, A5111	630
	1 each FMC Closer, C02241 with track hold and spring stop, stop mounted slide track arm, push side mount	630
Best	1 each Lever Storeroom, F86	630
	1 each 7 Pin SFIC, F24, E09241	630
	1 each 40" Drip Ledge	MIL
	1 each 3070 Weatherstrip	MIL
	1 each 36" Bottom Sweep with Drip	MIL
	1 each 36" Threshold, J35100	MIL
	1 each Floor Stop, L02131	626
GFGI	1 each DPDT Balanced Magnetic Switch	MIL
GFGI	1 each Electric hinge	630

*Note: Furnish electric metallic tubing raceway, cabling, equipment and
programming to support connected devices and operate access control
components*

*Note: Furnish electric metallic tubing raceway, pull strings and blank
stainless steel coverplates to receive Government furnished and installed*

devices

*Note: Integrate access control equipment with fire alarm equipment.
Electric strike fails secure upon fire alarm notification*

Note: Access control equipment is located in Comm 117

Heavy Duty Non Rated Openings

Door No. 134A, 138A
HWS-11 Storage Pair

	6 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	Active Leaf RHR	
	1 each Lever Storeroom, F86	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	Inactive Leaf LHR	
	2 each 12" Lever Ext Flush Bolt, L14251	626
	1 each Dust Proof Strike, L04021	626
	2 each 8 x 34 Beveled Kick Plate, J102	630
	2 each Silencer, L03011	Grey
	2 each Wall Stop, L02251 or Floor Stop, L02161	626

Door No. 158A, 160A
HWS-12 Elec/Mech/Tel Com

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each Overhead Door Holder, C02511	626
	stop mounted slide track arm, push side mount	
	1 each Lever Storeroom, F86	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or Floor Stop, L02161	626

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 117A
HWS-12A Elec/Mech/Tel Com

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each Overhead Door Holder, C02511	626
	stop mounted slide track arm, push side mount	
	1 each Lever Storeroom, F86	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or Floor Stop, L02161	626
GFGI	1 each DPDT Balanced Magnetic Switch	MIL
GFGI	1 each Electric Strike	630
GFGI	2 each Card Reader, Wall Mounted	Black
GFGI	1 each Electric hinge	630

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Note: Furnish electric metallic tubing raceway, cabling, equipment and programming to support connected devices and operate access control components

Note: Furnish electric metallic tubing raceway, pull strings and blank stainless steel coverplates to receive Government furnished and installed devices

Note: Integrate access control equipment with fire alarm equipment. Electric strike fails secure upon fire alarm notification

Note: Access control equipment is located in Comm 117

Door No. 102A, 104A, 104B, 107A, 107B, 108A, 109A, 110A, 110B, 113A, 113B, 115A

HWS-13 Gang Head, Shower

3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
1 each FMC Closer, C02021	630
1 each Strike Filler Plate	600
1 each 4 x 16 Beveled Push Plate, J301	630
1 each 4 x 16 Beveled Pull Plate, J405	630
1 each 8 x 34 Beveled Kick Plate, J102	630
1 each 4 x 34 Beveled Mop Plate, J103	630
3 each Silencer, L03011	Grey
1 each Wall Stop, L02251 or Floor Stop, L02161	626

Door No. 105A, 112A

HWS-14 Staff Head

3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
1 each FMC Closer, C02021	630
1 each Lever Privacy, F76 no SFIC	630
1 each 8 x 34 Beveled Kick Plate, J102	630
1 each 4 x 34 Beveled Mop Plate, J103	630
3 each Silencer, L03011	Grey
1 each Wall Stop, L02251 or Floor Stop, L02161	626

Door No. 116A

HWS-15 Janitor, Utility

3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
1 each FMC Closer, C02021	630
1 each Lever Storeroom, F86	630
Best 1 each 7 Pin SFIC, F24, E09241	630
1 each 8 x 34 Beveled Kick Plate, J102	630
1 each 4 x 34 Beveled Mop Plate, J103	630
3 each Silencer, L03011	Grey
1 each Wall Stop, L02251 or Floor Stop, L02161	626
1 each Lever Door Holder, L01381	626

Note: Trim is to have an abrasive texture to indicate a potentially hazardous environment to the blind

Door No. 157A

HWS-16 Wellness, Lactation

3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
1 each FMC Closer, C02021	630
1 each Lever Privacy, F76 no SFIC	630
3 each Silencer, L03011	Grey
1 each Wall Stop, L02251 or	626

Floor Stop, L02161

Door No. 120A, 121A, 122B, 127A, 131A, 139A, 153A
HWS-17 Suite, Shop, Training

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each FMC Closer, C02231 with	630
	track hold open, soffit mounted slide	
	track arm, push side mount	
Best	1 each Lever Entry, F109	630
	1 each 7 Pin SFIC, F24, E09241	630
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or	626
	Floor Stop, L02161	

Door No. 135A, 135D, 136A, 155A
HWS-17.1 Clean Spaces

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each FMC Closer, C02231 with	630
	track hold open, soffit mounted slide	
	track arm, push side mount	
Best	1 each Lever Entry, F109	630
	1 each 7 Pin SFIC, F24, E09241	630
	1 each 3070 Weatherstrip	MIL
	1 each Wall Stop, L02251 or	626
	Floor Stop, L02161	

Door No. 167A, 168A, 169A
HWS-18 Suite, Office

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each Lever Entry, F109	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or	626
	Floor Stop, L02161	

Door No. 164A, 164B, 165A
HWS-19 Training, Conference

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each Lever Passage, F75	630
	no SFIC	
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or	626
	Floor Stop, L02161	

Door No. 162A, 162B
HWS-20 Suite, Lounge, Break Room

	3 each BB 4.5 x 4.5 Butt Hinge, A5111	630
	1 each FMC Closer, C02021	630
	1 each Dead Bolt, E0141	630
Best	1 each 7 Pin SFIC, F24, E09241	630
	1 each Strike Filler Plate	600
	1 each 6 inch, Type 7, Back to Back	630
	Pulls, J401	
	2 each 4 x 16 Beveled Push Plate, J301	630
	1 each 8 x 34 Beveled Kick Plate, J102	630
	3 each Silencer, L03011	Grey
	1 each Wall Stop, L02251 or	626
	Floor Stop, L02161	

Door No. 120D, 120E, 120F, 120G
HWS-21 Access Door

2 each BB 4.5 x 4.5 Butt Hinge, A5111	630
1 each Lever Passage, F75 no SFIC	630
2 each Silencer, L03011	Grey
1 each Wall Stop, L02251	626

-- End of Section --