

REQ DOC NO. - 6009V204

ATTACHMENT 1

CONTRACT NO. _____

PAGE

1 OF 1

NAME OF OFFER OR/CONTRACTOR

ITEM #	SUPPLIES/SERVICES	QTY	U/I
1	PUMP	2	EACH

C. DESCRIPTION/SPECIFICATIONS.

C.1. PUMP/MOTOR:

- C.1.1. SEALLESS, LEAK-PROOF CANNED MOTOR, DRY STATOR CAVITY.
- C.1.2. STAINLESS STEEL 300 SERIES PUMP CASE AND ROTOR.
- C.1.3. TEIKOKU/CHEMPUMP, G-SERIES, MANUFACTURER'S P/N GC-3K-3S
- C.1.4. 4-3/4-INCH IMPELLER, NON-WELDED IMPELLER NUT
- C.1.5. EPDM CASING GASKET
- C.1.6. RATED FOR 300 PSIG AT 220F
- C.1.7. 3450 RPM
- C.1.8. 460 VAC

C.2. PUMP CONNECTIONS (INLET/OUTLET):

- C.2.1. CLASS 300 RAISED-FACE FLANGE CONNECTIONS PER ASME B16.5 (A/R).
- C.2.2. 2-INCH SUCTION
- C.2.3. 1.5-INCH DISCHARGE

D. PRESERVATION/PACKAGING/PACKING.

D.1. COMMERCIALY PACKAGED