

The highest quality and security of isolation which is reasonably practicable shall always be used.

Each line connected to the equipment to be isolated shall be assessed using the Isolation Selector Tool (IST).

Do not apply one IST assessment to all lines connected to the equipment being isolated – each line connected to the equipment requires to be assessed in its own right.

[Launch Isolation Selector Tool](#)

For guidance, refer to:

- [Safe Isolation and Reinstatement of Plant Procedure \(TUK-17-C-004\)](#)
- [Control of Work Procedure \(TUK-17-C-001\)](#)

