OB122 - <offline>

"MOD_ERR" Module Access Error

Name: **Family:**
Author: **Version:** 0.1
Block version: 2
Time stamp Code: 04/28/2003 09:18:07 AM
Interface: 02/15/1996 04:51:10 PM
Lengths (block/logic/data): 00112 00002 00020

Name	Data Type	Address	Comment
TEMP		0.0	
OB122_EV_CLASS	Byte	0.0	16#29, Event class 2, Entering event state, Internal fault event
OB122_SW_FLT	Byte	1.0	16#XX Software error code
OB122_PRIORITY	Byte	2.0	Priority of OB Execution
OB122_OB_NUMBR	Byte	3.0	122 (Organization block 122, OB122)
OB122_BLK_TYPE	Byte	4.0	16#88/8C/8E Type of block fault occured in
OB122_MEM_AREA	Byte	5.0	Memory area where access error occured
OB122_MEM_ADDR	Word	6.0	Memory address where access error occured
OB122_BLK_NUM	Word	8.0	Block number in which error occured
OB122_PRG_ADDR	Word	10.0	Program address where error occured
OB122_DATE_TIME	Date_And_Time	12.0	Date and time OB1 started

Block: OB122 "Module Access Error"

Network: 1

