UDT65 - <offline>

"TCON_PAR" Connection Parameters for TCON
Name: TCON_PAR **Family:** COMM
Author: SIMATIC **Version:** 2.1
Block version: 2
Time stamp Code: 05/22/2006 01:28:48 PM
Interface: 05/22/2006 01:28:48 PM
Lengths (block/logic/data): 00000 00000 00000
UNLINKED

Address	Name	Type	Initial value	Comment
0.0		STRUCT		
+0.0	block_length	WORD	W#16#40	Length of the UDT (64 bytes)
+2.0	id	WORD	W#16#0	Reference to this connection (valuerange: W#16#0001 to W#16#FFFF)
+4.0	connection_type	BYTE	B#16#1	B#16#11: TCP/IP native; B#16#12: ISO on TCP; B#16#01: TCP/IP native
+5.0	active_est	BOOL	FALSE	FALSE: passive connection establishment; TRUE: active connection establishment
+6.0	local_device_id	BYTE	B#16#2	Allowed values: B#16#0, B#16#2, B#16#3, B#16#5. See online help.
+7.0	local_tsap_id_len	BYTE	B#16#2	Used length of the parameter local_tsap_id
+8.0	rem_subnet_id_len	BYTE	B#16#0	Unused; must be B#16#00
+9.0	rem_staddr_len	BYTE	B#16#0	Meaning of parameter rem_staddr: B#16#00: is ir relevant; B#16#04: valid address
+10.0	rem_tsap_id_len	BYTE	B#16#0	Used length of the parameter rem_tsap_id
+11.0	next_staddr_len	BYTE	B#16#0	Used length of the parameter next_staddr
+12.0	local_tsap_id	ARRAY[1..16]	B#16#0	Depending on parameter connection_type: local port no. / local TSAP-ID
*1.0		BYTE		
+28.0	rem_subnet_id	ARRAY[1..6]	B#16#0	Unused; must be B#16#00
*1.0		BYTE		
+34.0	rem_staddr	ARRAY[1..6]	B#16#0	IP address of the remote connection end point, e. g. 192.168.0002.0003
*1.0		BYTE		
+40.0	rem_tsap_id	ARRAY[1..16]	B#16#0	Depending on connection type: remote port no. / remote TSAP-ID
*1.0		BYTE		
+56.0	next_staddr	ARRAY[1..6]	B#16#9	Depending on local_device_id: rack / slot no. of the associated CP / irrelevant
*1.0		BYTE		
+62.0	spare	WORD	W#16#0	Unused; must be W#16#0000
=64.0		END_STRUCT		