GENERAL	1	**Tag No.**	**45-PT -92609**		P&ID No.	PH-ME-P-0160-001	
	2	Service	PH 1stStgDiscCool CM Out				
	3	Piping Material / Class	22 CR DUPLEX				
	4	Design Pressure	14 bar -g		Design Temperature		ºC
	5	Certification	ATEX				
	6	Protection	EEx ia		Zone	1	Group IIB
	7	Temperature Class	T3		I.S. / Non-Incendive		IS
	8	Enclosure Rating	IP66				
	9						
	10	Ambient Temp Min	-8.2 ºC		Ambient Temp Max		24.5 ºC
PROCESS CONDITIONS	11	Pressure @ Normal Flow	5 bar gage		Pressure @ Maximum Flow		14 bar gage
	12						
	13						
	14						
UNIT	15	Instrument Range			0 bar	-	55.16 bar g
	16	Calibrated Range			0 bar	-	17 bar g
	17	Output			Linear, with Damping at Mfgr Std		
	18	Body Material	Hastelloy C-276		Element Material		Hastelloy C-276
	19	Process Connection	1/2" FNPT		Body Rating		110.3 bar-g
	20	Output	4-20mA HART		Mounting		Line Mounted
	21	Wetted O-Rings Material	Mfg Std		Electrical Connection		M20
	22	NACE MR0175-2003	Yes		Instrument Power		24 VDC 2-wire
	23	Vents / Drains	No				
	24						
	25						
	26						
	27						
OPTIONS	28	Integral Meter	Yes, LCD		Integral Meter Scale		Same As Calibrated Range
	29	Calibration	Yes		Manifold		N/A
	30	Surge Suppression	No				
	31	Failure Mode	NAMUR High Alarm				
	32	Mounting Bracket	No				
	33						
	34	HART tag / descr	See Note 1				
	35	Write Protect	ON				
	36	Diaphram Seal	No				
	37						
	38						
	39						
	40						
	41						
	42						
	43						
PURCHASE	44	Manufacturer	ROSEMOUNT				
	45	Model	3051TG3A2B31KI1M5Q4Q8QTC1C4TR				

NOTES: See notes

No.	By	Date	Revision	Chk	App
1	AC	7/31/2008	Reissued for Purchase	DP	JB
0	MF	5/14/2008	Issue for Purchase	DP	JB
A	MF	4/8/2008	Issue for ITT	DP	JB

INSTRUMENT SPECIFICATION

Pressure Transmitter PT

bp VALHALL

Sheet 1 of 2

Code: 7161 | Document No.: 45-PT -92609-SP | Rev.: 1

Tag Number : 45-PT -92609

1. See General Notes and PH-ME-I-0251 for additional requirements.
2. Transmitter shall be shipped as a complete and tested assembly.

				INSTRUMENT SPECIFICATION		
1	AC	7/31/2008	Reissued for Purchase	Pressure Transmitter PT		
0	MF	5/14/2008	Issue for Purchase			
A	MF	4/8/2008	Issue for ITT			Sheet 2 of 2
No.	By	Date	Revision	Code: 7161	Dwg. No.: 45-PT -92609-SP	Rev.: 1