GENERAL	1	**Tag No.**	**45-TT -92607A**	P&ID No.	PH-ME-P-0160-001	
	2	Service	PH 1stStgDiscClr CoolMed Out			
	3	Line Number	0600-AD20-3D	Equipment No.	23-HA-9114/9115	
	4	Size / Schedule	6 in 10S			
	5	Protection	EEx ia	Zone	1	Group IIB
	6	Certification	ATEX	I.S. / Non-Incendive	IS	
	7	Design Pressure	14 bar -g	Design Temperature	175 ºC	
	8	Temperature Class	T3			
	9	Enclosure Rating	IP 66			
	10	Ambient Temp Min	-8.2 ºC	Ambient Temp Max	24.5 ºC	

☑ Element
☑ Transmitter
● Flanged Thermowell
○ Screwed Thermowell
○ N/A

A		G	7 mm
B		H	
C		J	
D		T	60 mm
E	1/2" NPT	U	225 mm
F			

Note: T= Manufacture Standard + Lag (if required)

PROCESS CONDITIONS	11	Process Fluid	Heat/Cooling Media	State	Liquid	
	12			Units	Minimum	Normal / Maximum
	13	Pressure		bar-g		5.8
	14	Temperature		ºC		108
	15	Velocity		m/s		
	16	Density		kg/m³		1049
	17	Compressibility Factor				
	18	Viscosity		cP		1.92
	19	Flow Rate	124 Am3/h			
	20	NACE MR0175-2003	Yes	Molecular Weight		
ELEMENT	21	Type	100Ohm Plat 3 Wire RTI	Grounded	No	
	22	Wire Gauge		Single / Double	Double	
	23	Sheath Material	316SS	Spring Loaded	Yes	
	24			RTD model	0065N32J0150N0435I1XA	
HEAD / TRANS-MITTER	25	Enclosure	See General Section	Material	316SS	
	26	Terminal Block	Dual Ceramic	Ground Screw	No	
	27	Extension Type	Nipple/Union/Nipple	Calibrated Range	-10 - 125 ºC	
	28	Output	4-20 mA HART	Linearization	Mfgr Std	
	29	Up / Dn on Burnout Failure	See Model # code	Instrument Power	24 VDC 2-wire	
	30	Nipple/Union/Nipple Material	316SS	Nipple//Union/Nipple Length	See Notes	
	31	Integral Meter	Yes, LCD	Write Protect	OFF	
WELL	32	Process Connection	1.5" ANSI 150 RF	Material	2205 SS	
	33	Construction Type	Flanged - note 1	Wake Frequency Calc	Req'd - See Note 1	
	34					
PURCHASE	35	Manufacturer	ROSEMOUNT			
	36	Model	3144PD6A2I1M5C1A1Q4U2QTXA			

NOTES: See notes

No.	By	Date	Revision	Chk	App
3	AC	1/16/2009	Revised Issue for Purchase	DP	JRB
2	AC	8/5/2008	Revised Issued for Purchase	DP	JRB
1	LS	5/14/2008	Revised Issued for Purchase	DP	JRB
0	LS	3/28/2008	Issued for Purchase	DP	JRB
B	AIC	3/20/2008	Revised for Inquiry	DP	JRB

INSTRUMENT SPECIFICATION

Temperature Transmitter

bp VALHALL

Sheet 1 of 2

Code: 7134 | Document No.: 45-TT -92607A-SP- | Rev.: 3

Tag Number : 45-TT -92607A

1. See General Notes and PH-ME-I-0251 for additional requirements.
2. Transmitter and element and thermowell to be factory assembled and shipped as one unit.

No.	By	Date	Revision
3	AC	1/16/2009	Revised Issue for Purchase
2	AC	8/5/2008	Revised Issued for Purchase
1	LS	5/14/2008	Revised Issued for Purchase
0	LS	3/28/2008	Issued for Purchase
B	AIC	3/20/2008	Revised for Inquiry

INSTRUMENT SPECIFICATION

Temperature Transmitter

bp VALHALL

Sheet 2 of 2

Code: 7134 | Dwg. No.: 45-TT -92607A-SP- | Rev.: 3