ARGENT PROCESS CONTROLS

DATA SHEET APC-DS REV 1

TAG No. 100-LT-1004

SERVICE INLET SEPARATOR LEVEL (TRIP)

PROJECT	Inlet Separation Facility (fictional)
CLIENT	Example Energy Co.
MEASURING PRINCIPLE	Guided wave radar
CALIBRATED RANGE	0 to 1500 mm
OUTPUT SIGNAL	4-20 mA HART
HAZARDOUS AREA	Ex ia IIC T4 Ga
PROCESS CONNECTION	2" ASME B16.5 Cl.300 RF
WETTED PARTS	SS316L
QUANTITY	1
ENCLOSURE	IP66 / IP67
POWER SUPPLY	Loop powered, 10.5 - 42 V DC
AMBIENT DESIGN	Desert, 55 °C max, 100 % RH