ARGENT PROCESS CONTROLS

DATA SHEET APC-DS REV 1

TAG No. 100-AT-1010

SERVICE GAS H2S ANALYSER

PROJECT	Inlet Separation Facility (fictional)
CLIENT	Example Energy Co.
SENSOR	Electrochemical, H2S
CALIBRATED RANGE	0 to 50 ppm H2S
OUTPUT SIGNAL	4-20 mA
HAZARDOUS AREA	Ex d IIC T4 Gb
PROCESS CONNECTION	3/4" NPT M
WETTED PARTS	SS316
QUANTITY	1
ENCLOSURE	IP66 / IP67
POWER SUPPLY	Loop powered, 10.5 - 42 V DC
AMBIENT DESIGN	Desert, 55 °C max, 100 % RH