NORVALE INSTRUMENTS

Instrument Data Sheet · Form ID-01 · Rev 0

Tag number: 100-PT-1011	Doc no: ISF-100-IN-DS-09
Service: Condensate pump discharge	Line / equipment: V-100

1 Project	Inlet Separation Facility (fictional)
2 Client	Example Energy Co.
3 Calibrated range	0 to 40 barg
4 Output signal	4-20 mA HART
5 Hazardous area	Ex ia IIC T4 Ga
6 Process connection	1/2" NPT F
7 Wetted parts	SS316L
8 Quantity	1
9 Enclosure	IP66 / IP67
10 Power supply	Loop powered, 10.5 - 42 V DC
11 Ambient design	Desert, 55 °C max, 100 % RH

Fictional test document for 'Engineering + Code + AI', article 02. Not a real product.