ARGENT PROCESS CONTROLS

DATA SHEET APC-DS REV 1

TAG No. 100-PT-1013

SERVICE SEPARATOR INLET PRESSURE

PROJECT	Inlet Separation Facility (fictional)
CLIENT	Example Energy Co.
CALIBRATED RANGE	0 to 10 barg
OUTPUT SIGNAL	4-20 mA HART
HAZARDOUS AREA	Ex ia IIC T4 Ga
PROCESS CONNECTION	1/2" NPT F
WETTED PARTS	SS316L
QUANTITY	1
ENCLOSURE	IP66 / IP67
POWER SUPPLY	Loop powered, 10.5 - 42 V DC
AMBIENT DESIGN	Desert, 55 °C max, 100 % RH