NORVALE INSTRUMENTS · Pressure Transmitters · Form ID-01M Rev 1

Project: Gas Compression Unit 200 (fictional) Doc no: GCU-200-IN-DS-0007

Tag number	200-PT-2001	200-PT-2002	200-PT-2003	200-PT-2004
Service	Suction pressure	Interstage pressure	Discharge pressure	Seal gas pressure
Sensor limits URL (bar)	40	100	400	100
Calibrated range (barg)	0 – 16	0 – 40	0 – 100 [1]	as col. 2
Output signal	4-20 mA HART	as col. 1	"	Foundation Fieldbus
Hazardous area	Ex ia IIC T4 Ga	"	"	Ex d IIC T6 Gb
Process connection	1/2" NPT F	"	3/4" NPT F	1/2" NPT F
Wetted parts	SS316L	"	Inconel 625	SS316L

[1] Rev 1: col. 3 calibrated range changed from 0 – 60 barg (Rev 0) after compressor re-rate.

Ditto (") and "as col. n" mean the value in the column to the left / in column n applies.