Hood and Duct Fire Extinguishing System(s)
Certified Installation and Semi-Annual Inspection Report
Page 1 of ___

☐Annual Inspection
☐Semi Annual Inspection
☐Certified Inspection

COMMENTS:

CUSTOMER NAME _____ DATE _____

ADDRESS _____

SYSTEM #1 _____

SYSTEM #2 _____

This is☐ is not☐ certification of original installation. Copy was☐ was not☐ left with client.

DESCRIPTION	SYSTEM 1	SYSTEM 2	EXPLANATIONS/EXCEPTIONS
1 Proper Hood and Duct Protection?	Yes☐ No☐	Yes☐ No☐	
2 Proper Cooking Surface Protection?	Yes☐ No☐	Yes☐ No☐	
3 Pipe/Conduit Secure and Correct?	Yes☐ No☐	Yes☐ No☐	
4 Chemical Cylinder Full?	Yes☐ No☐	Yes☐ No☐	
5 Cylinder Pressure Correct?	Yes☐ No☐	Yes☐ No☐	System #1 _____ PSI #2 _____ PSI
6 Cartridge Weight Correct?	Yes☐ No☐	Yes☐ No☐	System #1 _____ Lb #2 _____ Lb
7 System Actuation	Yes☐ No☐	Yes☐ No☐	Automatic (Terminal Detector)
8 Tested?	Yes☐ No☐	Yes☐ No☐	Manual (Remote Pull Station)
9 Appliances Shut Down	Yes☐ No☐	Yes☐ No☐	Electrical
10 upon System Actuation?	Yes☐ No☐	Yes☐ No☐	Gas Fired
11 All Appliances Under Exhaust Hood?	Yes☐ No☐	Yes☐ No☐	
12 Fusible Links Changed?	Yes☐ No☐	Yes☐ No☐	Old Links Left With _____
13 Discharge Nozzles Cleaned/Capped?	Yes☐ No☐	Yes☐ No☐	
14 Gas Pilots Relit?	Yes☐ No☐	Yes☐ No☐	
15 Filters have U.L. Listing?	Yes☐ No☐	Yes☐ No☐	
16 Hood & Filters Reasonably Clean?	Yes☐ No☐	Yes☐ No☐	
17 System is OK to Certify?	Yes☐ No☐	Yes☐ No☐	
18 System is Red Tagged?	Yes☐ No☐	Yes☐ No☐	
DESCRIPTION			
19 Kitchen Personnel Instructed in System/Portables Operation?	Yes☐ No☐		
20 40B:C Rated Portable Fire Extinguisher Installed?	Yes☐ No☐		Mfg or H/T Date ____ . ____

REFERENCE NFPA-96 (8-2.1): "Inspection and servicing of the fire extinguishing system by properly trained and qualified persons shall be made at least every **six months**." **Insureds** are responsible to provide this report to the insurer providing insurance coverage on the risk to receive your **discounts**. While the **insured** is required to maintain proper coverage, available **discounts**, if any, will affect the pricing of your insurance.

REFERENCE **TEXAS INSURANCE CODE, Article 1.10, Section 7(a)**: "**Violations** (of the CODE) can result in disciplinary action including suspension or **revocation** of license or certificate of registration or an order to pay **administrative penalties** up to **$25,000.00 per violation**, restitution to customers, or other remedial action..."

All property and equipment (including this report) used in installing or servicing the above referenced system(s) will remain the property of _____ until payment is made in full.

ACKNOWLEDGEMENT OF INSPECTION AND CONDITIONS:

INSPECTOR	SIGNATURE	LICENSED COMPANY	CUSTOMER
FEL-			
TEXAS LICENSE NUMBER	INSPECTION DATE	TEXAS CERTIFICATE OF REGISTRATION NUMBER	ACKNOWLEDGEMENT SIGNATURE