

UNCERTAINTY IN RELIABILITY PARAMETER ESTIMATES: INCLUSION IN THE GENERATION EXPANSION PLANNING (GEP) PROBLEM

ANDREW BLOHM, STEVE GABRIEL

1. ABSTRACT

What does uncertainty and nonstationarity in gas-fired generator reliability mean for the long-term reliability of our electricity system (and its optimal design)(In progress)? We anticipate that traditional methods significantly underestimate the riskiness of investment decisions and thus, overestimate system reliability, which potentially exposes consumers, generators, and system operators to greater risks of unmet demand. The contribution of our model to the literature is in the assessment of uncertainty and nonstationarity of the outage rate parameter on the optimal resource mix (as compared to existing methods). We anticipate that the composition, costs, and reliability resulting from our method will be quite different than existing methods, which rely on single point parameter estimates.

2. NOMENCLATURE

Indices and sets

$i(I)$ Index set of units

$t(T)$ Index set of time periods

Parameters

Variables (continuous)

Variables (binary)

3. INTRODUCTION

Investments in energy production capacity are subject to partial or complete irreversibility (i.e., large, sunk cost that is not particularly fungible) and are large, high-risk investments facing uncertain operating environments (i.e., economic and regulatory uncertainty)(Bakirtzis, Biskas, and Chatziathanasiou 2012). The Generation Expansion Planning (GEP) problem has been employed extensively to manage these risks while selecting an optimal production portfolio. The GEP model determines how best to meet expected future demand through the selection of plant size, production technology, and location, as well as timing over a planning horizon, usually between 10 - 30 years (Hemmati, Hooshmand, and Khodabakhshian 2013). The GEP problem is well studied, from a variety of perspectives including: solution

algorithms, incorporation of new production technologies, uncertainty characterization, reliability, time horizon, etc. (Hemmati, Hooshmand, and Khodabakhshian 2013).

Two approaches are generally used to determine the solution to the GEP: either a centralized or decentralized approach (Bakirtzis, Biskas, and Chatziathanasiou 2012).¹ The centralized approach is appropriate in monopoly situations (i.e., a monopoly utility determining least cost expansion plans) or in deregulated markets by governing or regulating authorities to better design markets and policies (Bakirtzis, Biskas, and Chatziathanasiou 2012). Solution methods for the centralized problem include stochastic dynamic programming (SDP)(), non-linear programming (NLP)(), evolutionary programming (), multi-objective programming (), mixed-integer linear programming (MILP) (), in addition to other approaches ()(Bakirtzis, Biskas, and Chatziathanasiou 2012). [Insert the citations from Bakirtzis, Biskas, and Chatziathanasiou 2012.]²

Uncertainty incorporation in the generation expansion planning problem has included price volatility, reliability of generation units, load forecast, electricity prices, and costs (i.e., fixed and variable) of each power production technology Hemmati, Hooshmand, and Khodabakhshian 2013; Pereira and Saraiva 2010; Pereira and Saraiva 2011. However, to date, the literature is bereft of an analysis of the effect of uncertainty or trends in the forced outage rate (FOR) parameter on the optimal investment portfolio in the GEP problem. Past studies have demonstrated that small changes in the FOR can have significant effects on the reliability of the system () (Shirvani (2012))[add citation].

There are significant, ongoing changes to the role and deployment of gas-fired generators that are potentially leading to changes in unit reliability. Natural-gas fired generators are more frequently ramping, as a result of more renewables, which is having unknown consequences but presumed negative affects on maintenance and reliability [add citation]. At the very least, generators are experiencing increasing O&M costs as a result of increasing power plant cycling given larger deployments of variable generation, especially for plants designed as baseload units (**nerl:2012aa**).³ These affects are being overlooked by current GEP problem formulations.

Power system adequacy in GEP problems has historically been addressed using deterministic methods, however, over the past few decades probabilistic criteria have largely replaced them. Deterministic criteria include a planning reserve margin, which could be one of several measures including, setting the reserve margin to the size of the largest generation unit, percentage of system capacity, etc. The issue with deterministic approaches (e.g., planning reserve margin) is that they do not

¹The micro-approach incorporates a high amount of model complexity that require operations research or meta-heuristic methods to solve but with the caveat that there is no guarantee that global optimality is achieved. Macro-modeling approaches reduce complexity by ignoring those features and constraints.

²The decentralized approach accounts for the behavior of market participants, usually in a deregulated market framework (Bakirtzis, Biskas, and Chatziathanasiou 2012). For a more detailed discussion of the decentralized approach the reader is directed to Bakirtzis, Biskas, and Chatziathanasiou 2012.

³Cycling means operating the plant in response to system load requirements (i.e., load following, varying load levels, etc.); as opposed to operating it as a baseload resource (**nerc:2012aa**). Each cycling exposes equipment to pressure and thermal stresses that can damage equipment and subsequently, lead to shorter component life expectancies, higher equivalent forced outage rates (EFOR), and shorter life expectancies (**nerc:2012aa**).

account for stochasticity in unit behavior, unit size, etc. As a result, deterministic methods can lead to either over-investment or inadequate system reliability (Aghaei et al. 2013).

Instead, stochastic methods naturally account for randomness such as unit forced outage rates, size, etc. but at the expense of an increasing computational burden (Aghaei et al. 2013). In general, probabilistic metrics measure the duration, intensity or frequency in which demand exceeds the resources available at that time (**dragoon:2006aa**). The adequacy of the deployed resources to meet demand can be incorporated into the GEP problem using: Loss of Load Expected (LOLE)⁴, Loss of Load Probability (LOLP)⁵, Loss of Load Cost (LOLC), and Expected energy not served (EENS)^{6,7}.

In this paper the centralized GEP problem is formulated as a two-stage stochastic mixed integer program. We incorporate the system reliability measure through the ... The proposed model is evaluated using the IEEE 14 and 30 bus test system (Christie 1999).⁸ [Talk with Jeremy about the appropriate test system].

In the first stage the model makes investment decisions while in the second stage the model checks to see that the system meets reliability constraints while in operation. We consider the forced outage rate of each plant as a random variable, which necessarily impacts system reliability. The reliability metric (i.e., LOLE, LOLP, EENS, etc.) are highly sensitive to the EFOR parameter (i.e., a small change in the parameter estimate can lead to large changes in the reliability metric. GEP models have not explored the solution space that surrounds the EFOR parameter estimate.

The rest of this paper is organized as follows: in the second section we discuss the data used in the analysis. In the third section, we discuss existing methods for incorporating uncertain parameters, including the forced outage rate, into an optimization framework. In the fourth section, we propose the mathematical formulation of the two-stage stochastic mixed integer problem. In the fifth section, we introduce our case studies before we discuss the results of our model formulation. In the final section, we discuss some relevant conclusions of our work.

4. DATA

A common approach in the literature when developing a new model is to use a well studied data set. In the GEP literature this is the IEEE Reliability Test system, which has a number of sizes (i.e., the number of buses in the system)

⁴The LOLE is the expected number of hours in which demand is not satisfied and is calculated as $LOLE = \sum_{k=1}^S P_k (C_T - L_k) \times t_k$, where there are S sub-periods and each sub-period is of length t_k .

⁵The LOLP is the long-run probability of power system demand exceeding the capacity available (Endrenyi 1978). LOLP can be calculated using daily peak load (i.e. hour demand for a 24 hour period) or using daily peak loads for a 1-year period using a load duration curve (Endrenyi 1978).

⁶EENS is the expectation of the energy that the system is not capable of serving and is calculated as the following $EENS = P_k (C_T - L_k) \times (C_T - L_k)$.

⁷Given its simplicity LOLE has been extensively used in the past, however, EENS does have certain advantages including that it encompasses the degree of the deficiency, as well as the likelihood (Murugan, Kannan, and Baskar 2009, p622).

⁸We downloaded the power system data for each of the 14, 30, 57, 188, and 300 bus test systems.

(**billinton:1994aa**). We use the IEEE Reliability Test System ... [insert system size] ().

5. METHODS

A number of reviews have been completed that systematically organize the GEP literature. (Bakirtzis, Biskas, and Chatziathanasiou 2012; Hemmati, Hooshmand, and Khodabakhshian 2013)(Kagiannas et al., 2004; Zhu and Chow, 1997; Hobbs, 1995)⁹

Bakirtzis, Biskas, and Chatziathanasiou 2012 incorporates system level reliability using the value of lost load (VLL) in the problem objective function (i.e., mixed-integer linear program) while addressing stochasticity through scenario exploration. A simple model is used whereby the equivalent forced outage rate (EFOR) is used to derate the maximum output of each unit (Bakirtzis, Biskas, and Chatziathanasiou 2012). **tekiner:2010aa** developed a two-stage mixed-integer linear program that addresses stochasticity in the forced outage rates through the development of scenarios using Monte Carlo methods.

The GEP problem is a large-scale, highly-constrained mixed-integer linear program (MINLP) that requires complete enumeration (i.e., investigation of every combination of assets over the time horizon) to identify the global optimum (Bakirtzis, Biskas, and Chatziathanasiou 2012). The inability to undertake such an exercise has led to the development of simplifications to reduce the computational load of the problem.

A common approach to dealing with uncertainties in the GEP framework is Monte Carlo methods (Pereira and Saraiva 2010). Typically, the LOLE and EENS are generated using Monte Carlo techniques (Roy Billinton and R. N. Allan 1996; Li and Zio 2012). It is typically built recursively using the Capacity Outage Cumulative Probability Table (COCPT).¹⁰

Assessing system adequacy using stochastic methods can lead to computational issues given the widely held belief that the GEP is actually a mixed integer non-linear program (Aghaei et al. 2013). As a result, several methods were developed to assess system adequacy. proposed the 'Z-Method' to evaluate system adequacy in the GEP problem, which replaces the stochastic adequacy assessment metric (i.e., loss-of-load probability (LOLP)) with a new constraint. The approach accounts for unit forced outage rates (FOR), system adequacy targets¹¹, uncertainty in expected load growth, as well as the size, type and number of units in the production mix (**"ldots"** ; Aghaei et al. 2013).

⁹Zhu, J., and Chow, M., A Review of Emerging Techniques on Generation Expansion Planning, IEEE Transactions on Power Systems, Vol.12, No.4, 1997; Hobbs, B.F., Optimization Methods for Electric Utility Resource Planning, European Journal of Operational Research, 83, 1-20, 1995; Kagiannas, A. G., Askounis, D.Th., and Psarras, J., Power Generation Planning: A Survey from Monopoly to Competition, International Journal of Electrical Power and Energy Systems, 26, 413-421, 2004

¹⁰COCPT assumes that the failure of a unit is "independent of the operating level, system load, and the outage pattern of other units" (Goel presentation, 2011).

¹¹In the GEP formulation framework the modeler would select an acceptable level of service (i.e., industry standard is an insufficient capacity with a frequency of 1-in-10 years)(). The model would then calculate the appropriate reliability statistic using the EFOR (i.e., the number of hours of unit failure as a percentage of all available hours) for each generation unit type and size.

6. MODEL DESCRIPTION AND MATHEMATICAL FORMULATION

Planning and investment in power generation capacity expansion is difficult given the competing objectives for power producers (i.e. minimization of investment costs and maximization of reliability); uncertainty in a number of parameters (i.e. costs, demand, regulation), physical and technical constraints, complex mix of regulated and deregulated market structure across the country, and, large and lumpy investments, to name a few.

6.1. Load model description. The system load for each period is represented using a step-wise load duration curve. Demand varies across the year using a load duration curve representation that decomposes annual demand into several load segments. The number of steps was chosen to accurately represent the load duration curve across the hours.

6.2. Energy balance constraints.

6.3. Unit operating cost constraints.

6.4. Annual budget constraints.

6.5. Binary constraints.

6.5.1. Maximum construction limit This constraint is a maximum allowable number, capacity, or investment amount for new generation sources to be built during period t given limited resources (i.e., capital, manpower, space, etc.).

6.5.2. LOLP constraint To ensure that adequacy requirements (i.e., minimum level of service) are maintained the GEP problem formulation typically includes reliability constraints.¹²¹³

$$(1) \quad lolpc_t \leq lolps_t \forall t \in T$$


The $lolpc_t$ is the loss-of-load probability at stage t and $lolps_t$ is the loss-of-load probability limit (i.e., the reliability target selected by the user) (**dragon:2006aa**). The equivalent Z constraint is ...

6.6. Computational, convergence, and feasibility issues. [Insert description of the computer used to solve] [Insert description of the number of variables and equations] **bakirtzis** used a convergence tolerance of 0.25% with their model taking between 7 and 18 minutes to solve.

¹²Reliability and adequacy are considered early in the planning process, typically well before stability and fault analysis. These factors are a necessary component of any long-term planning process; otherwise, there is no guarantee of having adequate supply to meet system demand.

¹³The determination of the adequate generation supply capacity can be divided into two areas: static and operating capacity requirements (R Billinton and R. Allan 1984). In this study, we focus on the static capacity requirement, which is the capacity that must be planned and installed in advance of system demand (i.e., as a part of a long-term planning process) (R Billinton and R. Allan 1984). Static capacity must be able to provide for outages and regularly scheduled maintenance, in addition to anticipated load growth (R Billinton and R. Allan 1984). Operating capacity, which we mention only for completeness, determines the capacity necessary to meet actual short-term load and is used in different frameworks, such as unit commitment problems (R Billinton and R. Allan 1984).

7. SMIP GEP: CASE STUDY



8. RESULTS

The proposed model is evaluated using the ... bus IEEE Reliability test network (). The system has ... nodes with total installed demand and capacities as defined in Table ???. We display other assumptions, such as the fuel cost and variable operations and maintenance costs in Table ??. The average load of the system is ... with a peak load of

The load duration curve ... We have ... scenarios for the load growth: ...

[Insert model parameterization discussion here]

9. DISCUSSION

REFERENCES

- Aghaei, Jamshid et al. (2013). “Multiobjective generation expansion planning considering power system adequacy”. In: *Electr. Power Syst. Res.* 102, pp. 8–19. ISSN: 0378-7796. DOI: 10.1016/j.epsr.2013.04.001.
- Bakirtzis, Grigorios A., Pandelis N. Biskas, and Vasilis Chatziathanasiou (2012). “Generation Expansion Planning by MILP considering mid-term scheduling decisions”. In: *Electr. Power Syst. Res.* 86, pp. 98–112. ISSN: 0378-7796. DOI: 10.1016/j.epsr.2011.12.008.
- Barbosa, Fernando Pires Maciel (1977). “Confidence limits on loss of load probability method”. PhD thesis. Victoria University of Manchester.
- Billinton, R and RN Allan (1984). *Reliability evaluation of power systems*. Plenum Press.
- Billinton, Roy and Ronald N Allan (1996). “Reliability assessment of electric power systems”. In: *University of Saskatchewan, Canada, S7N OWO*.
- Christie, R.D. (1999). *Power Systems Test Case Archive*. URL: <https://www2.ee.washington.edu/research/pstca/>.
- Endrenyi, J. (1978). *Reliability Modelling in Electric Power Systems*. John Wiley & Sons.
- Gugel, H et al. (2015). “Polar vortex analysis with Generator Availability Data System (GADS) data”. In: *Power & Energy Society General Meeting, 2015 IEEE*. IEEE, pp. 1–5.

- Hemmati, Reza, Rahmat-Allah Hooshmand, and Amin Khodabakhshian (2013). “Comprehensive review of generation and transmission expansion planning”. In: *IET Gener. Transm. Distrib.* 7.9, pp. 955–964. ISSN: 1751-8687. DOI: 10.1049/iet-gtd.2013.0031.
- Li, Yanfu and Enrico Zio (2012). “Uncertainty analysis of the adequacy assessment model of a distributed generation system”. In: *Renewable Energy* 41, pp. 235–244.
- Murugan, P, S Kannan, and S Baskar (2009). “NSGA-II algorithm for multi-objective generation expansion planning problem”. In: *Electric Power Systems Research* 79.4, pp. 622–628.
- NERC (2011a). *2011 Special Reliability Assessment: A Primer of the Natural Gas and Electric Power Interdependency in the United States*. Tech. rep. Atlanta, GA: North American Electric Reliability Corporation.
- (2011b). *Generating Availability Data System: Mandatory Reporting of Conventional Generation Performance Data*. Tech. rep. Atlanta, GA: North American Electric Reliability Corporation.
- (2013). *2013 Special Reliability Assessment: Accomodating an increased dependence on natural gas for electric power. Phase II: A vulnerability and Scenario Assessment for the North American Bulk Power System*. Tech. rep. Atlanta, GA: North American Electric Reliability Corporation.
- Pereira, Adelino JC and João Tomé Saraiva (2010). “A decision support system for generation expansion planning in competitive electricity markets”. In: *Electric power systems research* 80.7, pp. 778–787.
- (2011). “Generation expansion planning (GEP)—a long-term approach using system dynamics and genetic algorithms (GAs)”. In: *Energy* 36.8, pp. 5180–5199.
- US EIA (2014). *Annual energy outlook 2014*. Tech. rep. Washington, DC: US Energy Information Administration.