225 Building Environment Report

NEU Seattle Devs (Hot Sauce)

2025-02-25

1 Basic Monitoring Information

1.1 Sensor Details

Sensor Information:

Sensor # 3:

Date: 2/25/2025

Time Range: 8:30:20 - 12:15:01

Location: Floor-1 Sensor Status: OK

Sensor # 5:

Date: 2/25/2025

Time Range: 8:30:20 - 12:15:01

Location: Floor-2 Sensor Status: OK

1.2 Environmental Monitoring Chart

2 Environmental Monitoring Charts

Multi-sensor environmental monitoring charts saved in 'charts/'.

2.1 Sensor Comparison Charts

2.1.1 Temperature Comparison




Figure 1: Temperature Comparison

2.1.2 Humidity Comparison




Figure 2: Humidity Comparison

2.1.3 CO₂ Comparison




Figure 3: CO2 Comparison

2.1.4 PM 2.5 Comparison




Figure 4: PM2.5 Comparison

2.2 Data Insights

Temperature: ranging from 70.8° F to 76.1° F **Humidity**: ranging from 70.8° F to 76.1° F

```
**CO2 Levels**: ranging from 70.8° F to 76.1° F
**PM 2.5 Levels**: ranging from 70.8° F to 76.1° F
```

3 Comfort Level

Comfort Scores

Indoor Comfort Scores: 91.21

Comfort Levels

- Excellent (90-100) Ideal indoor environment
- Good (75-89) Comfortable but slightly off-optimal
- Moderate (50-74) Some discomfort noticeable
- Poor (25-49) Significant discomfort or air quality concerns
- Unacceptable (0-24) Unhealthy indoor conditions

Comfort Categories

- 1. Temperature (°F) Ideal indoor temperatures typically range between 70°F and 77°F for comfort.
- 2. Humidity (%) Optimal indoor humidity falls between 40% and 60% to maintain comfort and air quality.
- 3. CO Levels (ppm) Higher CO levels can indicate poor ventilation. Readings below 600 ppm are ideal, while values above 1000 ppm suggest poor air circulation.
- 4. PM 2.5 ($\mu g/m^3$) Ideal indoor PM 2.5 levels should remain below 12 $\mu g/m^3$. Levels exceeding 35 $\mu g/m^3$ are considered unhealthy, especially for sensitive groups.

3.1 Anomaly Detection -> for later dev

- CO2 and PM2.5 levels show steady increase
- Potential indicators:
 - Increased occupancy
 - Reduced ventilation
 - Ongoing activities in the monitored space

4 Sensor Specification

- Sensor Models: ESP8266, PMS5003(PM2.5), SHT31-D(Temp/Hum), S8(CO2)
- Calibration Date: January 15, 2025
- Sampling Interval: 5 minutes