# 225 Building Environment Report

NEU Seattle Devs (Hot Sauce)

2025-02-25

## 1 Basic Monitoring Information

#### 1.1 Sensor Details

Sensor Information:

\_\_\_\_\_\_

Sensor # 3:

Date: 2/25/2025

Time Range: 8:30:20 - 12:15:01

Location: Floor-1 Sensor Status: OK

\_\_\_\_\_

Sensor # 5:

Date: 2/25/2025

Time Range: 8:30:20 - 12:15:01

Location: Floor-2 Sensor Status: OK

\_\_\_\_\_

### 1.2 Environmental Monitoring Chart

## 2 Environmental Monitoring Charts

Multi-sensor environmental monitoring charts saved in 'charts/'.

## 2.1 Sensor Comparison Charts

## 2.1.1 Temperature Comparison




Figure 1: Temperature Comparison

### 2.1.2 Humidity Comparison




Figure 2: Humidity Comparison

### 2.1.3 CO<sub>2</sub> Comparison




Figure 3: CO2 Comparison

### 2.1.4 VOC Comparison




Figure 4: VOC Comparison

## 2.2 Data Insights

- Temperature: Ranging from  $22.5^{\circ}$ C to  $25.6^{\circ}$ C
- **Humidity**: Ranging from 45% to 38%

• CO2 Levels: Ranging from 400 ppm to 750 ppm

• VOC Levels: Ranging from 50 to 85

### 3 Comfort Level

#### **Comfort Scores**

Comfort Score: 88.31 (Good)

#### **Comfort Levels**

- Excellent (90-100) Ideal indoor environment
- Good (75-89) Comfortable but slightly off-optimal
- Moderate (50-74) Some discomfort noticeable
- Poor (25-49) Significant discomfort or air quality concerns
- Unacceptable (0-24) Unhealthy indoor conditions

#### **Comfort Categories**

- 1. Temperature (°F) Ideal indoor temperatures typically range between 69.8°F and 77°F for comfort.
- 2. Humidity (%) Optimal indoor humidity falls between 40% and 60% to maintain comfort and air quality.
- 3. CO Levels (ppm) Higher CO levels can indicate poor ventilation. Readings below 600 ppm are ideal, while values above 1000 ppm suggest poor air circulation.
- 4. VOC Levels Volatile Organic Compounds (VOCs) affect air quality, with values below 50 considered excellent and those above 150 potentially harmful.

### 3.1 Anomaly Detection -> for later dev

- CO2 and VOC levels show steady increase
- Potential indicators:
  - Increased occupancy
  - Reduced ventilation
  - Ongoing activities in the monitored space

### 4 Sensor Specification

- Sensor Models: ESP8266, PMS5003(PM2.5), SHT31-D(Temp/Hum), S8(CO2)
- Calibration Date: January 15, 2025
- Sampling Interval: 5 minutes