

CLIENT CUSTOMER		LIEU D'INSTALLATION PLANT LOCATION		REV	
FONCTION SERVICE		PURGED WATER STRIPPING COLUMN BOTTOM PUMP(6)		QUANTITE NECESSAIRE N° OF UNITS 1	
ENTRAINE PAR DRIVEN BY		ELECTRICAL MOTOR		SERVICE OPERATION	
NOM DU PROJET PROJECT NAME		TYPE TYPE		CENTRIFUGAL	
REFERENCE OFFRE CONSTRUCTEUR MFR PROPOSAL N°					
1 CONDITIONS OPERATOIRES OPERATING CONDITIONS				CARACTERISTIQUES PERFORMANCES	
2 LIQUID LIQUID water + traces of VCM (5)				COURBE DE PROPOSITION N° PROPOSAL CURVE N°	
3 DEBIT Nominal FLOW Nominal 3.35				DEBIT Maxi. FLOW Maxi. 4.2 m3/h	
4 PRESS. REFOULEMENT (2)(3) DISCHARGE PRESS. (2)(3)				3.98 kg/cm²g	
5 PRESSION/TEMP. DE REF. PRESSURE/TEMP. REF 108°C				PRESSION ASPIRATION (2)(3) SUCTION PRESSURE (2)(3) 0.7 kg/cm²g	
6 MASSE VOL. A PT DENSITY AT PT 941 kg/m³				PRESS. DIFFERENTIELLE(1)(2) DIFFERENTIAL PRESS. (1)(2) 3.28 kg/cm²	
7 TENSION DE VAPEUR A T VAPOR PRESSURE AT T 1.33 kg/cm²a				HAUTEUR MANO. (1)(2) DIFFERENTIAL HEAD (1)(2) 35 m. liq.	
8 VISCOSITE A PT VISCOSITY AT PT 0.3 cP				NPSH DISPONIBLE (2) NPSH AVAILABLE (2) 3.9 m. liq.	
CORROSION/EROSION DUE A CORROSION/EROSION CAUSED BY (5)				DEBIT CONT. MINI (PAR CONSTR.) MIN CONTINUOUS FLOW (BY MFR) m3/h	
9 TYPE ET MATERIAUX DE CONSTRUCTION CONSTRUCTION AND MATERIALS				SENS DE ROTATION FACE ACCOUP. ROTATION (VIEWED FROM CPLG END)	
10 SUPPORTAGE CORPS CASING MOUNTING				EAU DE REFROIDISSEMENT COOLING WATER	
11 JOINT SPLIT				SUR DBLE ENVEL. G.M. TO MECHAN. SEAL JACKET m3/h	
12 TYPE TYPE				SUR DBLE ENVEL. P.E. TO STUFFING BOX JACKET m3/h	
13 BOSSAGES TAPPED OPENINGS				SUR FOND DE POMPE. TO REAR CASING JACKET m3/h	
14 TUBULURES NOZZLES				SUR PALIER TO BEARING HOUSING m3/h	
15 ASPIRATION SUCTION				DEBIT D'EAU TOTAL TOTAL WATER REQ'D m3/h	
16 REFOULEMENT DISCHARGE				EAU LANTERNE P.E. WATER TO LANTERN RING	
17 DIAMETER DE LA ROUE IMPELLER DIAMETER				RECHAUFFAGE HEATING JACKET	
18 PALIER BEARING				CIRCUIT EAU DE REFROID. SEAL COOLING	
19 ACCOUPLEMENT MARQUE COUPLING MFR				SUIVANT API 610 FIG. ACC. TO API 610 FIG. PLAN	
20 PROTECTEUR D'ACCOUPLEMENT COUPLING GUARD				AUXILIAIRES FOURNIS AVEC LA POMPE DEVICE SUPPLIED WITH PUMP	
21 PRESSE-ETOUPE (P.E.) PACKING TYPE AND SIZE				CIRCUIT D'ARROSAGE G.M. PIPING FOR SEALS	
22 GARNITURE MECANIQUE (G.M.) MECHANICAL SEAL MFR				SUIVANT API 610 FIG. ACC. TO API 610 FIG. PLAN	
23 G.M. DIAM. ET CARACTERISTIQUES M.S. SIZE AND CHARACTERISTICS				INSTRUMENT SUR POT G.M. ALARMS AND SAFETY FOR SEAL DEVICES	
24 GARNITURES MECANQUES MECHANICAL SEALS					
25 REMARQUES REMARKS (1) VALUE STATED FOR DESIGN FLOWRATE					
26 (2) NPSHA INDICATED IS FROM PUMP CENTERLINE WHICH IS AT 800 mm ELEVATION FROM GRADE.					
27 (3) ESTIMATED DISCHARGE DESIGN PRESSURE (CORRESPONDING TO SHUT-OFF PRESSURE) IS 16 kg/cm² g. VENDOR SHALL LIMIT RISE TO SHUT-OFF SO AS NOT TO EXCEED THE DISCHARGE DESIGN PRESSURE. DESIGN TEMPERATURE: 240°C. DESIGN SUCTION PRESSURE : 11 kg/cm2 g.				01	
28 (4) ESTIMATED SHAFT POWER. TO BE CONFIRMED BY PUMP VENDOR. MOTOR SHALL BE ENERGY-EFFICIENT : - CEI60034-30, class IE2 or IE3, or equivalent. TO BE CONFIRMED BY ELECTRICAL DISCIPLINE IN MDS.					
29 (5) PUMPED FLUID IS MAINLY WATER WITH TRACES OF VCM AND HCI.					
30 (6) PUMP TO BE INSULATED FOR HOT INSULATION.					
31 (7) TO BE CONFIRMED BY PUMP VENDOR					
POMPE CENTRIFUGE CENTRIFUGAL PUMP		REPERE - ITEM		PAGE 2 / 3	
				DATE 22/06/2024	
				06/03/2025	
				REV. 00	
				01	

CLIENT
CUSTOMER

FONCTION
SERVICE

ENTRAINE PAR
DRIVEN BY

NOM DU PROJET
PROJECT NAME

REFERENCE OFFRE CONSTRUCTEUR
MFR PROPOSAL N°

LIEU D'INSTALLATION
PLANT LOCATION

PURGED WATER STRIPPING COLUMN BOTTOM PUMP

ELECTRICAL MOTOR

SERVICE
OPERATION

TYPE
TYPE

QUANTITE NECESSAIRE
N° OF UNITS

CONTINU
CONTINUOUS

DISCONTINU
DISCONTINUOUS

CENTRIFUGAL

REV

31	MATERIAUX MATERIALS		POMPE PUMP	GARNITURE MECANIQUE (1) MECHANICAL SEAL		ESAIS CHEZ CONSTRUCTEUR SHOP TESTS	DEMANDE REQUIRED	CONTR. CLIENT PURCH. CHECK		
32	ROUE IMPELLER		CS	GRAIN FIXE COTE P. STAT SEAL PUMP SIDE		PERFORMANCEE PERFORMANCE	Yes	Yes		
33	CORPS INNER CASE		CS	GRAIN TOURN. COTE P. ROT. SEAL. PUMP SIDE		NPSH NPSH	Yes	Yes		
34	CHEMISE (P.E.) SLEEVE (PACKED)			RESSORT/SOUFFLET SPRING/BELLOWS		DEMONTAGE DISMANTLING	No			
35	CHEMISE (G.M.) SLEEVE (M.S.)			AUTRES PIECES OTHERS		PROCES-VERBAL TEST RECORD	Yes	Yes		
36	BAGUE D'USURE WEAR RINGS			GRAIN FIXE COTE EXT. STAT. SEAL EXT. SIDE		EPREUVE HYDRAU. HYDRAUL. TESTS	Yes	Yes		
37	ARBRE SHAFT			GRAIN TOURN. C. EXT. ROT. SEAL EXT. SIDE		P/T MAX. ADMISSIBLE P/T MAX. ALLOWABLE	kg/cm²g	°C		
38	JOINTS DE CORPS CASING GASKET			JOINTS GASKETS & O RINGS		POIDS POMPE WEIGHT PUMP	kg	SOCLE BASE	kg	
39				POT RESERVOIR		LIEU DES ESSAIS TESTS LOCATION	In manufacturer workshop			
40				LIQUIDE TAMPON BUFFING LIQUID						
41	MOTEUR FOURNI PAR MOTOR SUPPLIED BY			ENTRAINEMENT DRIVERS		CARACTERISTIQUES REELLES MFR FINAL DATA (AS BUILT)				
42	MARQUE MFR		TYPE TYPE	ACCOUPLEMENT COUPLING		DIAM. REEL ROUE ACTUAL IMPELLER DIAMETER				
43	kW kW		Tr/min RPM	Carc. Frame		COUBE D'ESSAI N° TEST CURVE N°				
44	PROTECTION PROTECTION		IP55			PLAN D'ENSEMBLE N° OUTLINE DRWG N°				
45	ANTIDÉFLAGRANT EXPLOSION PROOF		EExd IIB T4 (4)			PLAN EN COUPE N° SECTIONAL DRWG N°				
46	VOLTS/PHASES/Hz VOLTS/PHASES/Hz		415/3/50			PLAN DE LA GARNITURE N° SEALING SYSTEM DRWG N°				
47	PALIER BRGS		bearing LUB. LUB.	Oil			N° DE LA SERIE DE LA POMPE PUMP SERIAL N°			
48	INTENSITE A CHARGE MAXI CURRENT AT MAX LOADING									
49	MONTE PAR MOUNTED BY		POIDS WT			kg				
50	REMARQUES REMARKS									
51										
52	(1) SINGLE MECHANICAL SEAL									
53	(2) MDMT : 5 °C									
54	(3) PUMPING FLUID WILL CONTAIN AVERAGE PVC CONCENTRATION OF 40 mg/l WITH AVERAGE PARTICLE SIZE OF 25 µm. MAXIMUM PARTICLE SIZE IS 200 µm.									
55	(4) MOTOR TYPE BASED ON HAZARDOUS AREA CLASSIFICATION TO BE CONFIRMED BY ELECTRICAL AND HSE DISCIPLINE IN MECHANICAL DATASHEET.									
56	NOTES CONTINUED FROM PAGE 2/3...									
57	(8) SEAL PLAN AND FLUSHING LIQUID REQUIREMENT FOR PUMP TO BE CONFIRMED BY MECHANICAL DISCIPLINE IN MDS BASED ON VENDOR REQUIREMENT.									
58										
59										
60										
			POMPE CENTRIFUGE CENTRIFUGAL PUMP							
			REPERE - ITEM							
						PAGE	DATE	REV.		
						3 / 3	22/06/2024	00		
							06/03/2025	01		