

Transformer Condition Diagnostic Summary Sheet

Generated: 15-06-2026 16:02 | Diagnostic Framework: IS 1866:2017 Criteria

Total Assets Evaluated	Acceptable Status (H2O)	Unacceptable Status (H2O)	Not Detected
3	2	1	0

Asset Name	Report ID	H2O ppm	Limit	BDV kV	H2 gas	TGC Eval	Verdict
Power Transformer Represe	—	28.0	40	—	—	—	ACCEPTABLE
Power Transformer Represe	—	22.0	40	—	—	—	ACCEPTABLE
Power Transformer Represe	—	72.0	40	—	—	—	UNACCEPTABLE