

Property Condition Report

SouthPark Centre - 4800 Sharon Road, Charlotte, NC

EXECUTIVE SUMMARY

Report Date:	April 15, 2026
Inspector:	GreatPlains Engineering Associates
Building Age:	25 years (built 2001)
Last Renovation:	2014 (common areas)

Overall Condition:	Fair to Good	Deferred maintenance in lobby/common areas
---------------------------	---------------------	---

STRUCTURAL / ENVELOPE

Foundation:	Good	No settlement observed
Steel Frame:	Good	No corrosion or fatigue
Curtainwall:	Fair	Minor sealant deterioration at several joints. Budget for resealing within 3-5 years.
Roof:	Fair	See separate Roof Inspection Report. 10-15 years remaining useful life.

MECHANICAL / ELECTRICAL

HVAC:	Fair	See separate HVAC Assessment. 3 of 8 RTUs approaching end of life.
Electrical:	Good	Panel capacity adequate. Emergency generator functional.
Plumbing:	Fair	Ground floor modifications for medical tenant. Restrooms dated on floors 1-5.
Fire Protection:	Good	Sprinkler system compliant. Annual inspection current.

INTERIOR

Lobby:	Poor	Dated finishes from 2014 renovation. Recommend full renovation.
Corridors (Fl 1-5):	Fair	Carpet worn, paint faded. Refresh recommended.
Corridors (Fl 6-8):	Good	Acceptable condition.

Lobby:	Poor	Dated finishes from 2014 renovation. Recommend full renovation.
Restrooms (Fl 1-5):	Poor	Fixtures dated, tile cracked in several locations. Full renovation recommended.
Restrooms (Fl 6-8):	Good	Renovated more recently.
Elevators:	Good	See separate Elevator Inspection. Cab finishes dated but functional.

SITE

Parking Structure:	Fair	Surface cracking in several areas. Budget for resurfacing within 2-3 years. Est. \$85,000.
Landscaping:	Good	Well maintained.
Signage:	Poor	Monument sign outdated. Wayfinding inadequate.

CAPITAL RECOMMENDATIONS

Parking resurfacing:	\$85,000	Within 2-3 years
Curtainwall resealing:	\$120,000	Within 3-5 years
Lobby renovation:	See developer scope	Recommended immediately
Restroom renovation (Fl 1-5):	See developer scope	Recommended immediately