

Roof Inspection Report

SouthPark Centre - 4800 Sharon Road, Charlotte, NC

INSPECTION SUMMARY

Report Date:	October 2024
Inspector:	Charlotte Roofing Consultants
Roof Type:	Modified bitumen, ballasted
Original Install:	2001
Last Repair:	2019 (patch repairs)
Overall Condition:	Fair
Remaining Useful Life:	10-15 years

FINDINGS

Membrane:	Fair	Minor blistering in 3 locations. No active leaks.
Flashing:	Fair	Some deterioration at parapet walls. Recommend re-flashing.
Drainage:	Good	Drains clear, no ponding observed.
Insulation:	Good	R-value adequate per current code.

RECOMMENDATIONS

Minor repairs:	\$45,000	Patch blisters, re-flash parapets. Recommended within 12 months.
Full replacement:	Not needed	Not recommended for 10-15 years.