

# FIRE FREE ENGINEER'S

FIRE PROTECTION ENGINEERS & GOVT. CONTRACTORS

Authorised Distributor :-

JAINEX (FIRE & SAFETY) SYSTEM PVT. LTD. MUMBAI



**FIREBELL**

2253649

Beside Maharashtra Bhawan,

Choubey Colony,

RAIPUR - 492 001 (C.G.)

Mobile : 94252-11527

## TEST CERTIFICATE/INSPECTION CERTIFICATE

Customer's Name & Address :

M/s. Gyan Ganga Educational  
Academy Vidhansabha  
Raipur (CG)

Date : 17/06/21

This is to Certify that Mr. R. S. Sahy has made the  
periodical inspection/Testing of the fire Extinguishers installed here.

1. Present installation of Fire Extinguishers 02 NOS 2Kg Capacity ABC Type  
+ 02 NOS ABC Type 04Kg Capacity F/E + 02 NOS 05Kg Capacity  
ABC Type + 05 NOS DCP Type 05Kg Capacity Fire Extinguishers  
Complete
2. No. of Refills in hand and condition N/A
3. Fire Extinguishers for Hydraulic test All fire Extinguishers  
operated Tested and Refilled  
Found OK
4. Extinguishers failed during Hydraulic test N/A
5. Any new Fire Extinguishers/Refills required N/A

6. State person (s) present at the time of inspection / Testing ① Narendra Kaidan  
② Mohit Sahy ③ Jeewan Sahy ④ Mohan Lal Verma.

7. Have the Fire Extinguishers being used at any outbreak of fire since last inspection

Note :- fire Extinguishers Dummy Demonstrated



For, FIRE FREE ENGINEER'S

Admin Officer

Customer's Signature