

WORK ORDER REPORT #1023 - PREVENTIVE OVERHAUL

Section: Work Order Details

Work Order Number: WO-1023 | Asset Tag: P-101
Date Executed: 12 March 2024 | Lead Technician: M. Vance
Operating Hours at Service: 12,450 Hours
Scope: Scheduled 12,000-hour major preventive overhaul and inspection.
Actions Taken: Disassembled pump wet end and bearing cartridge.
Replaced Components: Drive-End Bearing (SKF 6312) and mechanical seal faces.
Installed new synthetic lubricant ISO VG 46 (2.4 L).
Test Run: Baseline vibration measured at 2.2 mm/s RMS. Return to service approved.