

CROSS-TRAIN FLUID TRANSFER REPORT — USER-TEST-001 & USER-TEST-002

Document Subject: Dual Asset Inspection & Performance Comparison

Primary Equipment Tags: USER-TEST-001 and USER-TEST-002

Facility: Main Pumping Complex — Unit 2

Inspection Date: 2026-09-05

Executive Findings:

This shared operational audit covers both USER-TEST-001 (Lead User Test Pump) and USER-TEST-002 (Standby Booster Pump).

During parallel transfer operations, USER-TEST-001 delivered 145 m³/h while USER-TEST-002 delivered 138 m³/h.

Pressure differential between USER-TEST-001 and USER-TEST-002 remained under 0.4 bar.

Both USER-TEST-001 and USER-TEST-002 require synchronized maintenance shutdown.