

Contents

CONTEXT steam_boiler_controller_context	2
CONTEXT steam_boiler_controller_context2	3
CONTEXT steam_boiler_controller_context3	4
MACHINE steam_boiler_controller	5
MACHINE steam_boiler_controller2	6
MACHINE steam_boiler_controller3	8

CONTEXT steam_boiler_controller_context

SETS

SteamBoiler

CONSTANTS

SB

AXIOMS

axm: $SB \in \text{SteamBoiler}$

axm1: $\text{SteamBoiler} = \{SB\}$

END

CONTEXT steam_boiler_controller_context2

EXTENDS steam_boiler_controller_context

SETS

Sensor

Actuator

Data_Set_1

Data_Set_2

Data_Set_3

CONSTANTS

SteamBoilerSensors

SteamBoilerActuators

Min1

Max1

Min2

Max2

degraded

normal

rescue

defective

nondefective

close

open

AXIOMS

axm0: $finite(SteamBoiler)$

axm1: $SteamBoilerSensors \in SteamBoiler \leftrightarrow Sensor$

axm2: $\forall x. (x \in Sensor \Rightarrow card(SteamBoilerSensors^{-1}[\{x\}]) = 1)$

axm3: $SteamBoilerActuators \in SteamBoiler \leftrightarrow Actuator$

axm4: $\forall x. (x \in Actuator \Rightarrow card(SteamBoilerActuators^{-1}[\{x\}]) = 1)$

axm5: $\{Min1, Max1, Min2, Max2\} \subseteq \mathbb{N}$

axm6: $partition(Data_Set_1, \{degraded\}, \{normal\}, \{rescue\})$

axm7: $partition(Data_Set_2, \{defective\}, \{nondefective\})$

axm8: $partition(Data_Set_3, \{close\}, \{open\})$

p1.1: $Min1 < Max1$

p1.2: $Min2 \leq Min1$

p1.3: $Max1 \leq Max2$

END

CONTEXT steam_boiler_controller_context3

EXTENDS steam_boiler_controller_context2

CONSTANTS

SU
 SteamUnit
 WU
 WaterUnit
 PC
 PumpController
 P
 Pump
 Controls

AXIOMS

axm0: $finite(Sensor) \wedge finite(Actuator)$
axm1: $\forall sb. (sb \in SteamBoiler \Rightarrow card(SteamBoilerActuators[\{sb\}]) = 1)$
axm2: $\forall sb. (sb \in SteamBoiler \Rightarrow card(SteamBoilerSensors[\{sb\}]) = 3)$
axm6: $partition(Sensor, WaterUnit, PumpController, SteamUnit)$
axm4: $SU \in SteamUnit$
axm5: $SteamUnit = \{SU\}$
axm7: $WU \in WaterUnit$
axm8: $WaterUnit = \{WU\}$
axm10: $PC \in PumpController$
axm11: $PumpController = \{PC\}$
axm12: $Pump \subseteq Actuator$
axm13: $P \in Pump$
axm14: $Pump = \{P\}$
axm15: $Controls \in Pump \mapsto PumpController$
axm16: $Controls = \{P \mapsto PC\}$
axm17: $SteamBoilerActuators = \{SB \mapsto P\}$
axm18: $SteamBoilerSensors = \{SB \mapsto WU, SB \mapsto SU, SB \mapsto PC\}$

END

```
MACHINE steam_boiler_controller
SEES steam_boiler_controller_context
VARIABLES
    waterLevel
INVARIANTS
    inv:  $waterLevel \in SteamBoiler \rightarrow \mathbb{N}$ 
EVENTS
Initialisation
    begin
        act:  $waterLevel : \in \{SB\} \rightarrow \mathbb{N}$ 
    end
Event ControlWaterLevel <ordinary>  $\hat{=}$ 
    any
        wlv1
    where
        grd:  $wlv1 \in \mathbb{N}$ 
    then
        act:  $waterLevel(SB) := wlv1$ 
    end
END
```

MACHINE steam_boiler_controller2**REFINES** steam_boiler_controller**SEES** steam_boiler_controller_context2**VARIABLES**

waterLevel
 operatingMode
 sensorState
 sensorInput
 actuatorState
 actuatorOutput

INVARIANTS

inv1: $operatingMode \in SteamBoiler \rightarrow Data_Set_1$
inv2: $sensorState \in Sensor \rightarrow Data_Set_2$
inv3: $actuatorState \in Actuator \rightarrow Data_Set_2$
inv4: $actuatorOutput \in Actuator \rightarrow Data_Set_3$
inv5: $sensorInput \in Sensor \rightarrow \mathbb{N}$
p1,4: $\forall sb. ((sb \in SteamBoiler \wedge operatingMode(sb) = normal) \Rightarrow waterLevel(sb) \in Min1..Max1)$
p1,5: $\forall sb. ((sb \in SteamBoiler \wedge operatingMode(sb) \in \{degraded, rescue\}) \Rightarrow waterLevel(sb) \in Min2..Max2)$
t1: $\langle \text{theorem} \rangle$
 $\forall wlv, values. (($
 $(wlv \in (\{TRUE \mapsto Min1..Max1, FALSE \mapsto Min2..Max2\})(bool(operatingMode(SB) = normal)))$
 $\wedge (values \in (SteamBoilerSensors[\{SB\}] \cap sensorState^{-1}[\{nondefective\}]) \rightarrow \mathbb{N})$
 $) \Rightarrow$
 $(wlv \in \mathbb{N})$
 $)$
t2: $\langle \text{theorem} \rangle$
 $(\forall mode. ($
 $(mode \in Data_Set_1)$
 $\wedge (waterLevel(SB) \in (\{TRUE \mapsto Min1..Max1, FALSE \mapsto Min2..Max2\})(bool(mode = normal))))$
 $) \Rightarrow$
 $(\exists wlv. (wlv \in \mathbb{N}))$
t3: $\langle \text{theorem} \rangle$
 $(\forall actions. ($
 $(actions \in (SteamBoilerActuators[\{SB\}] \cap actuatorState^{-1}[\{nondefective\}]) \rightarrow Data_Set_3)$
 $) \Rightarrow$
 $(\exists wlv. (wlv \in \mathbb{N}))$
t4: $\langle \text{theorem} \rangle$
 $\forall wlv, values, mode, actions. (($
 $(wlv \in (\{TRUE \mapsto Min1..Max1, FALSE \mapsto Min2..Max2\})(bool(operatingMode(SB) = normal)))$
 $\wedge (values \in (SteamBoilerSensors[\{SB\}] \cap sensorState^{-1}[\{nondefective\}]) \rightarrow \mathbb{N})$
 $\wedge (mode \in Data_Set_1)$
 $\wedge (waterLevel(SB) \in (\{TRUE \mapsto Min1..Max1, FALSE \mapsto Min2..Max2\})(bool(mode = normal)))$
 $\wedge (actions \in (SteamBoilerActuators[\{SB\}] \cap actuatorState^{-1}[\{nondefective\}]) \rightarrow Data_Set_3)$
 $) \Rightarrow$
 $(wlv = wlv)$
 $)$

EVENTS**Initialisation****begin**

act1: $waterLevel := \{SB \mapsto Min1\}$
act2: $operatingMode := \{SB \mapsto normal\}$
act3: $sensorState := Sensor \times \{nondefective\}$
act4: $actuatorState := Actuator \times \{nondefective\}$
act5: $actuatorOutput : \in Actuator \rightarrow Data_Set_3$
act6: $sensorInput : \in Sensor \rightarrow \mathbb{N}$

```

    end
Event ReadInputs  $\langle \text{ordinary} \rangle \hat{=}$ 
refines ControlWaterLevel
    any
        wlv1
        values
    where
        grd1:  $wlv1 \in (\{TRUE \mapsto Min1 .. Max1, FALSE \mapsto Min2 .. Max2\})(bool(operatingMode(SB) =$ 
             $normal))$ 
        grd2:  $values \in (SteamBoilerSensors[\{SB\}] \cap sensorState^{-1}[\{nondefective\}]) \rightarrow \mathbb{N}$ 
    then
        act1:  $waterLevel(SB) := wlv1$ 
        act2:  $sensorInput := sensorInput \Leftarrow values$ 
    end
Event ComputeNextSystemMode  $\langle \text{ordinary} \rangle \hat{=}$ 
    any
        mode
    where
        grd1:  $mode \in Data\_Set\_1$ 
        grd2:  $waterLevel(SB) \in (\{TRUE \mapsto Min1 .. Max1, FALSE \mapsto Min2 .. Max2\})(bool(mode =$ 
             $normal))$ 
    then
        act:  $operatingMode(SB) := mode$ 
    end
Event SendActionCommand  $\langle \text{ordinary} \rangle \hat{=}$ 
    any
        actions
    where
        grd:  $actions \in (SteamBoilerActuators[\{SB\}] \cap actuatorState^{-1}[\{nondefective\}]) \rightarrow Data\_Set\_3$ 
    then
        act2:  $actuatorOutput := actuatorOutput \Leftarrow actions$ 
    end
END

```

MACHINE steam_boiler_controller3

REFINES steam_boiler_controller2

SEES steam_boiler_controller_context3

VARIABLES

waterLevel
operatingMode
sensorState
sensorInput
actuatorState
actuatorOutput

INVARIANTS

p2,1: $sensorState(WU) = defective \Rightarrow operatingMode(SB) = rescue$

p2,2: $(sensorState(WU) = nondefective \wedge defective \in sensorState[\{SU, PC\}] \cup actuatorState[\{P\}]) \Rightarrow operatingMode(SB) = degraded$

p2,3: $(sensorState[\{WU, PC, SU\}] = \{nondefective\} \wedge actuatorState(P) = nondefective) \Rightarrow operatingMode(SB) = normal$

EVENTS

Initialisation

begin

act1: $waterLevel := \{SB \mapsto Min1\}$
act2: $operatingMode := \{SB \mapsto normal\}$
act3: $sensorState := Sensor \times \{nondefective\}$
act4: $actuatorState := Actuator \times \{nondefective\}$
act5: $actuatorOutput : \in Actuator \rightarrow Data_Set_3$
act6: $sensorInput : \in Sensor \rightarrow \mathbb{N}$

end

Event ReadWaterUnit $\langle ordinary \rangle \hat{=}$

refines ReadInputs

any

wlvl
values
val

where

grd0: $sensorState(WU) = nondefective$
grd1: $val \in \mathbb{N}$
grd2: $values = \{WU \mapsto val\}$
grd3: $wlvl = values(WU)$
grd4: $wlvl \in (\{TRUE \mapsto Min1 .. Max1, FALSE \mapsto Min2 .. Max2\})(bool(operatingMode(SB) = normal))$

then

act1: $waterLevel(SB) := wlvl$
act2: $sensorInput := sensorInput \Leftarrow values$

end

Event ReadInputsInRescueMode $\langle ordinary \rangle \hat{=}$

refines ReadInputs

any

wlvl
values
val1
val2

where

grd0: $sensorState(WU) = defective \wedge sensorState[\{SU, PC\}] = \{nondefective\}$
grd1: $\{val1, val2\} \subseteq \mathbb{N}$
grd2: $values = \{SU \mapsto val1, PC \mapsto val2\}$
grd3: $wlvl \in Min2 .. Max2$

then


```

    act1: waterLevel(SB) := wlv
    act2: sensorInput := sensorInput  $\Leftarrow$  values
  end
Event ComputeNextSystemMode  $\langle$ ordinary $\rangle \hat{=}$ 
refines ComputeNextSystemMode
  any
    mode
  where
    grd1: mode  $\in$  Data_Set.1
    grd2: waterLevel(SB)  $\in$  ( $\{TRUE \mapsto Min1 .. Max1, FALSE \mapsto Min2 .. Max2\}$ )(bool(mode =
      normal))
    grd3: sensorState(WU) = defective  $\Rightarrow$  mode = rescue
    grd4: (sensorState(WU) = nondefective  $\wedge$  defective  $\in$  sensorState[{SU, PC}]  $\cup$  actuatorState[{P}])  $\Rightarrow$ 
      mode = degraded
    grd5: (sensorState[{WU, PC, SU}] = {nondefective}  $\wedge$  actuatorState(P) = nondefective)  $\Rightarrow$ 
      mode = normal
  then
    act: operatingMode(SB) := mode
  end
Event OpenPump  $\langle$ ordinary $\rangle \hat{=}$ 
refines SendActionCommand
  any
    actions
  where
    grd0: waterLevel(SB) < ( $\{TRUE \mapsto Max1, FALSE \mapsto Max2\}$ )(bool(operatingMode(SB) =
      normal))
    grd1: actions  $\in$  (SteamBoilerActuators[{SB}]  $\cap$  actuatorState-1[{nondefective}])  $\rightarrow$  {open}
  then
    act2: actuatorOutput := actuatorOutput  $\Leftarrow$  actions
  end
Event ClosePump  $\langle$ ordinary $\rangle \hat{=}$ 
refines SendActionCommand
  any
    actions
  where
    grd0: waterLevel(SB) > ( $\{TRUE \mapsto Min1, FALSE \mapsto Min2\}$ )(bool(operatingMode(SB) =
      normal))
    grd1: actions  $\in$  (SteamBoilerActuators[{SB}]  $\cap$  actuatorState-1[{nondefective}])  $\rightarrow$  {close}
  then
    act2: actuatorOutput := actuatorOutput  $\Leftarrow$  actions
  end
END

```