

TABLE 3.3.2-2
ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>Primary Containment Isolation Signals (Continued)</u>		
a. Reactor Vessel Water Level*		
1) Low, Low, Low, Level 1	≥ 17.8 in.	≥ 10.8 in.
2) Low, Low, Level 2	≥ 108.8 in.	≥ 101.8 in.
3) Low, Level 3	≥ 159.3 in.	≥ 157.8 in.
b. Drywell Pressure - High	≤ 1.68 psig	≤ 1.88 psig
c. Main Steam Line		
1) Radiation - High	$\leq 3 \times$ Full Power Background	$\leq 3.6 \times$ Full Power Background
2) Pressure - Low	≥ 766 psig	≥ 746 psig
3) Flow - High	≤ 103 psid	≤ 109.5 psid
d. Main Steam Line Tunnel		
1) Temperature - High	$\leq 165.7^{\circ}\text{F}$	$\leq 169.9^{\circ}\text{F}$
2) Δ Temperature - High	$\leq 66.7^{\circ}\text{F}$	$\leq 71.3^{\circ}\text{F}$
3) Temperature - High MSL Lead Enclosure	$\leq 146.7^{\circ}\text{F}$	$\leq 150.9^{\circ}\text{F}$
e. Condenser Vacuum Low	≥ 8.5 in Hg vacuum	≥ 7.6 in. Hg vacuum
f. RHR Equipment Area Temperature - High (HXs/A&B Pump Rooms)	$\leq 135^{\circ}\text{F}$	$\leq 144.5^{\circ}\text{F}$
g. Reactor Vessel Pressure - High (RHR Cut-in Permissive)	≤ 128 psig	≤ 148 psig
h. SGTS Exhaust - High Radiation	$\leq 5.7 \times 10^{-3}$ $\mu\text{Ci/cc}$	$\leq 1.0 \times 10^{-2}$ $\mu\text{Ci/cc}$