

Computational and Mathematical Organization Theory

A novel optimization framework for optimal sensor deployment in smart buildings

--Manuscript Draft--

Manuscript Number:	
Full Title:	A novel optimization framework for optimal sensor deployment in smart buildings
Article Type:	Manuscript
Keywords:	Smart Buildings; Sensor Deployment; Optimization Framework; Baseline Approach; Sensor Reduction
Corresponding Author:	Anshul Agarwal, Ph.D. Indian Institute of Technology Bombay Department of Computer Science and Engineering Mumbai, Maharashtra INDIA
Corresponding Author Secondary Information:	
Corresponding Author's Institution:	Indian Institute of Technology Bombay Department of Computer Science and Engineering
Corresponding Author's Secondary Institution:	
First Author:	Anshul Agarwal, Ph.D.
First Author Secondary Information:	
Order of Authors:	Anshul Agarwal, Ph.D. Krithi Ramamritham
Order of Authors Secondary Information:	
Funding Information:	
Suggested Reviewers:	David Culler University of California Berkeley culler@cs.berkeley.edu Expert in the relevant field Prashant Shenoy University of Massachusetts Amherst shenoy@cs.umass.edu Expert in the relevant field Kamin Whitehouse University of Virginia whitehouse@virginia.edu Expert in the relevant field Yuvraj Agarwal Carnegie Mellon University yuvraj@cs.cmu.edu Expert in the relevant field

A novel optimization framework for optimal sensor deployment in smart buildings

Anshul Agarwal^{1,*} and Krithi Ramamritham¹

¹Smart Energy Informatics Lab (SEIL), Department of Computer Science and Engineering, Indian Institute of Technology (IIT) Bombay, Maharashtra, India.

***Corresponding Author**

Dr. Anshul Agarwal

Address: Smart Energy Informatics Lab (SEIL), SIC-213, KReSIT, Department of Computer Science and Engineering, Indian Institute of Technology (IIT) Bombay, Maharashtra, India.

Pin code: 400076

Email id: a.anshul215@gmail.com; anshula@iitb.ac.in

A novel optimization framework for optimal sensor deployment in smart buildings

Received: date / Accepted: date

Abstract Smart buildings are considered to be the new age buildings. They are expected to evolve continuously and provide intelligent solutions. This is achieved by sensing the different factors of the building. The existing approaches overlook the problems associated with the deployment of a large number of sensors. However, this article presents a novel and holistic optimal sensor deployment method – an optimization framework for sensing different factors to make buildings smarter. It describes how intelligently using the existing information can lead to a reduction in sensors. The optimization framework is compared with the baseline approach, which deploys sensors at all the locations where they should be sensed, for an existing building. The results indicate that the newly developed optimization framework requires 72.92% less sensors as compared to the baseline approach. This feature makes it an impressive proposition and results in lesser in e-waste generation.

Keywords Smart Buildings · Sensor Deployment · Optimization Framework · Baseline Approach · Sensor Reduction

1 Introduction

Internet of Things (IoT) and Cyber-Physical Systems (CPS) are the two very commonly heard terms nowadays. Due to the advent of these technologies, buildings have evolved from being intelligent to becoming smarter. A smart building is expected to fulfill tasks like monitoring the health of appliances, provide thermal comfort to the users (Reena et al., 2018), track occupants in the building, and optimize and reduce the wastage of energy (Karmakar et al., 2018). However, fulfilling these tasks requires sensing of factors such as energy consumption, occupancy and type of appliances that are switched ON. Therefore, it is important to deploy sensors in the building to sense these

Address(es) of author(s) should be given

factors of interest (Agarwal et al., 2016a). There exist various techniques for placement of sensors in the buildings to sense different factors (Bellala et al., 2012; Meyn et al., 2009). However, these techniques do not consider the issues related to the deployment of a large number of sensors, such as increased user inconvenience and capital cost of procuring, installing, maintaining and upgrading the sensors, disturbing the aesthetics of the building, incremental investment on storage and communication facilities for the sensors and threat to privacy (Hnat et al., 2011; Stankovic, 2014). The most worrying drawback of these techniques is the increased generation of e-waste. In 2016, the CEO of SoftBank Group Corporation estimated that there would be at least a trillion connected devices around the world in the next 20 years (The Internet of Trash: IoT Has a Looming E-Waste Problem, 2018). Therefore, the existing techniques fail to provide effective solutions with sensor minimization as an important parameter. In fact, rapid research in data mining, algorithms, and machine/deep learning approaches has led to efficient techniques for processing large amounts of sensor data. This encourages the approach of throwing sensors at the problem so that large amounts of data are generated and can be processed to provide smart applications and experience.

The objective of this article is to provide an approach that reduces the number of sensors that should be deployed to overcome the various issues related to the deployment of a large number of sensors in a smart building. The major contribution of this article is a novel and holistic approach to optimal sensor deployment in buildings to make it smarter by sensing the factors of interest. It uses soft sensing which implies inferring a factor from other set of factors; for instance, Ciftler et al. (2018) demonstrated how occupancy can be inferred in the buildings using the Wi-Fi signal information. Soft sensing defines how existing information can be intelligently used to infer the factors of interest, and thus used as a primary tool to reduce the number of sensors to be deployed. The effectiveness of this approach is tested on a real-world problem of sensor deployment in an existent building to make it smarter and demonstrate an impressive reduction in sensors.

2 Literature Review

This article presents (a) a holistic optimization framework for making buildings smarter (b) seamless deployment of hard and soft sensors and (c) utilizing a minimum number of sensors and deploying them at the right places in a building. A survey of the work done in these and related areas is presented in this section.

Integration of Internet of Things (IoT) with buildings has led to buildings becoming smarter. One of the challenges in smart buildings is the storage and analysis of real-time sensor data (Zanella et al., 2014; El-Shafie and Fakeih, 2018). Bashir and Gill (2016) proposed a technique for the integration of big data analytics and IoT for effectively dealing with real-time building sensor data. Stojkoska and Trivodaliev (2017) described a holistic framework for in-

tegrating smart home objects into a cloud-centric framework. Minoli et al. (2017) discussed the various practical challenges faced by IoT in smart buildings. Pan et al. (2015) proposed an IoT framework that used smartphone and cloud platforms for saving energy and improving the home network intelligence. Hernández-Ramos et al. (2015) proposed an ARM compliant security framework using IoT. Ghayvat et al. (2015) discussed how wellness of the home residents is monitored to determine if they are fine and extended this approach to the smart building environment.

Buildings play an important role in efficient functioning of electric grids. It is important for building to not impose higher loads on the electric grids, since they have other factors that bring in uncertainties like renewable energy sources, dispatchable resources and storage devices (Tao et al., 2019). Gross and Finlay (2000) have proposed a novel framework for the analysis of bids in competitive electricity market. Supplying electricity to remote areas requires optimal sizing of hybrid renewable energy systems (HRES) such that load requirements are satisfied with high reliability and low cost (Eltamaly et al., 2017). To minimize the total energy and operating cost of the micro-grid, an efficient algorithm based on particle swarm optimization is proposed by Radosavljević et al. (2016).

There exist multiple works that discuss inferring a factor from other sets of factors (Agarwal et al., 2016b; Balaji et al., 2013). Using virtual sensors to abstract hard sensors for programmatically specifying high-level requirements has been described by Kabadayi et al. (2006). Using Wi-Fi signals to infer the occupancy status and information has been demonstrated by Ciftler et al. (2018); Thanayankizil et al. (2012). Occupancy prediction using CO_2 based physical and statistical modeling has been investigated by Zuraimi et al. (2017). Salimi et al. (2019) proposed an adaptive probabilistic occupancy prediction model. Ekwevugbe et al. (2012) discussed a low cost and non-intrusive method for sensor network deployment to combine information such as sound level, appliance case temperature, CO_2 and motion. Using inference models like support vector regression and ensemble models to manage building power is discussed by Bellala et al. (2017). A network of sensors and cloud infrastructure can be used to monitor different behaviour inside homes as discussed by Mora et al. (2018). The work uses different soft sensing approaches to infer different behavioural patterns. Barker et al. (2019) have proposed a virtual power meter, an example of a soft sensor, for online load tracking. Iyengar et al. (2017) have proposed a soft sensor model called as SolarCast for predicting solar power for smart homes. Ujager and Mahmood (2019) have discussed a type of soft sensor context-aware accurate wellness determination (CAAWD) for estimating the wellness of elderly people in homes. A review article is presented by Li et al. (2019) to discuss modeling of occupancy behaviour and its effect on building performance. Learning about occupants and their sleep patterns to optimally operate HVACs has been described by Lu et al. (2010). These work utilize various soft sensing approaches to infer different behavioural patterns. But these soft sensing approaches are not holistic since they aim to sense only one kind of factor. To understand the behaviour of the buildings, the factors

such as energy consumption, occupancy, appliance information and air quality are sensed individually in the existing literature. The optimization framework proposed in this article emphasizes that factors should be monitored in conjunction with each other to reduce the number of sensors to be deployed and obtain a better perspective about the building functioning.

Chang et al. (2011) proposes a solution for achieving observability by optimally deploying sensors in nodes by formulating it as an optimization problem. Even though it reduces the number of sensors to be allocated, it does not present a holistic approach for sensing multiple factors at different granules of a building, unlike the optimization framework proposed in this article. Bellala et al. (2012); Meyn et al. (2009) sense factors using only physical sensors and ignore the problems associated with deployment of large number of sensors. Agarwal et al. (2016b) proposed a technique for reducing the number of sensors for sensing building factors. But the solution, unlike the proposed approach of this article, does not provide solutions with optimal allocation of sensors. Pre-deployment strategies with respect to sensors are discussed by Krause et al. (2006). But it demands a prerequisite knowledge about the outdoor area statistics beforehand. Prakash et al. (2015) proposed a smartmeter allocation method to sense power consumption of building. But it considers only smartmeter sensors, and thus fail to provide a generic minimum sensor allocation strategy.

A popular approach to represent building metadata has been proposed by Balaji et al. (2016). It discusses an improved technique for preparing a uniform schema to represent building metadata. But this approach contains a drawback; it assumes that sensors are already deployed in an intelligent way, and thus, does not propose any efficient technique for allocating the sensors. Therefore, the optimization framework proposed in this article can be added as a layer of optimal sensor deployment technique in this framework, enhancing it to be more holistic and pragmatic .

The problem of sensing building factors with reduced sensors is similar to observing the electric grid using minimum number of Phasor Measurement Unit (PMU) sensors. PMUs sensors help to estimate the state of electric grid by measuring line parameters like voltage and current phasors (Phadke, 1993), which leads to observability of the grid. The electric grid is represented as a graph, where the set of nodes represent buses (power generation centers or electric substations) of electric grids, and the edges of the graph correspond to the transmission lines between the the buses. It is not desirable to install PMUs on all the nodes to observe state of the grid since they are expensive sensors (Ree et al., 2010). Therefore, the goal is to deploy reduced number of PMU sensors in the electric grid. Numerous work has been done on developing solutions for placing minimum PMUs in the grid to achieve observability (Noureen et al., 2017; Manousakis et al., 2012). Optimal PMU placement for observing the grid is NP-Complete as proven by Gyllstrom et al. (2012). Formulating optimal PMU placement as an optimization problem is discussed by Dua et al. (2008); Abur and Magnago (1999); Xu and Abur (2004). Comparing this problem with the goal tackled in this article, the optimal PMU placement

problem considers only a single type of sensor (PMU). In addition, it primarily focuses on sensing only one factor, that is voltage, since current value is obtained using Ohm's Law and Kirchhoff's laws. Thus, this is a relatively simple problem where only one sensor and one factor is considered. On the other hand, the proposed optimization framework of this article provides a holistic solution which deals with sensing multiple factors using a set of heterogeneous type of sensors, while ensuring that a minimum number of sensors are deployed in the building.

3 Methodology

In this article, a new optimization framework has been developed for optimal sensor deployment. This optimization framework outputs the optimal number, type, and location of sensors such that required factors are sensed in the smart buildings.




Fig. 1 Block diagram summarizing the proposed approach


A block diagram to summarize the proposed optimization framework has been demonstrated in Figure 1. Details of the various inputs and symbols given to the framework and the output produced by it are described in Table 1.

3.1 Application Area

For the application of optimization framework, a classroom building, in the Computer Science and Engineering Department, IIT Bombay (India) was selected. The building consists of one HVAC room and two levels. Each level consists of one small and one big room as shown in Figure 2. Each big room was divided into two zones to sense different factors. A separate location for the HVAC room is denoted since it provides common cooling to all the rooms of the building and consumes a very high amount of energy.

Table 1 Description of different symbols used in the optimization framework

Input	Description
$\{L\}$	set of locations where factors are required to be sensed like rooms, levels and wings of the building
$\{K\}$	set of factors to be sensed in the building like occupancy and temperature
$\{s^k\}$	set of hard sensors to sense factors, where s_i^k denotes sensor s_i that senses factor k . For example, passive infrared sensors (PIR) and camera are used to sense occupancy
$limit(s_i^k)$	denotes the limit on the number of sensors of type s_i^k that can be deployed for sensing factor k . For example, $limit(smartmeter) = 2$ implies that a maximum of 2 smartmeters can be deployed to sense power
$tosense(l, k)$	outputs a value 1 if factor k should be sensed at location l ; 0 otherwise
Output	Description
$used(l, k, s_i^k)$	outputs a value 1 if sensor s_i^k is allocated in location l to sense factor k ; 0 otherwise
$sensed(l, k)$	outputs a value 1 if factor k is sensed in location l ; 0 otherwise

**Fig. 2** Hierarchical representation of the application area building

3.2 Optimization Framework

It consists of an objective function and set of constraint functions which are described as follows.

3.2.1 Objective Function

Equation (1) is used to specify the aim of deploying minimum number of sensors in the building to sense factors.

$$\text{minimize } \sum_{l \in \{L\}} \sum_{k \in \{K\}} \sum_{s \in \{s^k\}} \text{used}(l, k, s) \quad (1)$$

3.2.2 Constraint Functions

◇ Sensing Requirement: It denotes the set of factors that should be sensed in different locations of the smart building. This requirement is specified by $\text{tosense}(l, k)$ matrix. The constraint specified by Equation (2) ensures that the set of factors sensed (denoted by sensed matrix) due to the final optimal sensor allocation is in agreement with the sensing requirements of the smart building.

$$\forall l \in \{L\} \quad \forall k \in \{K\} \quad \text{sensed}(l, k) = \text{tosense}(l, k) \quad (2)$$

◇ Sensing Rules: A hard sensor denotes a physical sensor like smartmeter and temperature sensor. A soft sensor is defined as a model that infers a factor from the set of other available factors. An example of a soft sensor is inferring power consumption from temperature and time of the day (Agarwal et al., 2016b). Soft sensors can be used to reduce the number of hard sensors given the type of information available in a location. The following set of rules specify if the factors are sensible for a given allocation of sensors:

Rule 1: If a hard sensor s_i^k is allocated in location l , then the factor k is sensible in location l . This rule is denoted by Equation (3).

$$\forall l \in \{L\} \quad \forall k \in \{K\} \quad \text{sensed}(l, k) = \sum_{s \in \{s^k\}} \text{used}(l, k, s) \quad (3)$$

Rule 2: If a soft sensor, that infers factor k from others factors $\{k_i\}$, is allocated in location l and factors $\{k_i\}$ are sensible in location l , then the factor k is sensible in location l . This rule is denoted by Equation (4).

$$\forall l \in \{L\} \quad \forall k \in \{K\} \quad \text{sensed}(l, k) = \prod_{j \in \{k_i\}} \text{sensed}(l, j) \quad (4)$$

Combining Equations (3) and (4), the constraint specifying the sensing rules is denoted by Equation (5) as follows:

$$\forall l \in \{L\} \quad \forall k \in \{K\} \quad \text{sensed}(l, k) = \max \left(\sum_{s \in \{s^k\}} \text{used}(l, k, s), \prod_{j \in \{k_i\}} \text{sensed}(l, j) \right) \quad (5)$$

◇ Sensing from sub-locations: A location may be composed of sub-locations or relatively small locations (Figure 2). Let the set of sub-locations of a location l be represented by $\{subl^l\}$. This constraint states that if a factor k that is sensible in all the sub-locations of a location l , then the factor k is also sensible at location l . For example, consider a room that consists of two zones. If the power consumption of these zones is sensed, then aggregating these values will produce the total power of the room. This constraint is represented by Equation (6) as follows:

$$\forall l \in \{L\} \quad \forall k \in \{K\} \quad sensed(l, k) = \max \left(\sum_{s \in \{s^k\}} used(l, k, s), \prod_{sub \in \{subl^l\}} sensed(sub, k) \right) \quad (6)$$

◇ Limiting the sensors: $limit(s_i^k)$ represents the maximum number of sensors of type s_i sensing factor k that can be deployed in the building. The constraint denoted by Equation (7) ensures that the total number of sensors s_i^k deployed in the optimal sensor allocation does not exceed the provided limit.

$$\forall k \in \{K\} \quad \forall s \in \{s^k\} \quad \left(\sum_{l \in \{L\}} used(l, k, s) \right) \leq limit(s) \quad (7)$$

4 Results and Discussion

A smart building provides thermal comfort at optimum power consumption based on the occupancy in different building locations using minimum number of sensors. It can be achieved by detecting occupancy, monitoring power and temperature, and accordingly automating the appliances. To fulfill these tasks, four primary factors need to be sensed: power consumption, number and type of ON appliances, occupancy and temperature of the rooms.

4.1 Inputs used for optimal sensor allocation

- Set of Locations $\{L\}$: as represented in Figure 2.
- Factors to Sense: power consumption, number and type of ON appliances, occupancy and temperature.
- Type of Sensors: used to sense the above factors as shown in Table 2.
- Sensing Requirement: All the factors in all the locations, except HVAC room (H), should be sensed. This requirement is specified using Equation (8) as follows:

$$\forall l \in \{L \setminus H\} \quad \forall k \in \{K\} \quad tosense(l, k) = 1 \quad (8)$$

Table 2 List of sensors for sensing different factors

Sensor Type	Power Consumption	Number and Type of ON Appliances	Occupancy	Temperature
Hard Sensor	Smartmeter	Smart Switch	PIR (passive infrared), Camera	Temperature sensor
Soft Sensor (infer from factors)	Number of ON appliances	Occupancy and Temperature	-	-

In HVAC room H , only power consumption should be sensed since the room is never occupied, and sensing other factors is not meaningful. It is specified by Equation (9) as follows:

$$\begin{aligned} \text{tosense}(H, \text{power}) &= 1, \\ \forall k \in \{K \setminus \text{power}\} \quad \text{tosense}(L^H, k) &= 0 \end{aligned} \quad (9)$$

4.2 Output

The optimization framework has been implemented in python library PuLP (Mitchell et al., 2011) which is used for solving linear programs. After the inputs are provided to the optimization framework, it implements the objective function Equation (1) and constraint functions (Equation (2) – (7)) to output the optimal sensor allocation for the application area, whose details are summarized in Table 3 and Table 4.

Table 3 *sensed* matrix denoting the factors that are sensible in different locations

Locations	Power	ON Appliances	Occupancy	Temperature
Building B	1	1	1	1
Level L_1	1	1	1	1
Level L_2	1	1	1	1
HVAC room H	1	0	0	0
Small Room SR_1	1	1	1	1
Big Room BR_1	1	1	1	1
Zone Z_{11}	1	1	1	1
Zone Z_{12}	1	1	1	1
Small Room SR_2	1	1	1	1
Big Room BR_2	1	1	1	1
Zone Z_{21}	1	1	1	1
Zone Z_{22}	1	1	1	1

Observing the *sensed* matrix (Table 3), it can be concluded that the sensing requirement of sensing all the factors in all the locations, except HVAC room, is satisfied by the optimization framework. In HVAC room, only power consumption is observed. The details of optimal sensor allocation for satis-

Table 4 *used* matrix denoting the details of sensor allocation

Locations	Power	ON Appliances	Occupancy		Temperature
	Smartmeter	Smart Switch	PIR	Camera	Temperature Sensor
Building B	0	0	0	0	0
Level L_1	0	0	0	0	0
Level L_2	0	0	0	0	0
HVAC room H	1	0	0	0	0
Small Room SR_1	0	0	1	0	1
Big Room BR_1	0	0	0	0	0
Zone Z_{11}	0	0	1	0	1
Zone Z_{12}	0	0	1	0	1
Small Room SR_2	0	0	1	0	1
Big Room BR_2	0	0	0	0	0
Zone Z_{21}	0	0	1	0	1
Zone Z_{22}	0	0	1	0	1

fying the sensing requirements is denoted by *used* matrix (Table 4) and are explained as follows.

- Since no soft sensor is available to sense temperature (Table 2), two hard sensors are used to sense the temperature in two small rooms (one for each room) and four sensors for big rooms (one for each zone). In big rooms, the temperature is sensible since temperature of the zones is sensed (Equation (6)). Similarly, the temperature of levels and the building becomes sensible. Thus, a total of six temperature sensors are deployed.
- Occupancy is sensed either by placing a Passive infrared (PIR) sensor or a camera in two small rooms (one for each room) and two big rooms (one for each zone). No soft sensor is used since occupancy cannot be inferred from the other factors in these locations. Using Equation (6), occupancy of big rooms, levels and the building becomes sensible. Therefore, a total of six PIR + camera sensors are deployed.
- Information of ON appliances can be inferred from occupancy and temperature using a soft sensor (Table 2). Since all the locations already sense temperature and occupancy, the number and type of ON appliances is sensed using the soft sensor (Equation (5)). Therefore, no hard sensor is deployed to sense this factor.
- In the HVAC room, only one smartmeter is allocated to sense power consumption since no other factor is sensed at this location. In all the remaining locations, power consumption is inferred from number and type of ON appliances information using a soft sensor (Equation (5)).

Therefore, to sense the factors in all the locations of the building, only 13 sensors are required as tabulated in Table 5.

Table 5 Sensor allocation for sensing the factors using the optimization framework

Type of Hard Sensor	Location	Number of Sensors Allocated
Temperature Sensor	$SR_1, Z_{11}, Z_{12}, SR_2, Z_{21}, Z_{22}$	6
PIR or Camera	$SR_1, Z_{11}, Z_{12}, SR_2, Z_{21}, Z_{22}$	6
Smart Switch	–	–
Smartmeter	HVAC Room (H)	1
Total		13

However, the effectiveness of the proposed optimization framework is compared with baseline approach for sensor deployment at the same application area. The baseline approach consists of deploying appropriate sensors for all the factors in all the locations where they should be sensed. For example, to sense power, ON appliances, occupancy, and temperature at all the location of the building (Figure 2), four sensors (one for each factor) is deployed in all the locations, leading to the deployment of 48 sensors as shown in Table 6.

Table 6 Sensor allocation for sensing the factors using the baseline approach

Type of Hard Sensor	Location	Number of Sensors Allocated
Temperature Sensor	$B, L_1, SR_1, BR_1, Z_{11}, Z_{12}, L_2, SR_2, BR_2, Z_{21}, Z_{22}, H$	12
PIR or Camera	$B, L_1, SR_1, BR_1, Z_{11}, Z_{12}, L_2, SR_2, BR_2, Z_{21}, Z_{22}, H$	12
Smart Switch	$B, L_1, SR_1, BR_1, Z_{11}, Z_{12}, L_2, SR_2, BR_2, Z_{21}, Z_{22}, H$	12
Smartmeter	$B, L_1, SR_1, BR_1, Z_{11}, Z_{12}, L_2, SR_2, BR_2, Z_{21}, Z_{22}, H$	12
Total		48

Therefore, it can be concluded that the newly developed optimization framework is highly effective as compared to the baseline approach. This is because, to satisfy the same sensing requirements, the baseline approach needs 48 sensors while the newly developed optimization framework requires only 13 sensors, which is about 72.9% savings in the number of sensors to be deployed.

This impressive reduction demonstrates how practical the proposed technique is and should be used as a primary tool for sensing factors when developing smart cities and buildings. For example, if this methodology is used for a smart city consisting of one thousand smart buildings of the same size and design (as described in the application area), it will require only thirteen thousand sensors while the baseline approach will require forty-eight thousand sensors, resulting into a net savings of thirty-five thousand sensors. However, in the semi-smart buildings, sometimes it is required to sense only one or two parameters. For example, it may be required to sense only the number of ON appliances at any one time or total power consumption of the building. Un-

Table 7 Sensor allocation for satisfying different sensing requirements

Sensing Requirement	Baseline Approach		Optimization Framework	
	Number of Sensors	Description	Number of Sensors	Description
Sense power consumption (using smartmeters)	12 (smartmeters)	Smartmeters are allocated on all the nodes	7 (smartmeters)	Smartmeters allocated only on leaf nodes
Sense power consumption(temperature and occupancy information is already available)	12 (smartmeters)	Smartmeters are allocated on all the nodes	1 (smartmeter)	1 smartmeter allocated in HVAC room and power inferred from temperature and occupancy in other locations
Sense number of ON appliances using smart switches	12 (smart switch sensors)	Smart switches are allocated on all the nodes	7 (smart switch sensors)	Smart switches allocated only on leaf nodes
Sense number of ON appliances (temperature and occupancy information is already available)	12 (smart switch sensors)	Smart switches are allocated on all the nodes	0	ON appliances inferred from temperature and occupancy in all the locations

der all such scenarios, Table 7 summarizes that the developed optimization framework is very effective as compared to the baseline approach.

It is depicted from Table 7 that for sensing the number of ON appliances, twelve smart switch sensors are required by using the baseline approach. However, using the newly developed optimization framework, only seven smart switch sensors are required. If the information about temperature and occupancy is available, then the optimization framework allocates only one smart switch sensor. Similarly to measure the power consumption, twelve and seven smartmeters are required using the baseline approach and optimization framework, respectively. In presence of temperature and occupancy information, the optimization framework does not deploy any smart switch sensors. Therefore, the newly developed optimization framework is an effective tool to reduce the number of sensors required to make buildings smarter.

5 Conclusion

Various factors such as power consumption, number and type of ON appliances, occupancy and temperature can be sensed using a minimum number of sensors. This can be achieved by using the newly developed optimization framework which is an effective tool to reduce the number of sensors required to sense various factors in a smart building. This optimization framework has been compared with the baseline approach and results are found to be very

encouraging. When this technique is applied to an existing building, it requires 72.92% less sensors as compared to the baseline approach. This feature makes it an impressive proposition and leads to a large reduction in e-waste generation. However, if this approach is extended to a smart city, it will not only result in huge savings of sensors, but also lead to huge reduction in e-waste generation. Therefore, it can be concluded that if the existing information is used intelligently, it will lead to a reduction in sensors.

References

- Abur A, Magnago FH (1999) Optimal meter placement for maintaining observability during single branch outages. *IEEE Transactions on Power Systems* 14(4):1273–1278, DOI 10.1109/59.801884
- Agarwal A, Jaiswal K, Gudhaka U, Munigala V, Ramamritham K, Karmakar G (2016a) Observability-driven sensor deployment in smart academic environments: Demo abstract. In: *Proceedings of the 14th ACM Conference on Embedded Network Sensor Systems, SenSys 2016, Stanford, CA, USA, November 14-16, 2016*, pp 328–329, DOI 10.1145/2994551.2996546, URL <http://doi.acm.org/10.1145/2994551.2996546>
- Agarwal A, Munigala V, Ramamritham K (2016b) Observability: replacing sensors with inference engines. In: *Proceedings of the Seventh International Conference on Future Energy Systems, Waterloo, ON, Canada, June 21 - 24, 2016 - Poster Sessions*, pp 9:1–9:2, DOI 10.1145/2939912.2942356, URL <http://doi.acm.org/10.1145/2939912.2942356>
- Balaji B, Xu J, Nwokafor A, Gupta R, Agarwal Y (2013) Sentinel: Occupancy based hvac actuation using existing wifi infrastructure within commercial buildings. In: *Proceedings of the 11th ACM Conference SenSys '13, ACM, New York, NY, USA*, pp 17:1–17:14, URL <http://doi.acm.org/10.1145/2517351.2517370>
- Balaji B, Bhattacharya A, Fierro G, Gao J, Gluck J, Hong D, Johansen A, Koh J, Ploennigs J, Agarwal Y, Berges M, Culler D, Gupta R, Kjær-gaard MB, Srivastava M, Whitehouse K (2016) Brick: Towards a unified metadata schema for buildings. In: *Proceedings of the 3rd ACM International Conference BuildSys '16, ACM, New York, NY, USA*, pp 41–50, URL <http://doi.acm.org/10.1145/2993422.2993577>
- Barker S, Kalra S, Irwin D, Shenoy P (2019) Building virtual power meters for online load tracking. *ACM Trans Cyber-Phys Syst* 3(2):23:1–23:24, DOI 10.1145/3303860, URL <http://doi.acm.org/10.1145/3303860>
- Bashir MR, Gill AQ (2016) Towards an iot big data analytics framework: Smart buildings systems. In: *2016 IEEE 18th International Conference on High Performance Computing and Communications; IEEE 14th International Conference on Smart City; IEEE 2nd International Conference on Data Science and Systems (HPCC/SmartCity/DSS)*, pp 1325–1332, DOI 10.1109/HPCC-SmartCity-DSS.2016.0188

- Bellala G, Marwah M, Arlitt M, Lyon G, Bash C (2012) Following the electrons: Methods for power management in commercial buildings. In: Proceedings of the 18th ACM SIGKDD International Conference on Knowledge Discovery and Data Mining, ACM, New York, NY, USA, KDD '12, pp 994–1002, DOI 10.1145/2339530.2339685, URL <http://doi.acm.org/10.1145/2339530.2339685>
- Bellala G, Marwah M, Arlitt M, Lyon G, Bash C, Shah A (2017) Data analytics for managing power in commercial buildings. *ACM Trans Cyber-Phys Syst* 1(4):22:1–22:25, DOI 10.1145/3110219, URL <http://doi.acm.org/10.1145/3110219>
- Chang X, Tan R, Xing G, Yuan Z, Lu C, Chen Y, Yang Y (2011) Sensor placement algorithms for fusion-based surveillance networks. *IEEE Transactions on Parallel and Distributed Systems* 22(8):1407–1414, DOI 10.1109/TPDS.2011.115
- Ciftler BS, Dikmese S, Guvenc A, Akkaya K, Kadri A (2018) Occupancy counting with burst and intermittent signals in smart buildings. *IEEE Internet of Things Journal* 5(2):724–735, DOI 10.1109/JIOT.2017.2756689
- Dua D, Dambhare S, Gajbhiye RK, Soman SA (2008) Optimal multistage scheduling of pmu placement: An ilp approach. *IEEE Transactions on Power Delivery* 23(4):1812–1820, DOI 10.1109/TPWRD.2008.919046
- Ekwevugbe T, Brown N, Fan D (2012) A design model for building occupancy detection using sensor fusion. In: 2012 6th IEEE International Conference on Digital Ecosystems and Technologies (DEST), pp 1–6, DOI 10.1109/DEST.2012.6227924
- El-Shafie M, Fakeih L (2018) The smart environment of commercial buildings. In: 2018 15th Learning and Technology Conference (L T), pp 161–166, DOI 10.1109/LT.2018.8368501
- Eltamaly AM, Mohamed MA, Al-Saud MS, Alolah AI (2017) Load management as a smart grid concept for sizing and designing of hybrid renewable energy systems. *Engineering Optimization* 49(10):1813–1828, DOI 10.1080/0305215X.2016.1261246, URL <https://doi.org/10.1080/0305215X.2016.1261246>, <https://doi.org/10.1080/0305215X.2016.1261246>
- Ghayvat H, Mukhopadhyay S, Gui X, Suryadevara N (2015) Wsn- and iot-based smart homes and their extension to smart buildings. *Sensors* 15(5):10350–10379, DOI 10.3390/s150510350, URL <http://dx.doi.org/10.3390/s150510350>
- Gross G, Finlay D (2000) Generation supply bidding in perfectly competitive electricity markets. *Computational & Mathematical Organization Theory* 6(1):83–98, DOI 10.1023/A:1009677326718, URL <https://doi.org/10.1023/A:1009677326718>
- Gyllstrom D, Rosensweig E, Kurose J (2012) On the impact of pmu placement on observability and cross-validation. In: Proceedings of the 3rd International Conference on Future Energy Systems: Where Energy, Computing and Communication Meet, ACM, New York, NY, USA, e-Energy '12, pp 20:1–20:10, DOI 10.1145/2208828.2208848, URL

- <http://doi.acm.org/10.1145/2208828.2208848>
- Hernández-Ramos JL, Moreno MV, Bernabé JB, Carrillo DG, Skarmeta AF (2015) Safir: Secure access framework for iot-enabled services on smart buildings. *Journal of Computer and System Sciences* 81(8):1452 – 1463, DOI <https://doi.org/10.1016/j.jcss.2014.12.021>, URL <http://www.sciencedirect.com/science/article/pii/S0022000014001858>
- Hnat TW, Srinivasan V, Lu J, Sookoor TI, Dawson R, Stankovic J, Whitehouse K (2011) The hitchhiker’s guide to successful residential sensing deployments. In: *Proceedings of the 9th ACM SenSys*, ACM, NY, USA, pp 232–245
- Iyengar S, Sharma N, Irwin D, Shenoy P, Ramamritham K (2017) A cloud-based black-box solar predictor for smart homes. *ACM Trans Cyber-Phys Syst* 1(4):21:1–21:24, DOI 10.1145/3004056, URL <http://doi.acm.org/10.1145/3004056>
- Kabadayi S, Pridgen A, Julien C (2006) Virtual sensors: abstracting data from physical sensors. In: *2006 International Symposium on a World of Wireless, Mobile and Multimedia Networks(WoWMoM’06)*, pp 6 pp.–592, DOI 10.1109/WOWMOM.2006.115
- Karmakar G, Arote U, Agarwal A, Ramamritham K (2018) Adaptive hybrid approaches to thermal modeling of building. In: *Proceedings of the Ninth International Conference on Future Energy Systems*, ACM, New York, NY, USA, e-Energy ’18, pp 477–479, DOI 10.1145/3208903.3212068, URL <http://doi.acm.org/10.1145/3208903.3212068>
- Krause A, Guestrin C, Gupta A, Kleinberg J (2006) Near-optimal sensor placements: maximizing information while minimizing communication cost. In: *2006 5th International Conference IPSN*, pp 2–10, DOI 10.1145/1127777.1127782
- Li J, Yu ZJ, Haghighat F, Zhang G (2019) Development and improvement of occupant behavior models towards realistic building performance simulation: A review. *Sustainable Cities and Society* 50:101685, DOI <https://doi.org/10.1016/j.scs.2019.101685>, URL <http://www.sciencedirect.com/science/article/pii/S2210670719303774>
- Lu J, Sookoor T, Srinivasan V, Gao G, Holben B, Stankovic J, Field E, Whitehouse K (2010) The smart thermostat: Using occupancy sensors to save energy in homes. In: *Proceedings of the 8th ACM Conference on Embedded Networked Sensor Systems*, ACM, New York, NY, USA, SenSys ’10, pp 211–224, DOI 10.1145/1869983.1870005, URL <http://doi.acm.org/10.1145/1869983.1870005>
- Manousakis NM, Korres GN, Georgilakis PS (2012) Taxonomy of pmu placement methodologies. *IEEE Transactions on Power Systems* 27(2):1070–1077, DOI 10.1109/TPWRS.2011.2179816
- Meyn S, Surana A, Lin Y, Oggianu SM, Narayanan S, Frewen TA (2009) A sensor-utility-network method for estimation of occupancy in buildings. In: *Proceedings of the 48h IEEE Conference on Decision and Control (CDC) held jointly with 2009 28th Chinese Control Conference*, pp 1494–1500

- Minoli D, Sohraby K, Occhiogrosso B (2017) Iot considerations, requirements, and architectures for smart buildings—energy optimization and next-generation building management systems. *IEEE Internet of Things Journal* 4(1):269–283, DOI 10.1109/JIOT.2017.2647881
- Mitchell S, Consulting SM, Dunning I (2011) Pulp: A linear programming toolkit for python
- Mora N, Matrella G, Ciampolini P (2018) Cloud-based behavioral monitoring in smart homes. *Sensors* 18(6), DOI 10.3390/s18061951, URL <http://www.mdpi.com/1424-8220/18/6/1951>
- Noureen SS, Roy V, Bayne SB (2017) Phasor measurement unit integration: A review on optimal pmu placement methods in power system. In: 2017 IEEE Region 10 Humanitarian Technology Conference (R10-HTC), pp 328–332, DOI 10.1109/R10-HTC.2017.8288967
- Pan J, Jain R, Paul S, Vu T, Saifullah A, Sha M (2015) An internet of things framework for smart energy in buildings: Designs, prototype, and experiments. *IEEE Internet of Things Journal* 2(6):527–537, DOI 10.1109/JIOT.2015.2413397
- Phadke AG (1993) Synchronized phasor measurements in power systems. *IEEE Computer Applications in Power* 6(2):10–15, DOI 10.1109/67.207465
- Prakash AK, Prakash VC, Doshi B, Arote U, Sahu PK, Ramaritham K (2015) Locating and sizing smart meter deployment in buildings. In: Proceedings of the 2015 ACM Sixth International Conference on Future Energy Systems, ACM, New York, NY, USA, e-Energy '15, pp 223–224, DOI 10.1145/2768510.2770950, URL <http://doi.acm.org/10.1145/2768510.2770950>
- Radosavljević J, Jevtić M, Klimenta D (2016) Energy and operation management of a microgrid using particle swarm optimization. *Engineering Optimization* 48(5):811–830, DOI 10.1080/0305215X.2015.1057135, URL <https://doi.org/10.1080/0305215X.2015.1057135>, <https://doi.org/10.1080/0305215X.2015.1057135>
- Ree JDL, Centeno V, Thorp JS, Phadke AG (2010) Synchronized phasor measurement applications in power systems. *IEEE Transactions on Smart Grid* 1(1):20–27, DOI 10.1109/TSG.2010.2044815
- Reena KM, Mathew AT, Jacob L (2018) A flexible control strategy for energy and comfort aware hvac in large buildings. *Building and Environment* 145:330 – 342, DOI <https://doi.org/10.1016/j.buildenv.2018.09.016>, URL <http://www.sciencedirect.com/science/article/pii/S036013231830564X>
- Salimi S, Liu Z, Hammad A (2019) Occupancy prediction model for open-plan offices using real-time location system and inhomogeneous markov chain. *Building and Environment* 152:1 – 16, DOI <https://doi.org/10.1016/j.buildenv.2019.01.052>, URL <http://www.sciencedirect.com/science/article/pii/S0360132319300885>
- Stankovic JA (2014) Research directions for the internet of things. *IEEE Internet of Things Journal* 1(1):3–9, DOI 10.1109/JIOT.2014.2312291
- Stojkoska BLR, Trivodaliev KV (2017) A review of internet of things for smart home: Challenges and solutions. *Journal of Cleaner Production*

- 140:1454 – 1464, DOI <https://doi.org/10.1016/j.jclepro.2016.10.006>, URL <http://www.sciencedirect.com/science/article/pii/S095965261631589X>
- Tao L, Gao Y, Liu Y, Zhu H (2019) A rolling penalty function algorithm of real-time pricing for smart microgrids based on bilevel programming. *Engineering Optimization* 0(0):1–18, DOI 10.1080/0305215X.2019.1642882, URL <https://doi.org/10.1080/0305215X.2019.1642882>, <https://doi.org/10.1080/0305215X.2019.1642882>
- Thanayankizil LV, Ghai SK, Chakraborty D, Seetharam DP (2012) Soft-green: Towards energy management of green office buildings with soft sensors. In: 2012 Fourth International Conference on Communication Systems and Networks (COMSNETS 2012), pp 1–6, DOI 10.1109/COMSNETS.2012.6151374
- The Internet of Trash: IoT Has a Looming E-Waste Problem (2018) URL <https://spectrum.ieee.org/telecom/internet/the-internet-of-trash-iot-has-a-looming-ewaste-problem>
- Ujager FS, Mahmood A (2019) A context-aware accurate wellness determination (caawd) model for elderly people using lazy associative classification. *Sensors* 19(7), DOI 10.3390/s19071613, URL <http://www.mdpi.com/1424-8220/19/7/1613>
- Xu B, Abur A (2004) Observability analysis and measurement placement for systems with pmus. In: IEEE PES Power Systems Conference and Exposition, 2004., pp 943–946 vol.2, DOI 10.1109/PSCE.2004.1397683
- Zanella A, Bui N, Castellani A, Vangelista L, Zorzi M (2014) Internet of things for smart cities. *IEEE Internet of Things Journal* 1(1):22–32, DOI 10.1109/JIOT.2014.2306328
- Zuraimi M, Pantazaras A, Chaturvedi K, Yang J, Tham K, Lee S (2017) Predicting occupancy counts using physical and statistical co2-based modeling methodologies. *Building and Environment* 123:517 – 528, DOI <https://doi.org/10.1016/j.buildenv.2017.07.027>, URL <http://www.sciencedirect.com/science/article/pii/S0360132317303268>

Dr. Anshul Agarwal

He did his Ph.D. in the department of Computer Science, IIT Bombay, from where he completed his Masters. He has published numerous papers in ACM e-Energy and ACM BuildSys. His paper was nominated for best paper award in ACM BuildSys '16. He has served as a reviewer in IEEE IOT Journal and International Conference on Power Systems '17. His primary research interests revolve around IoT, Cyber-Physical Systems and Smart Buildings.

Prof. Krithi Ramamritham

He received Ph.D. degree in computer science from the University of Utah. He is currently at IIT Bombay as a professor in the Department of Computer Science. He has served on numerous program committees of conferences and workshops. His editorial board contributions include IEEE Transactions, the Real Time Systems Journal, and the VLDB Journal. He is a fellow of the IEEE, ACM, Indian National Academy of Engineering, and Indian Academy of Science.