

上海氟络国际贸易有限公司

FLUO SHANGHAI INTERNATIONAL TRADE CO.,LTD.

ROOM 2003,NO 1, JILONG ROAD ,CHINA (SHANGHAI)PILOT FREE TRADE ZONE

Tel: +86-021-58710356

Fax: +86-0579-87645878

CERTIFICATE OF ANALYSIS

Sample name: REFRIGERANT GAS R134A

BATCH NO: 20260331

Sample source: 13.6KG PER CYLINDER

Produce time:MARCH 31,2026

Test standard: GB/T 18826-2016

Sampling time: MARCH 31,2026

Density items	Standard demands	Results
Smell	Colourless and no smelling	Colourless and no smelling
Appearance	Colourless and not turbid	Colourless and not turbid
R-134A	≥99.90	99.93
Moisture%	≤0.001	0.00064
Evaporation residue%	≤0.005	0.0006
Acidity (as HCl) %	≤0.0001	<0.0001
Fouling gas %	≤1.5	0.57
Chloride (Cl),%	Conformity	Conformity
Product amount:15803.20KGS	Final conclusion: Conformity	
Tester: HUAIFENG SUN Checker: XIAOHUI KANG Auditor: QI ZHANG	上海氟络国际贸易有限公司 Fluo Shanghai International Trade Co.,Ltd. 潘登	