

上海氟络国际贸易有限公司
FLUO SHANGHAI INTERNATIONAL TRADE CO.,LTD.
ROOM 2003,NO 1, JILONG ROAD ,CHINA (SHANGHAI)PILOT FREE TRADE ZONE
Tel: +86-021-58710356 Fax: +86-0579-87645878

CERTIFICATE OF ANALYSIS

Sample name: REFRIGERANT GAS R404A

BATCH NO: 20260331

Sample source: 10.9KG PER CYLINDER

Produce time: MARCH 31,2026

Test standard: HG/T 5161-2017

Sampling time:MARCH 31,2026

Density items	Standard demands	Results
Smell	Colourless and no smelling	Colourless and no smelling
Appearance	Colourless and not turbid	Colourless and not turbid
Purity,%	≥ 99.9	99.99
HFC-143A,%	52 ± 1	51.7
HFC-125,%	44 ± 2	44.1
HFC-134A,%	4 ± 2	4.2
Moisture%	≤ 0.0010	0.00083
Evaporation residue%	≤ 0.005	0.0008
Acidity (as HCl) %	≤ 0.0001	< 0.0001
Fouling gas %	≤ 1.5	0.31
Chloride (Cl),%	Conformity	Conformity
Product amount:6104.00KGS	Final conclusion: Conformity	
Tester: SHEN LI Checker: ZHEWEI GONG Auditor: SHAOXIONG TANG	上海氟络国际贸易有限公司 Fluo Shanghai International Trade Co.,Ltd. 潘登	