

上海氟络国际贸易有限公司
FLUO SHANGHAI INTERNATIONAL TRADE CO.,LTD.
ROOM 2003,NO 1, JILONG ROAD ,CHINA (SHANGHAI)PILOT FREE TRADE ZONE
Tel: +86-021-58710356 Fax: +86-0579-87645878

CERTIFICATE OF ANALYSIS

Sample name: REFRIGERANT GAS R410A

BATCH NO: 20260331

Sample source: 11.3KG PER CYLINDER

Produce time: MARCH 31,2026

Test standard: HG/T 5162-2017

Sampling time:MARCH 31,2026

Density items	Standard demands	Results
Appearance	Colorless、no turbid	Colourless and not turbid
Propylene percent,%	≥99.9	99.99
HFC-32,%	49.5±1	50.2
HFC-125,%	50.5±1	49.8
Moisture%	≤0.0010	0.00086
Evaporation residue%	≤0.005	0.0008
Acidity (as HCl) %	≤0.0001	<0.0001
Fouling gas %	≤1.5	0.21
Chloride (Cl),%	Conformity	Conformity
Product amount:9040.00KGS	Final conclusion: Conformity	
Tester: SHEN LI Checker: ZHEWEI GONG Auditor: SHAOXIONG TANG	上海氟络国际贸易有限公司 Fluo Shanghai International Trade Co.,Ltd. 潘 登	